

## EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management  
Fisher Controls International LLC  
205 South Center Street  
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following products considered as,

**Non-electrical instrumentation  
(pneumatic – positioners, controllers, transmitters, volume boosters, and switches)**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



---

Danny Nelson

Vice President – Instrument Business Unit

---

14-March-2016

Date

**European Contact**

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

**ATEX Directive – 2014/34/EU** (Applicable only if this mark  appears on the product)

Non-electrical instrumentation – **Group II Category 2 GD**

Equipment is marked as follows:



Standards used: EN13463-1:2009, EN1127-1:2011

The Technical Documentation has been submitted and retained by the Notified Body:

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom

**PED Directive – 2014/68/EU**

Declaration of SEP

Models: Non-electrical instrumentation (pneumatic – positioners, controllers, transmitters, volume boosters, and switches)

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.

## EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management  
Fisher Controls International LLC  
205 South Center Street  
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product;

**Digital Level Controller  
DLC3010**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



---

Danny Nelson

Vice President – Instrument Business Unit

---

14-March-2016

Date

**European Contact**

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

## **EMC Directive – 2014/30/EU**

All models

EN 61326-1:2013  
EN61326-2-3:2006

## **ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)**

Certificate – **LCIE01ATEX6053X – Group II Category 1 GD – Intrinsically Safe & Dust**

DLC3010

Ex ia IIC T5(Ta ≤ 80°C) Ga

Ex ia IIIC T83°C(Ta ≤ 80°C) Da, IP66

Standards used: EN60079-0:2012 + A11:2013 and EN60079-11:2012

Certificate – **LCIE01ATEX6054X – Group II Category 2 GD – Flameproof & Dust**

DLC3010

Ex d IIC T5(Ta ≤ 80°C) Gb

Ex tb IIIC T83°C(Ta ≤ 80°C) Db, IP66

Standards used: EN60079-0:2012 + A11:2013, EN60079-1:2007 and EN60079-31:2009

Certificate – **LCIE02ATEX6055X – Group II Category 3 GD – Type n & Dust**

DLC3010

Ex nA IIC T5(Ta ≤ 80°C) Gc

Ex tc IIIC T83°C(Ta ≤ 80°C) Dc, IP66

Standards used: EN60079-0:2012 + A11: 2013, EN60079-15:2010 and EN60079-31:2009

### **ATEX Notified Body for EC-Type Examination Certificate(s)**

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081

33 Avenue du General Leclerc BP 8

F92233 Fontenay-aux-Roses cedex

France

### **ATEX Notified Body for Quality Assurance**

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom

## EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management  
Fisher Controls International LLC  
205 South Center Street  
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Digital Valve Controllers  
DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S  
DVC6010F, DVC6020F, DVC6030F, DVC6010FS, DVC6020FS, DVC6030FS  
DVC6005, DVC6005F, DVC6015, DVC6025, DVC6035  
DVC6200, DVC6200S, DVC6200F, DVC6200FS, DVC6200P, DVC6200PS  
DVC6205, DVC6205F, DVC6205P, DVC6215**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



---

Danny Nelson

Vice President – Instrument Business Unit

---

14-March-2016

Date

**European Contact**

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

## **EMC Directive – 2014/30/EU**

All models

EN 61326-1:2013

## **PED Directive – 2014/68/EU**

Declaration of SEP

Models: DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S, DVC6005, DVC6005F, DVC6200, DVC6200S, DVC6200F, DVC6200FS, DVC6200P, DVC6200PS, DVC6205, DVC6205F, DVC6205P

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.

## **ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)**

Certificate – **LCIE02ATEX6002X – Group II Category 1 GD** – Intrinsically Safe & Dust

--WHEN INSTALLED PER DWG GE60771--

### HART – HW1

DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S, DVC6005, DVC6200, DVC6200S

Ex ia IIC or IIB T5(Ta ≤ 80°C), T6(Ta ≤ 75°C) Ga

DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S

Ex ia IIIC T92°C(Ta ≤ 80°C) / T85°C(Ta ≤ 73°C) Da

DVC6005, DVC6200, DVC6200S

Ex ia IIIC T89°C(Ta ≤ 80°C) / T85°C(Ta ≤ 76°C) Da

### HART – HW2 without I/O Package

DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S, DVC6005, DVC6200, DVC6200S, DVC6205

Ex ia IIC T5(Ta ≤ 80°C), T6(Ta ≤ 74°C) Ga

DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S

Ex ia IIIC T101°C(Ta ≤ 80°C) / T85°C(Ta ≤ 64°C) Da

DVC6005, DVC6200, DVC6200S, DVC6205

Ex ia IIIC T91°C(Ta ≤ 80°C) / T85°C(Ta ≤ 74°C) Da

### HART – HW2 with I/O Package

DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S, DVC6005, DVC6200, DVC6200S, DVC6205

Ex ia IIC or IIB T5(Ta ≤ 80°C), T6(Ta ≤ 61°C) Ga

Ex ia IIIC T104°C(Ta ≤ 80°C) / T85°C(Ta ≤ 61°C) Da

### FIELDBUS & PROFIBUS

DVC6010F, DVC6020F, DVC6030F, DVC6010FS, DVC6020FS, DVC6030FS, DVC6005F, DVC6200F,

DVC6200FS, DVC6200P, DVC6200PS, DVC6205F, DVC6205P

Ex ia IIC T4(Ta ≤ 80°C), T5(Ta ≤ 77°C), T6(Ta ≤ 62°C) Ga

Ex ia IIIC T103°C(Ta ≤ 80°C) / T100°C(Ta ≤ 77°C) / T85°C(Ta ≤ 62°C) Da

### FEEDBACK ASSEMBLY

DVC6015, DVC6025, DVC6035

Ex ia IIC T4(Ta ≤ 125°C), T5(Ta ≤ 95°C), T6(Ta ≤ 80°C) Ga

Ex ia IIIC T146°C(Ta ≤ 125°C) / T135°C(Ta ≤ 114°C) / T100°C(Ta ≤ 79°C) / T85°C(Ta ≤ 64°C) Da

DVC6215 – Excludes Dust

Ex ia IIC T4(Ta ≤ 125°C), T5(Ta ≤ 95°C), T6(Ta ≤ 80°C) Ga

Standards used: EN60079-0:2012 + A11:2013, EN60079-11:2012

Certificate – **LCIE02ATEX6001X – Group II Category 2 G** – Flameproof

DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S, DVC6010F, DVC6020F, DVC6030F, DVC6010FS, DVC6020FS, DVC6030FS, DVC6005, DVC6005F, DVC6200, DVC6200F, DVC6200P, DVC6200S, DVC6200FS, DVC6200PS, DVC6205, DVC6205F, DVC6205P

Ex d IIC T5(Ta ≤ 85°C), T6(Ta ≤ 80°C) Gb

DVC6015, DVC6025, DVC6035, DVC6215

Ex d IIC T4( $T_a \leq 125^\circ\text{C}$ ), T5( $T_a \leq 95^\circ\text{C}$ ), T6( $T_a \leq 80^\circ\text{C}$ ) Gb  
Standards used: EN60079-0:2012 + A11:2013, EN60079-1:2007

**Certificate – LCIE02ATEX6003X – Group II Category 3 G – Type n**

DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S, DVC6010F, DVC6020F, DVC6030F,  
DVC6010FS, DVC6020FS, DVC6030FS, DVC6005, DVC6005F, DVC6200, DVC6200F, DVC6200P, DVC6200S,  
DVC6200FS, DVC6200PS, DVC6205, DVC6205F, DVC6205P

Ex nC IIC T5( $T_a \leq 80^\circ\text{C}$ ), T6( $T_a \leq 75^\circ\text{C}$ ) Gc  
DVC6015, DVC6025, DVC6035, DVC6215

Ex nA IIC T4( $T_a \leq 125^\circ\text{C}$ ), T5( $T_a \leq 95^\circ\text{C}$ ), T6( $T_a \leq 80^\circ\text{C}$ ) Gc  
Standards used: EN60079-0:2012 + A11:2013, EN60079-15:2010

ATEX Notified Body for EC-Type Examination Certificate(s)

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081  
33 Avenue du General Leclerc BP 8  
F92233 Fontenay-aux-Roses cedex  
France

ATEX Notified Body for Quality Assurance

SGS Baseefa Limited – Notified Body Number: 1180  
Rockhead Business Park  
Staden Lane, Buxton, Derbyshire SK17 9RZ  
United Kingdom

## EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management  
Fisher Controls International LLC  
205 South Center Street  
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Electro-pneumatic Converters  
3622, 3722 582i**

**Electro-pneumatic Transducer  
646**

**Electro-pneumatic Positioner  
3661**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



---

Danny Nelson

Vice President – Instrument Business Unit

---

14-March-2016

Date

**European Contact**

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France



## **EMC Directive – 2014/30/EU**

All models

EN 61326-1:2013

## **PED Directive – 2014/68/EU**

Declaration of SEP

Models: 3622, 3722, 582i, 646, 3661

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.

## **ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)**

Certificate – **LCIE03ATEX6001X – Group II Category 1 GD – Intrinsically Safe & Dust**

3622, 3722

Ex ia IIC T4(Ta ≤ 82°C), T5(Ta ≤ 62°C), T6(Ta ≤ 47°C) Ga

Ex ia IIIC T120°C(Ta ≤ 82°C) / T100°C(Ta ≤ 62°C) / T85°C(Ta ≤ 47°C) Da, IP64

582i

Ex ia IIC T4(Ta ≤ 71°C), T5(Ta ≤ 62°C), T6(Ta ≤ 47°C) Ga

Ex ia IIIC T109°C(Ta ≤ 71°C) / T100°C(Ta ≤ 62°C) / T85°C(Ta ≤ 47°C) Da, IP64

646

Ex ia IIC T4(Ta ≤ 71°C), T5(Ta ≤ 40°C) Ga

Ex ia IIIC T155°C(Ta ≤ 71°C) / T124°C(Ta ≤ 40°C) Da, IP64

3661 – Excludes Dust

Ex ia IIC T4(Ta ≤ 82°C), T5(Ta ≤ 62°C), T6(Ta ≤ 47°C) Ga

Standards used: EN60079-0:2012, EN60079-11:2012

Certificate – **KEMA04ATEX2137X – Group II Category 2 GD – Flameproof & Dust**

582i, 646

Ex d IIC T6(Ta ≤ 71°C) Gb

Ex tb IIIC T74°C(Ta ≤ 71°C) Db

3622, 3722

Ex d IIC T5(Ta ≤ 82°C) Gb

Ex tb IIIC T82°C(Ta ≤ 79°C) Db

Standards used: EN60079-0:2012, EN60079-1:2007, EN60079-31:2009

Certificate – **LCIE03ATEX6002X – Group II Category 3 GD – Type n & Dust**

3622, 3722

Ex nA IIC T6(Ta ≤ 82°C) Gc

Ex tc IIIC T85°C(Ta ≤ 82°C) Dc, IP64

582i

Ex nA IIC T6(Ta ≤ 71°C) Gc

Ex tc IIIC T85°C(Ta ≤ 71°C) Dc, IP64

646

Ex nA IIC T6(Ta ≤ 71°C) Gc

Ex tc IIIC T85°C(Ta ≤ 71°C) Dc, IP64

3661 – Excludes Dust

Ex nA IIC T6(Ta ≤ 82°C) Gc

Standards used: EN60079-0:2012, EN60079-15:2010, EN60079-31:2009

### **ATEX Notified Body for EC-Type Examination Certificate(s)**

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081

33 Avenue du General Leclerc BP 8

F92233 Fontenay-aux-Roses cedex

France

DEKRA Certification B.V. – Notified Body Number: 0344  
Utrechtseweg 310  
6812 AR Arnhem  
P.O. Box 5185  
6802 ED Arnhem  
The Netherlands

ATEX Notified Body for Quality Assurance

SGS Baseefa Limited – Notified Body Number: 1180  
Rockhead Business Park  
Staden Lane, Buxton, Derbyshire SK17 9RZ  
United Kingdom

## EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management  
Fisher Controls International LLC  
205 South Center Street  
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Position Transmitter  
4210, 4211, 4221, 4215, 4220, 4221, 4222**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



---

Danny Nelson

Vice President – Instrument Business Unit

---

14-March-2016

Date

**European Contact**

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

## **EMC Directive – 2014/30/EU**

All models

EN 61326-1:2013

## **ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)**

Certificate – **LCIE03ATEX6220X – Group II Category 1 GD** – Intrinsically Safe & Dust

4211, 4221

Ex ia IIC T4(Ta ≤ 71°C), T5(Ta ≤ 40°C) Ga

Ex ta IIIC T81°C(Ta ≤ 71°C), T50°C(Ta ≤ 40°C) Da, IP66

Standards used: EN60079-0:2009, EN60079-11:2012, EN60079-26:2007, EN60079-31:2009

Certificate – **SIRA11ATEX1344 – Group II Category 2 GD** – Flameproof & Dust

4210, 4211, 4212, 4215, 4220, 4221, 4222

Ex d IIC T5(Ta ≤ 71°C), T6(Ta ≤ 56°C) Gb

Ex tb IIIC T72°C(-20°C ≤ Ta ≤ 56°C) Db, IP66

Standards used: EN60079-0:2009, EN60079-1:2007, EN60079-31:2009

Certificate – **LCIE03ATEX6219 – Group II Category 3 GD** – Type n & Dust

4211, 4221

Ex nA IIC T4(Ta ≤ 71°C) Gc

Ex tc IIIC T81°C(Ta ≤ 71°C) Dc, IP66

Standards used: EN60079-0:2009, EN60079-15:2010, EN60079-31:2009

### **ATEX Notified Body for EC-Type Examination Certificate(s)**

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081

33 Avenue du General Leclerc BP 8

F92233 Fontenay-aux-Roses cedex

France

SIRA Certification Service – Notified Body Number: 0518

Rake Lane, Eccleston

Chester, CH4 9JN

United Kingdom

### **ATEX Notified Body for Quality Assurance**

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom

## EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management  
Fisher Controls International LLC  
205 South Center Street  
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Electro-pneumatic Transducer  
846**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



---

Danny Nelson

Vice President – Instrument Business Unit

---

14-March-2016

Date

**European Contact**

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

## **EMC Directive – 2014/30/EU**

All models  
EN 61326-1:2013

## **PED Directive – 2014/68/EU**

Declaration of SEP

Models: 846

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.

## **ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)**

Certificate – **LCIE03ATEX6298X – Group II Category 1 GD** – Intrinsically Safe & Dust  
846

Ex ia IIC T4(Ta ≤ 80°C), T5(Ta ≤ 40°C) Ga  
Ex ia IIIC T90°C(Ta ≤ 80°C) / T50°C(Ta ≤ 40°C) Da, IP66  
Standards used: EN60079-0:2012, EN60079-11:2012, EN60079-26:2007

Certificate – **Baseefa05ATEX0130X – Group II Category 2 G** – Flameproof  
846

Ex d IIB T5(Ta ≤ 80°C), T6(Ta ≤ 65°C) Gb  
Standards used: EN60079-0:2012, EN60079-1:2007

Certificate – **LCIE03ATEX6299 – Group II Category 3 GD** – Type n & Dust  
846

Ex nA IIC T5(Ta ≤ 85°C), T6(Ta ≤ 74°C) Gc  
Ex tc IIIC T88°C(Ta ≤ 85°C) T<sub>500</sub> / T77°C(Ta ≤ 74°C) T<sub>500</sub> Dc, IP66  
Standards used: EN60079-0:2012, EN60079-15:2010, EN60079-31:2009

### **ATEX Notified Body for EC-Type Examination Certificate(s)**

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081  
33 Avenue du General Leclerc BP 8  
F92233 Fontenay-aux-Roses cedex  
France

SGS Baseefa Limited – Notified Body Number: 1180  
Rockhead Business Park  
Staden Lane, Buxton, Derbyshire SK17 9RZ  
United Kingdom

### **ATEX Notified Body for Quality Assurance**

SGS Baseefa Limited – Notified Body Number: 1180  
Rockhead Business Park  
Staden Lane, Buxton, Derbyshire SK17 9RZ  
United Kingdom

## **EU Declaration of Conformity**

We, the manufacturer,


**Emerson Process Management  
Fisher Controls International LLC  
205 South Center Street  
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Digital Valve Controller  
DVC2000**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



---

Danny Nelson  
Vice President – Instrument Business Unit

---

29-March-2017

---

Date

**European Contact**

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

## **EMC Directive – 2014/30/EU**

All models  
EN 61326-1:2013

## **PED Directive – 2014/68/EU**

Declaration of SEP

Models: DVC2000

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.

## **ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)**

Certificate – LCIE05ATEX6009X – Group II Category 1 G – Intrinsically Safe  
DVC2000

Ex ia IIC T4(Ta ≤ 80°C), T5(Ta ≤ 40°C) Ga

Standards used: EN60079-0:2012 + A11: 2013, EN60079-11:2012

### ATEX Notified Body for EC-Type Examination Certificate(s)

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081

33 Avenue du General Leclerc BP 8

F92233 Fontenay-aux-Roses cedex

France

### ATEX Notified Body for Quality Assurance

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom



## EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management  
Fisher Controls International LLC  
205 South Center Street  
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Electro-pneumatic Transducer  
i2P-100**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



---

Danny Nelson

Vice President – Instrument Business Unit

---

14-March-2016

Date

**European Contact**

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

## **EMC Directive – 2014/30/EU**

All models  
EN 61326-1:2013

## **PED Directive – 2014/68/EU**

Declaration of SEP

Models: i2P-100

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.

## **ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)**

Certificate – **LCIE15ATEX3008X – Group II Category 1, 2 GD** – Intrinsically Safe, Flameproof, & Dust  
i2P-100

Ex ia IIC T3(Ta ≤ 85°C), T4(Ta ≤ 81°C), T5(Ta ≤ 46°C) Ga

Ex ia IIIC T95°C(Ta ≤ 85°C) Da

Ex d IIC T5(Ta ≤ 85°C), T6(Ta ≤ 75°C) Gb

Ex tb IIIC T95°C(Ta ≤ 85°C) Db, IP64

Standards used: EN60079-0:2012 + A11:2013, EN60079-1:2007, EN60079-11:2012, EN60079-31:2009

Certificate – **LCIE15ATEX1008 – Group II Category 3 GD** – Type n & Dust

i2P-100

Ex nC IIC T5(Ta ≤ 85°C), T6(Ta ≤ 75°C) Gc

Ex tc IIIC T95°C(Ta ≤ 85°C) Dc, IP64

Standards used: EN60079-0:2012 + A11:2013, EN60079-15:2010, EN60079-31:2009

### **ATEX Notified Body for EC-Type Examination Certificate(s)**

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081

33 Avenue du General Leclerc BP 8

F92233 Fontenay-aux-Roses cedex

France

### **ATEX Notified Body for Quality Assurance**

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom

## EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management  
Fisher Controls International LLC  
205 South Center Street  
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Local Control Panel  
LCP100**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



---

Danny Nelson

Vice President – Instrument Business Unit

---

14-March-2016

Date

**European Contact**

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

## **EMC Directive – 2014/30/EU**

All models  
EN 61326-1:2013

## **ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)**

Certificate – **SIRA15ATEX2194X – Group II Category 1 G** – Intrinsically Safe  
LCP100  
Ex ia IIB T4( $T_a \leq 65^\circ\text{C}$ ) Ga  
Standards used: EN60079-0:2012, EN60079-11:2012, EN60079-26:2015

Certificate – **SIRA08ATEX3335X – Group II Category 2 G** – Increased Safety, Encapsulation, Intrinsically Safe  
LCP100  
Ex e mb [ib] IIC T4( $T_a \leq 65^\circ\text{C}$ ) Gb, IP66  
Standards used: EN60079-0:2012 +A11:2013, EN60079-7:2007, EN60079-11:2012, EN60079-18:2015

Certificate – **SIRA12ATEX4216X – Group II Category 3 G** – Intrinsically Safe  
LCP100  
Ex ic IIC T4( $T_a \leq 65^\circ\text{C}$ ) Gc  
Standards used: EN60079-0:2012 +A11:2013, EN60079-11:2012

### **ATEX Notified Body for EC-Type Examination Certificate(s)**

SIRA Certification Services – Notified Body Number: 0518  
Rake Lane, Eccleston  
Chester CH4 9JN  
United Kingdom

### **ATEX Notified Body for Quality Assurance**

SGS Baseefa Limited – Notified Body Number: 1180  
Rockhead Business Park  
Staden Lane, Buxton, Derbyshire SK17 9RZ  
United Kingdom

## EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management  
Fisher Controls International LLC  
205 South Center Street  
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**On/Off  
Wireless Position Monitor**

**TopWorx 4310  
4310 Battery Power with or without Pneumatic Output  
4310 External Power with or without Pneumatic Output**

**Fisher 4320  
4320 Battery Power with or without Pneumatic Output  
4320 External Power with or without Pneumatic Output**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



---

Danny Nelson

Vice President – Instrument Business Unit

---

14-March-2016

Date

**European Contact**

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

## **EMC Directive – 2014/30/EU**

All models  
EN 61326-1:2013

## **RED Directive – 2014/53/EU**

All models  
EN 301 489-1:1.9.2:2011, EN 301 489-17:2.2.1:2012, IEC 61010-1:2010

## **PED Directive – 2014/68/EU**

Declaration of SEP

Models: 4310, 4320 – Battery Power with Pneumatic Output, 4310, 4320 – External Power with Pneumatic Output

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.

## **ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)**

Certificate – LCIE13ATEX3059X – Group II Category 1 G – Intrinsically Safe

4310, 4320 – Battery Power without Pneumatic Output

Ex ia IIC T3(-40°C ≤ Ta ≤ 85°C), T4(-40°C ≤ Ta ≤ 75°C), T5(-40°C ≤ Ta ≤ 40°C) Ga

4310, 4320 – Battery Power with Pneumatic Output

Ex ia IIC T4(-20°C ≤ Ta ≤ 50°C), T5(-20°C ≤ Ta ≤ 46°C), T6(-20°C ≤ Ta ≤ 31°C) Ga

4310, 4320 – External Power without Pneumatic Output

Ex ia IIC T5(-40°C ≤ Ta ≤ 80°C) Ga

4310, 4320 – External Power with Pneumatic Output

Ex ia IIC T5(-20°C ≤ Ta ≤ 50°C) Ga

Standards used: EN60079-0:2012 + A11:2013, EN60079-11:2012

### ATEX Notified Body for EC-Type Examination Certificate(s)

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081  
33 Avenue du General Leclerc BP 8  
F92233 Fontenay-aux-Roses cedex  
France

### ATEX Notified Body for Quality Assurance

SGS Baseefa Limited – Notified Body Number: 1180  
Rockhead Business Park  
Staden Lane, Buxton, Derbyshire SK17 9RZ  
United Kingdom

## EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management  
Fisher Controls International LLC  
205 South Center Street  
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product;

**Digital Level Controller  
DLC3020F**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



---

Danny Nelson

Vice President – Instrument Business Unit

---

14-March-2016

Date

**European Contact**

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

## **EMC Directive – 2014/30/EU**

All models

EN 61326-1:2013  
EN61326-2-3:2006

## **ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)**

Certificate – **LCIE10ATEX3091X – Group II Category 1 GD** – Intrinsically Safe & Dust

DLC3020F

Ex ia IIC T5(Ta ≤ 80°C), T6(Ta ≤ 73°C) Ga

Ex ia IIIC T87°C(Ta ≤ 80°C) / T80°C(Ta ≤ 73°C) Da, IP66

Standards used: EN60079-0:2012 + A11:2013, EN60079-11:2012

Certificate – **LCIE10ATEX3076 – Group II Category 2 GD** – Flameproof & Dust

DLC3020F

Ex d IIC T5(Ta ≤ 80°C), T6(Ta ≤ 73°C) Gb

Ex tb IIIC T87°C(Ta ≤ 80°C) / T80°C (Ta ≤ 73°C) Db, IP66

Standards used: EN60079-0:2012 + A11:2013, EN60079-1:2007, EN60079-31:2014

Certificate – **LCIE10ATEX1010 – Group II Category 3 GD** – Type n & Dust

DLC3020F

Ex nA IIC T5(Ta ≤ 80°C), T6(Ta ≤ 73°C) Gc

Ex tc IIIC T87°C(Ta ≤ 80°C) / T80°C(Ta ≤ 73°C) Dc, IP66

Standards used: EN60079-0:2012 + A11:2013, EN60079-15:2010, EN60079-31:2014

### **ATEX Notified Body for EC-Type Examination Certificate(s)**

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081  
33 Avenue du General Leclerc BP 8  
F92233 Fontenay-aux-Roses cedex  
France

### **ATEX Notified Body for Quality Assurance**

SGS Baseefa Limited – Notified Body Number: 1180  
Rockhead Business Park  
Staden Lane, Buxton, Derbyshire SK17 9RZ  
United Kingdom



## EU Declaration of Conformity

We, the manufacturer,


**Emerson Process Management  
Fisher Controls International LLC  
205 South Center Street  
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Electric Actuator  
easy-Drive**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



---

Michael W McCarty  
Vice President – Advanced Research and  
Marketing

---

26-May-2016

Date


**European Contact**

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

**EMC Directive – 2014/30/EU**

All models

EN 61326-1:2013

**ATEX Directive – 2014/34/EU (Applicable only if this mark  appears on the product)**

Certificate – **SIRA12ATEX1168X – Group II Category 2 G** – Flameproof  
easy-Drive

Ex db IIA T6(Ta ≤ 70°C) Gb

Standards used: EN60079-0:2012/A11:2013, EN60079-1:2014

**ATEX Notified Body for EC-Type Examination Certificate(s)**

SIRA Certification Service – Notified Body Number: 0518

Unit 6, Hawarden Industrial Park,

Hawarden, CH5 3US

United Kingdom

**ATEX Notified Body for Quality Assurance**

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom

## EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management  
Fisher Controls International LLC  
205 South Center Street  
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Electro-pneumatic Transducer  
546, 546NS**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



---

Josh Wilford  
Vice President – Engineered Products

11-July-2016

---

Date

**European Contact**

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

## **EMC Directive – 2014/30/EU**

All models

EN 61326-1:2013

## **PED Directive – 2014/68/EU**

Declaration of SEP

Models: 546, 546NS

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.