

ATEX Hazardous Area Approvals Fisher™ LCP100 Local Control Panel

Hazardous Area Classifications and Special Instructions for “Safe Use” and Installations in Hazardous Locations

Certain nameplates may carry more than one approval, and each approval may have unique installation/wiring requirements and/or conditions of “safe use”. These special instructions for “safe use” are in addition to, and may override, the standard installation procedures. Special instructions are listed by approval.

Note

This information supplements the nameplate markings affixed to the product and the LCP100 Local Control Panel instruction manual ([D103272X012](#)), available from your Emerson sales office, Local Business Partner, or at [Fisher.com](#).

Always refer to the nameplate itself to identify the appropriate certification.

⚠ WARNING

Failure to follow these conditions of “safe use” could result in personal injury or property damage from fire or explosion, or area re-classification.

⊕ II 1G Ex ia IIB T4 Ga

⊕ II 2G Ex e mb [ib] IIC T4 Gb

⊕ II 3G Ex ic IIC T4 Gc

Ta = -40°C to +65°C

IP66

Ex ia IIB

Standards Used for Certification

EN 60079-0:2012
EN 60079-11:2012
EN 60079-26:2015

Entity parameters

Refer to drawing GE75327, shown in figure 1, 2, and 3.

Special Conditions for Safe Use

1. The 24 VDC input terminals shall not be used.
2. Under certain extreme circumstances, the plastic enclosure may store an ignition-capable level electrostatic charge. Precautions shall be taken to prevent the build up of electrostatic charge by charge-generating mechanisms, e.g. do not rub with a solvent, as indicated on the product nameplate.

Ex ic IIC and Ex e mb [ib] IIC

Standards Used for Certification

EN 60079-0:2012: +A11:2013
EN 60079-7:2007
EN 60079-11:2012
EN 60079-18:2015

Entity parameters


Ex ic IIC

$U_i = 27$ VDC
 $C_i = 1.1$ nF
 $L_i = 0$

Special Conditions for Safe Use

1. For Ex ic installations, it is not permitted to connect separate supplies to the LOOP+/LOOP- and AUX+/LOOP- terminals.
2. In 24VDC mode, do not connect to LOOP+. In Loop mode, do not connect to 24VDC+/24VDC-.

Figure 1. Wiring Configuration from Barrier to Fisher DVC6200 SIS to LCP100 - Loop-Powered Only (Drawing GE75327) (See Notes in Figure 2)



GE75327-Sheet 1


Figure 2. Schematic Notes for Figure 1 and Figure 3

NOTES:

1. FOR Ex ia APPLICATIONS THE FOLLOWING INFORMATION SHALL BE OBSERVED.
 - a) THE POWER SELECTOR SWITCH MUST BE POSITIONED IN THE "LOOP" MODE POSITION.
 - b) NO WIRING CONNECTIONS SHALL BE MADE TO THE 24 VDC POWER TERMINALS.
 - c) THE OVERALL GAS GROUP RATING OF THE INTRINSICALLY SAFE CIRCUIT WILL BE LOWEST GAS GROUPING OF ALL APPARATUS FORMING THE CIRCUIT. FOR EXAMPLE, A CIRCUIT WITH BOTH IIB AND IIC APPARATUS WILL HAVE AN OVERALL CIRCUIT GAS RATING OF IIB.
 - d) THE LEVEL OF PROTECTION OF THE INTRINSICALLY SAFE CIRCUIT WILL BE THE LOWEST LEVEL OF ALL APPARATUS FORMING THE CIRCUIT. FOR EXAMPLE, A CIRCUIT WITH BOTH "ia" AND "ib" WILL HAVE AN OVERALL PROTECTION RATING OF "ib".
2. THE PERMISSIBLE INPUT VOLTAGE U_i , INPUT CURRENT i_i AND INPUT POWER P_i OF EACH APPARATUS SHALL BE GREATER THAN OR EQUAL TO THE OUTPUT VOLTAGE U_o , OUTPUT CURRENT i_o , AND OUTPUT POWER P_o OF THE ASSOCIATED APPARATUS (BARRIER).
3. INSTALLATION OF THE LCP100 IS SUCH THAT ITS LOOP TERMINALS WILL BE CONNECTED IN PARALLEL WITH OTHER INTRINSICALLY SAFE APPARATUS LOOP TERMINALS. THE WIRING COMING FROM THE BARRIER INTO THE HAZARDOUS LOCATION MAY BE TERMINATED AT EITHER THE INTRINSICALLY SAFE APPARATUS, AS SHOWN IN FIGURE 1 OR AT THE LCP100, AS SHOWN IN FIGURE 3.

GE75327-Sheet 1

Figure 3. Wiring Configuration from Barrier to Fisher LCP100 to DVC6200 SIS - Loop-Powered Only (Drawing GE75327) (See Notes in Figure 2)



GE75327-Sheet 2

Neither Emerson, Emerson Automation Solutions, nor any of their affiliated entities assumes responsibility for the selection, use or maintenance of any product. Responsibility for proper selection, use, and maintenance of any product remains solely with the purchaser and end user.

Fisher is a mark owned by one of the companies in the Emerson Automation Solutions business unit of Emerson Electric Co. Emerson Automation Solutions, Emerson, and the Emerson logo are trademarks and service marks of Emerson Electric Co. All other marks are the property of their respective owners.

The contents of this publication are presented for informational purposes only, and while every effort has been made to ensure their accuracy, they are not to be construed as warranties or guarantees, express or implied, regarding the products or services described herein or their use or applicability. All sales are governed by our terms and conditions, which are available upon request. We reserve the right to modify or improve the designs or specifications of such products at any time without notice.

Emerson Automation Solutions
 Marshalltown, Iowa 50158 USA
 Sorocaba, 18087 Brazil
 Cernay, 68700 France
 Dubai, United Arab Emirates
 Singapore 128461 Singapore

www.Fisher.com

