

EC Declaration of Conformity

We, the manufacturer,

Bristol, Inc.
dba Remote Automation Solutions
1100 Buckingham Street
Watertown, CT 06795 USA

declare under our sole responsibility that the following ROC800 Series product,

Model W40203 Foundation Fieldbus Interface

bearing the following markings: **EEx nA IIC T4 (T_{amb}= -40°C to +75°C)** **CE** **Ex** **II 3 G**

is in conformity with the following standard(s):

(ATEX Directive)

- EN 60079-15:2003
- EN 50014:1997 +A1 +A2

as stated in Type Examination Certificate

SIRA 05ATEX4046X

(Category 3, Type n)

following the provisions of the ATEX Directive 94/9/EC with assessment by the Notified Body

Sira Certification Service (0518)

Rake Lane, Eccleston, Chester, CH4 9JN
United Kingdom


(EMC Directive)

- EN 55011:2007/A2:2007 Group 1 Class A ISM Emissions
- EN 61000-4-2:2001
- EN 61000-4-3:2006
- EN 61000-4-4:1995
- EN 61000-4-6:2006

following the provisions of the EMC Directive 2004/108/EC

European Contact

Emerson Process Management
Remote Automation Solutions
Waterfront Business Park, Dudley Rd.
Dudley DYS 1LX
United Kingdom



Brian LaMothe
Vice President, Technology

1-04-2014

Date