



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1019698 (83777-12)

Master Contract: 179806

Project: 1756783

Date Issued: 2006/01/27

Issued to: Fisher Service Company
1612 S 17th Ave
Marshalltown, Iowa 50158
USA
Attention: Mr. Dennis Sickels

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: Andrea Holbeche

Authorized by: Patricia Pasemko, Operations Manager

PRODUCTS

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Div. 2, Groups A, B, C and D:

- Types ROC306 and ROC312 Remote Operations Controllers, rated 8-30V dc, 1VA nominal, 12VA max; max ambient 75C, Temp Code T4:

Note: For mounting in suitable enclosures where the final assembly is subject to acceptance of CSA International or the inspection authority having jurisdiction.

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Certificate: 1019698 (83777-12)

Master Contract: 179806

Project: 1756783

Date Issued: 2006/01/27

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 142-M1987 - Process Control Equipment

CSA Std C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

UL Std No. 916 - Energy Management Equipment

UL Std No. 1604 - Electrical Equipment for Use in Class I and II, Division 2; Class III Hazardous (Classified) Locations



CSA INTERNATIONAL

Supplement to Certificate of Compliance

Certificate: 1019698

Master Contract: 179806

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1756783	2006/01/27	Remote Operations Controllers, Update of Report to cover revised documentation

History

- 1248694 April 19/2002 Minor revisions and updates.
- 1081786 June 27/2000 Minor revisions and updates.
- 1019698 Jan. 5, 2000 Alternate Communications Card and Addition of DPI Module.
- 37 Oct. 20/99 Minor revisions and alternate MCU PCB.
- 31 Sept. 10/98 Minor Revisions and Add Models W20264, and W20151.
- 28 Dec. 22/97 NRTL/C and minor revisions.
- 22 Feb. 12/97 Minor revisions and FlashPac and RS Modules.
- 18 June 26/96 Minor revisions and addition of I/O Modules.