

ULTRA 3000 DEFINITION SPECIFICATION

ULTRA 3000

METRIC

SINGLE ORIFICE DEFINITION

STARTUP CONFIGURATION

(1-36SD, 1-RTD)

Part Number 3-9003-310

Revision A

APRIL 1995

DANIEL

**DANIEL INDUSTRIES, INC.
ULTRA 3000
METRIC SINGLE ORIFICE DEFINITION
STARTUP CONFIGURATION**

NOTICE

DANIEL INDUSTRIES, INC. AND DANIEL MEASUREMENT AND CONTROL ("DANIEL") SHALL NOT BE LIABLE FOR TECHNICAL OR EDITORIAL ERRORS IN THIS MANUAL OR OMISSIONS FROM THIS MANUAL. **DANIEL MAKES NO WARRANTIES, EXPRESS OR IMPLIED, INCLUDING THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE WITH RESPECT TO THIS MANUAL AND, IN NO EVENT, SHALL DANIEL BE LIABLE FOR ANY SPECIAL OR CONSEQUENTIAL DAMAGES INCLUDING, BUT NOT LIMITED TO, LOSS OF PRODUCTION, LOSS OF PROFITS, ETC.**

PRODUCT NAMES USED HEREIN ARE FOR MANUFACTURER OR SUPPLIER IDENTIFICATION ONLY AND MAY BE TRADEMARKS/REGISTERED TRADEMARKS OF THESE COMPANIES.

COPYRIGHT © 1995
BY DANIEL MEASUREMENT AND CONTROL
HOUSTON, TEXAS, U.S.A.

All rights reserved. No part of this work may be reproduced or copied in any form or by any means - graphic, electronic or mechanical - without first receiving the written permission of Daniel Measurement and Control, Houston, Texas, U.S.A.

WARRANTY

Daniel Measurement and Control ("Daniel") warrants all equipment manufactured by it to be free from defects in workmanship and material, provided that such equipment was properly selected for the service intended, properly installed, and not misused. Equipment which is returned, transportation prepaid to Daniel within twelve (12) months of the date of shipment (eighteen (18) months from date of shipment for destinations outside of the United States), which is found after inspection by Daniel to be defective in workmanship or material, will be repaired or replaced at Daniel's sole option, free of charge, and return-shipped at lowest cost transportation. All transportation charges and export fees will be billed to the customer. Warranties on devices purchased from third party manufacturers not bearing a Daniel label shall have the warranty provided by the third party manufacturer.

Extended warranty - Models 2470, 2480 and 2500 are warranted for a maximum of twenty-four (24) months. The Danalyzer valves are warranted for the life of the instrument and the columns for five years.

The warranties specified herein are in lieu of any and all other warranties, express or implied, including any warranty of merchantability or fitness for a particular purpose.

Daniel shall be liable only for loss or damage directly caused by its sole negligence. Daniel's liability for any loss or damage arising out of, connected with, or resulting from any breach hereof shall in no case exceed the price allocable to the equipment or unit thereof which gives rise to the claim. Daniel's liability shall terminate one year after the delivery of the equipment except for overseas deliveries and extended warranty products as noted above.

In no event, whether as a result of breach of warranty or alleged negligence, shall Daniel be liable for special or consequential damages, including, but not limited to, loss of profits or revenue; loss of equipment or any associated equipment; cost of capital; cost of substitute equipment, facilities or services; downtime costs; or claims of customers of the purchaser for such damages.

| | | |
|------------|---|------------|
| 1.0 | INTRODUCTION | 1-1 |
| 1.1 | SCOPE OF SPECIFICATION | 1-1 |
| 1.2 | AGA3 DEFINITION/CONFIGURATION FEATURES | 1-2 |
| 1.3 | AGA3 METRIC SINGLE ORIFICE DEFINITION | 1-3 |
| 1.3.1 | DEFINITION HARDWARE REQUIREMENTS | 1-3 |
| 1.3.2 | DEFINITION FIELD WIRING MAP | 1-4 |
| 1.4 | CALCULATIONS | 1-5 |
| 1.4.1 | FLOW RATE EQUATIONS | 1-5 |
| 1.4.2 | ENERGY RATE EQUATION | 1-7 |
| 1.4.3 | RATE AND VOLUME CALCULATION | 1-7 |
| 1.4.4 | LOGGING | 1-7 |
| 1.5 | GAS CHROMATOGRAPH INTERFACE | 1-8 |
| 1.6 | VALVE POSITIONING | 1-10 |
| 1.6.1 | DIFFERENTIAL PRESSURE OVER-RANGE PROTECTION | 1-11 |
| 1.6.2 | FLOW RATE CONTROL | 1-11 |
| 1.6.3 | FLOW RATE CONTROL WITH PRESSURE OVER-RIDE | 1-12 |
| 1.6.4 | FLOW RATE OUTPUT | 1-12 |
| 1.6.5 | VOLUME PULSE OUTPUT | 1-12 |

| | | |
|------------|---|------------|
| 2.0 | FIXED MENU DEFAULTS | 2-1 |
| 2.1 | SECURITY CODES | 2-1 |
| 2.2 | EFM PARAMETERS | 2-1 |
| 2.3 | PORTS | 2-2 |
| 2.4 | AUDIT 1 DATA LOG | 2-4 |
| 2.5 | AUDIT 2 DATA LOG | 2-4 |
| 2.6 | USER DATA LOG | 2-5 |
| 2.7 | EFM DISPLAY LIST | 2-5 |
| 3.0 | DEFINITION SPECIFIC LABELS | 3-1 |
| 4.0 | DEFINITION SPECIFIC SUBMENUS | 4-1 |
| 4.1 | ALARMS | 4-1 |
| 4.1.1 | LOGGED ALARMS | 4-3 |
| 4.2 | ANALOGS | 4-4 |
| 4.3 | SCALES | 4-5 |
| 4.4 | DIGITALS | 4-6 |
| 4.5 | CONFIG | 4-7 |
| 4.6 | CONTROL | 4-8 |
| 4.7 | CALCULATED DATA | 4-9 |
| 4.8 | LIVE GAS DATA | 4-10 |
| 4.9 | FIXED GAS DATA | 4-11 |

| | | |
|------------|--|------------|
| 4.10 | RATES AND VOLUMES | 4-12 |
| 4.11 | DIAGNOSTICS | 4-13 |
| 5.0 | COMMUNICATIONS | 5-1 |
| 5.1 | DANIEL MODBUS ASCII REGISTER LIST | 5-1 |
| 6.0 | AGA8 NOMINAL RANGES FOR THE DETAIL AND GROSS CHARACTERIZATION METHODS | 6-1 |

This page intentionally left blank.

1.0 INTRODUCTION

The Ultra 3000 AGA3 Definitions have been designed for use with orifice meters and implement the required features of natural gas flow computers.

1.1 SCOPE OF SPECIFICATION

The Ultra 3000 involves a three-tiered approach to design. This task-oriented approach involves:

- Definition -- The flow engineer defines a specific application. This includes the number of tubes, assignment of inputs to functions, choosing a flow calculation method, etc.
- Configuration -- The field technician chooses a definition which has been previously defined by a flow engineer. He then is able to calibrate inputs, set pipe sizes, collect, data, etc.
- Tool Generation Programs -- When necessary, a software engineer will be asked to create a new tool or protocol driver.

Basic reference information on the Ultra 3000 system can be found in the Field Engineer's Manual and the Field Technician's Manual. A detailed description of the terminology (definitions, tools, ladders) and general procedure for generating a new definition are provided in the Flow Engineer's Manual. The Field Technician's Manual covers definitions and concepts necessary for installing, configuring, and using the Ultra 3000.

This specification includes sections on :

- Flow rate equations per API Chapter 14.3 Part 3
- Gas Chromatograph Interface Capability
- Valve Positioning Capability
- Default Security Codes
- Default Audit Logs 1 and 2 Lists
- EFM Display List
- Definition Specific Sub-Menus

- Default Alarm List
- Diagnostics Menu Representing Default Calibration Parameters
- Daniel Modbus ASCII Register List

1.2 AGA3 DEFINITION/CONFIGURATION FEATURES

The primary features of the Ultra 3000 AGA3 Definition software are as follows:

- Provides Modbus Communications for remote access
- Serves as a single orifice meter definition using AGA3 1992
- Supports AGA-8 1992 (both detail and gross methods)
- Accepts standard transducer assignments, including 36SD smart sensor for Static Pressure and Differential Pressure plus 500 OHM RTD input for Temperature
- Allows the user access to all auxiliary analog inputs and their scales
- Supports a serial interface with the Daniel Chromatograph, but will default to the use of operator entered gas quality values
- Performs valve positioning using an analog output to control corrected station flow rate (single analog outputs can be switched between valve positioning and flow rate)
- Provides an analog output proportional to station flow rate
- Provides two pulse outputs based on station volume

1.3 AGA3 METRIC SINGLE ORIFICE DEFINITION

The AGA3 Metric Single Orifice Definition uses flow rate equations from API Chapter 14.3 which are included in this specification.

1.3.1 DEFINITION HARDWARE REQUIREMENTS

This orifice definition uses the IOU Type 1 Card. The following hardware is required to support the Metric Single Orifice Definition (Part Number 8-3100-310), unless the inputs are using fixed values.

| INPUTS | OUTPUTS | NAME | REQUIREMENT | I/O TYPE & QTY. |
|--|----------------|--|--|----------------------------|
| 1 1 | 1 2 | Pres/Diff. Pres Flw Temp Flow Rate/Valve Control Station Volume | 36SD 500 OHM RTD 1-5 volts Contact Closures | 1 1 |
| ADDITIONAL UNASSIGNED I/O CONFIGURABLE USING EFMACCS DEFINITION S/W | | | | |
| 2 4 | 2 | Aux. Anlg. In Aux. Status In Aux. Control Out | 1-5 volts Contact Closures Contact Closures | |

1.3.2 DEFINITION FIELD WIRING MAP

| NAME | REQUIREMENT | INPUTS | OUTPUTS | IOU BOARD # |
|--------------------------|-----------------|------------------|-------------------|-------------|
| Pres1 | 36SD | | | 1 |
| Diff Pres1 | 36SD | | | 1 |
| Flw Temp1 | RTD | | | 1 |
| Aux 1 | 1-5 volts | Analog Input #1 | | 1 |
| Aux 2 | 1-5 volts | Analog Input #2 | | 1 |
| DIn1 | Contact Closure | Digital Input #1 | | 1 |
| DIn2 | Contact Closure | Digital Input #2 | | 1 |
| DIn3 | Contact Closure | Digital Input #3 | | 1 |
| DIn4 | Contact Closure | Digital Input #4 | | 1 |
| VP 1 | Contact Closure | | Digital Output #1 | 1 |
| VP 2 | Contact Closure | | Digital Output #2 | 1 |
| DOU3 | Contact Closure | | Digital Output #3 | 1 |
| DOU4 | Contact Closure | | Digital Output #4 | 1 |
| Stn Flw Rt/ Valve Pos | 1-5 volts | | Analog Output #1 | 1 |

1.4 CALCULATIONS

The calculations in the Ultra are divided into two distinct processes. These are as follows:

- Analog input sampling and average rate calculation
- Corrected flow rate and volume and calculation

These processes are usually executed independently without regard for the state of the other. When the volume calculation process begins a new cycle, it signals the sampling process for new inputs required for a flow calculation. Upon receiving this signal, the sampling process transfers the inputs that have accumulated to the calculation process, and begins new accumulations.

1.4.1 FLOW RATE EQUATIONS

NOTE: This definition has been modified to accept input units of KPA for pressure, degrees C for temperature, MJoules/M3 for energy, KPA for differential pressure, and MM for orifice and pipe diameters. All input values are converted to U.S. equivalent units prior to flow calculations. After flow calculations are performed the calculated values are converted to metric units.

The Ultra calculates volumetric flow rate using equations 3-6b and 3-7 from API Chapter 14.3 Part 3. These equations are:

$$Q_b = (14.73/P_b) * (T_b/519.67) * (Z_b/Z_s) * Q_v \quad \text{Eqn. 3-7}$$

$$Q_v = 7709.61 * C_d * E_v * Y * d^2 * \text{sqrt}(P_{fl} * h_w * Z_s / (G_r * Z_{fl} * T_f)) \quad \text{Eqn. 3-6b}$$

where :

- Q_b = volumetric flow rate in SCFH at base conditions
- Q_v = volumetric flow rate in SCFH at standard conditions
- P_b = base pressure in PSIA
- T_b = base temperature in Rankine
- Z_b = gas compressibility at base conditions
- Z_s = gas compressibility at standard conditions
- C_d = orifice discharge coefficient
- E_v = velocity of approach factor
- Y = expansion factor

- d = temperature corrected orifice diameter
- P_{f1} = upstream pressure in PSIA
- T_f = flowing temperature in Rankine
- h_w = differential pressure in InH₂O
- G_r = real gas relative density at standard conditions
- Z_{f1} = flowing compressibility at P_{f1} & T_f

Standard conditions = 14.73 PSIA and 519.67 Rankine

All compressibility values are calculated in accordance with AGA Report No. 8, 1992. The operator may select the DETAIL (full analysis) or GROSS (short form) method for compressibility calculation. For equations consult AGA Report No. 8.

All input gravity values used in the Ultra are assumed to be for reference conditions of 14.73 PSIA and 60 °F. This assumption is consistent with calculation examples given in API Chapter 14.3, Part 3. If the operator indicates that the input gravity is the ideal relative density, the ideal value is converted to G_r before the flow rate calculation is run. This value is internal to the flow calculation, and does not replace the specific gravity value the operator entered into the Ultra.

The quantity, $\sqrt{P_{f1} * h_w}$, is stored as a separate entity, FLOW EXTN, in the Ultra and is stored in the data log by default. This is in accordance with the COGM document on electronic flow meters.

1.4.2 ENERGY RATE EQUATION

The Ultra calculates volumetric energy rate using the following equation:

$$\text{Erate} = \text{Qb} * \text{Energy}$$

Qb = volumetric flow rate in cubic meters per hour at base conditions

Energy = energy in MJ/M3 at 101.56 KPAA and 15.56 DEGC

Erate = volumetric energy rate in MegaJoules at base conditions

1.4.3 RATE AND VOLUME CALCULATION

The Ultra calculates rates, volumes, and compressibility on a periodic basis, once a minute.

At the beginning of the calculation cycle, the analog input averages accumulated during the preceding I/O ladder are transferred to the CALC LADDER. Using these inputs, a new flow calculation is done. The flowing compressibility is calculated first, followed by the instantaneous flow rate. The rates and volumes are updated last.

1.4.4 LOGGING

The logging function is a part of the calculation ladder. During each cycle, the Ultra updates all of the running averages for the log. For Analog Inputs in the log, "flow averages" are kept based on flowing conditions. The meter is considered to be flowing if the differential pressure for that meter is above the cut-off value. Averaging is not performed during "no flow" conditions; this results in zero values for logging purposes.

1.5 GAS CHROMATOGRAPH INTERFACE

The Ultra 3000 supports retrieval of gas composition and gas quality from the Model 2251 Danalyzer Gas Chromatograph Controller. The Ultra polls the chromatograph if one of its serial ports has been configured for 'GC' protocol. It uses the communications parameters (baud rate, RTS delay, etc...) that are configured for that serial port.

To enable the gas chromatograph interface, three pieces of information must be programmed into the Ultra. These are the MODBUS communication address of the chromatograph, GC selected as one of the serial communications ports; and the chromatograph stream number of the data are required. The first two are configured with the Ultra 'Ports' Menu. The stream number is configured with the online Config Menu.

The Ultra initiates a poll of the GC about once every four minutes. If the poll is not successful, the poll will be retried every 4 seconds until the poll succeeds. Each poll of the GC is made up of a series of MODBUS queries for chromatograph data. If any query fails, the poll sequence is aborted.

The first query to the GC is for the time of the current analysis. This time stamp is saved for comparison later. Next, the current stream number is queried. Next a query is issued for the BTU content and specific gravity, followed by a query for the 11 component values supported by the Model 2251. The final query retrieves the chromatograph alarms and the analysis time stamp again. If the alarms denoted by the chromatograph's MODBUS registers 3046 and 3047 are non-zero, or the analysis time does not match that of the first query, the sequence is aborted. Otherwise, the data is processed and used in the Ultra.

ULTRA 3000 METRIC SINGLE ORIFICE

The data read from the GC and the associated MODBUS register numbers are:

| | |
|------------------|----------------------------------|
| C6+ | 7001 |
| Propane | 7002 |
| I-Butane | 7003 |
| Butane | 7004 |
| Neo-Pentane | 7005 |
| I-Pentane | 7006 |
| Pentane | 7007 |
| Nitrogen | 7008 |
| Methane | 7009 |
| CO2 | 7010 |
| Ethane | 7011 |
| Specific Gravity | 7035 (Real Gas Relative Density) |
| BTU Content | 7033 |

If the retrieved value for Nitrogen exceeds 50 percent, the data is discarded and no further processing is done. The most common cause of a value greater than 50 percent for Nitrogen is the reassignment of MODBUS register numbers done when Neo-Pentane is deleted from the Model 2251 configuration. If this component must be deleted, a dummy component should be inserted in its place to preserve the register assignments as shown. This is the only check the Ultra does on the retrieved data before storing.

Since the AGA-8 equations do not support Neo-Pentane or C6+ as a single component, the retrieved data is partially processed before storing the data in the Ultra. If Neo-Pentane is present, it is considered to be Iso-Pentane (which is the most chemically similar component supported by AGA-8) and added to that component's value. Any C6+ component reported is separated into the following fractions:

| | |
|---------|---------|
| Hexane | 0.47466 |
| Heptane | 0.3534 |
| Octane | 0.17194 |

These fractions are the default values used by Model 2251 in the calculation of the reported value for BTU content.

1.6 VALVE POSITIONING

The Ultra 3000 provides flow rate control based on rate or rate with pressure over-ride and also supports differential pressure over-range protection. The Ultra controls the flow rate by means of an analog output (1-5 VDC) connected to a control valve. The valve positioning function can be configured to operate in various ways based on the value of the following configuration variables:

| | |
|---|---|
| Valve positioning mode (VP Mode) | NONE [0]=none (disabled) FLWRT [1]=flow rate only UpPrOR [2]=rate w/upstream pressure over-ride DnPrOR[3]=rate w/downstream pressure over-ride |
| Flow setpoint | desired flow rate in M3/HR |
| Deadband | in % of setpoint |
| Small step | step for fine control |
| Large step | step for fast control |
| Fine control error limit | in % of setpoint |
| Over-ride pressure | in KPAG |
| Differential pressure over-range limit | in KPA |
| Preset valve position | valve position for DP over-ride |
| Update time in seconds | valve positioning update time |

If the function is disabled or the Maintenance Mode(Maint Mode ENABLE[1]) is enabled, no control is done. To fix the valve position to a specific value, place the output in the fixed mode and enter the desired fixed value. This value will be maintained regardless of any configuration variables. If the function is enabled, and the valve position has not been fixed by the operator, the valve positioning function runs each I/O ladder sample time after the analog inputs have been sampled.

1.6.1 DIFFERENTIAL PRESSURE OVER-RANGE PROTECTION

The differential pressure over-range protection feature is enabled by entering a non-zero value for the DP over-range limit. When enabled, this feature takes precedence over other valve positioning modes.

Each I/O cycle, the DP on the primary meter run is compared to the over-range limit. If the DP is below the over-range limit, valve positioning continues based on the selected mode. If the DP exceeds the limit, the valve position is set to the preset valve position, and the valve positioning function is aborted. Normal valve positioning resumes with the next analog sample cycle, that shows a DP below the over-range limit.

Certain combinations of parameters will cause the valve position to oscillate when this feature is enabled.

1.6.2 FLOW RATE CONTROL (VP MODE = FLW RT[1])

The Ultra attempts to cause the measured flow rate to match a user entered flow rate setpoint. Each I/O cycle, a timer is incremented. If this timer is less than the programmed update time, the function is postponed for another cycle. After the update time has elapsed, the current flow rate is compared to the setpoint. If the difference (error) is greater than a fine control threshold, a large step is applied to the valve position. Otherwise, if the error is greater than a user programmed deadband, a small step is applied to the valve position. If the error does not exceed the deadband, no change is made to the valve position. The following example illustrates this.

| | |
|---------------|-----------|
| Flow setpoint | 500 M3/HR |
| Small step | 0.1 % |
| Deadband | 1 % |
| Large step | 0.3 % |
| Fine control | |
| Error limit | 5 % |

If the observed flow rate is below 475 M3/HR, 0.3 percent will be added to the valve position (above 525, 0.3 percent will be subtracted). Otherwise, if the rate is below 495 M3/HR, 0.1 percent will be added to the valve position (above 505, 0.1 percent will be subtracted). If the observed flow rate is between 495 and 505 M3/HR, no control will be performed.

The flow rate for determining the error is estimated from the last system flow rate generated by the calculation cycle and the current flow extension. This estimation is:

$$Q_{vp} = Q_{sys} * Ext_{vp} / Ext_{sys}$$

where:

Q_{sys} = Station flow rate in M3/HR from last calculation cycle

Q_{vp} = Refers to the most recent value generated during the analog input sampling process

1.6.3 FLOW RATE CONTROL WITH PRESSURE OVER-RIDE (VP MODE = 2 OR 3)

Each I/O cycle, the instantaneous value of the pressure is compared to the over-ride pressure value. If the pressure is less than the over-ride value, normal flow rate control continues. If the pressure exceeds the over-ride value, the small step is added to the valve position for mode 2 or subtracted from the valve position for mode 3.

1.6.4 FLOW RATE OUTPUT

Ultra provides an analog output proportional to a station volumetric flow rate. This output is provided for use by external equipment which require an analog indication of the measured flow rate. The flow rate outputs are updated once each calculation cycle. The user is free to rescale this output.

1.6.5 VOLUME PULSE OUTPUT

Ultra provides two separate pulse outputs based on station volume. Each has a volume per pulse entry and a pulse period entry for configuration. For each output, a volume accumulator holds the volume since the last pulse was output. When the accumulator exceeds the volume per pulse, this volume is subtracted from the accumulator, and a pulse is output. The accumulation is done once each calculation cycle.

2.0 FIXED MENU DEFAULTS

2.1 SECURITY CODES

Defines the list of users and their security codes for the current configuration.

| USER ID | LEVEL |
|----------------|--------------|
| Field Engr | 255 |
| Super Tech | 200 |
| Field Tech | 100 |
| Observer | 0 |

2.2 EFM PARAMETERS

Allows the user to define and/or modify the following configuration parameters for the EFM.

| EFM PARAMETERS | SECURITY CLEARANCE | |
|----------------------------|---------------------------|--------------|
| | READ | WRITE |
| EFM Parameters | 0 | 100 |
| EFM Security Codes | 255 | 255 |
| EFM Communication Ports | 0 | 100 |
| User Data Log | 100 | 255 |
| EFM Display List | 0 | 255 |
| Log Clear Security Level | | 255 |
| User Data Log Interval | None | |
| Contract Hour | 7 | |
| Configuration Description | Default Configuration | |
| Display Inactivity Timeout | 60 | |
| Display Scroll Mode: | Blank Screen | |
| Display Scroll Interval | | |

2.3 PORTS

Configurable serial and parallel ports:

SERIAL

| PORT NO. | COMM ID. | USE |
|--------------------------|----------|------------------|
| 1 | 1 | MODBUS DANIEL |
| PARAMETERS | DEFAULT | |
| Baud Rate | 9600 | |
| Parity | Even | |
| Data Bits | 7 | |
| Start Bits | 1 | |
| Stop Bits | 1 | |
| RTS Required | YES | |
| RTS Up Delay | 200 | |
| RTS Down Delay | 10 | |
| CTS Required | NO | |
| CTS True Abort RTS Up | YES | |
| CTS False Abort RTS Down | NO | |
| CTS for Carrier Detect | NO | |
| CTS Timeout | 0 | |

SERIAL

| PORT NO. | COMM ID. | USE |
|--------------------------|-----------------|------------|
| 2 | 1 | GC |
| PARAMETERS | DEFAULT | |
| Baud Rate | 9600 | |
| Parity | Even | |
| Data Bits | 7 | |
| Start Bits | 1 | |
| Stop Bits | 1 | |
| RTS Required | YES | |
| RTS Up Delay | 200 | |
| RTS Down Delay | 10 | |
| CTS Required | NO | |
| CTS True Abort RTS Up | YES | |
| CTS False Abort RTS Down | NO | |
| CTS for Carrier Detect | NO | |
| CTS Timeout | 0 | |

PARALLEL DEFAULTS

| PORT NO. | COMM ID. | USE |
|-----------------|-----------------|--------------|
| 1 | 1 | LOCAL |

2.4 AUDIT 1 DATA LOG - 24 HOUR

The following items are included on the data log. Audit data logs 1 and 2 are set to 24-hour and 1-hour log intervals, respectively. The default contract hour is 7:00 am. When a graph is selected the scale range must be entered.

| LABEL | DECIMAL PLACES | DIGITS | GRAPH NO. |
|--------------|-----------------------|---------------|------------------|
| Log1 Dp1 | 2 | 6 | 0 |
| Log1 Pres1 | 1 | 6 | 0 |
| Log1 Temp1 | 1 | 6 | 0 |
| Log1FlwTm1 | 2 | 6 | 0 |
| Log1 Extn1 | 2 | 6 | 0 |
| Log1 Vol1 | 0 | 6 | 0 |
| Log1 Eng1 | 0 | 6 | 0 |

2.5 AUDIT 2 DATA LOG - 1 HOUR

| LABEL | DECIMAL PLACES | DIGITS | GRAPH NO. |
|--------------|-----------------------|---------------|------------------|
| Log2 Dp1 | 2 | 6 | 1 |
| Log2 Pres1 | 1 | 6 | 1 |
| Log2 Temp1 | 1 | 6 | 1 |
| Log2FlwTm1 | 2 | 6 | 0 |
| Log2 Extn1 | 2 | 6 | 0 |
| Log2 Vol1 | 0 | 6 | 2 |
| Log2 Eng1 | 0 | 6 | 0 |

| SCALE RANGE |
|--|
| Point Name: Log2 Pres1 Low Scale: 0.0 High Scale: 6900.0 |

ULTRA 3000 METRIC SINGLE ORIFICE

2.6 USER DATA LOG - NONE

2.7 EFM DISPLAY LIST

The DISPLAY List provides for viewing the selected setup parameters and data points from the field user data set unit at any given time. The menu is for display purposes only. No changes can be made to the values displayed using this menu.

| POINT NAME | UNITS |
|-------------------|--------------|
| F/L Prs1 | |
| Metr Pres1 | KPAG |
| F/L Tmp1 | |
| Flw Temp1 | DEGC |
| F/L Dp1 | |
| Diff Pres1 | KPA |
| Real Grav | |
| Energy | MJ/M3 |
| F/L Aux1 | |
| Aux Anlg 1 | PCT |
| F/L Aux2 | |
| Aux Anlg 2 | PCT |
| Flow Rate1 | M3/HR |
| Tot Vol 1 | M3 |
| Today Vol1 | M3 |
| Ysday Vol1 | M3 |
| Erate 1 | MJ/HR |
| Tot Enrgy1 | MJOULE |
| Tdy Enrgy1 | MJOULE |
| Ysy Enrgy1 | MJOULE |

This page intentionally left blank.

3.0 DEFINITION SPECIFIC LABELS

Descriptive labels are shown here for reference only. The column labeled DP in the table indicates the number of digits displayed past the decimal point.

| LABEL | UNITS | DP | DEFAULT | DESCRIPTION |
|--------------|--------------|-----------|----------------|--|
| AnOutSel | (None) | 0 | 0 | Analog Out Selector 1=Valve Positioning 0=Flow Rate1 |
| Flw Rt Out | M3/HR | 1 | 0.0 | Analog flow rate |
| Valve Pos | % | 1 | 50.0 | Current valve position |
| Version | | 2 | 1.00 | Software version |
| Sys Error | | 0 | 0 | System alarm |
| Atms Pres | KPAA | 3 | 101.559 | Atmospheric pressure |
| Pres Base | KPAA | 3 | 101.559 | Pressure base |
| Temp Base | DEG C | 2 | 15.56 | Temperature base |
| Orif Mtrl | (None) | 0 | STAIN[1] | Orifice material |
| Pipe Mtrl | (None) | 0 | CARBON[0] | Pipe material |
| Tref Orif | DEGC | 1 | 20.0 | Reference temperature of orifice plate |
| Tref Pipe | DEGC | 1 | 20.0 | Reference temperature of pipe |
| Spec Heat | | 2 | 1.30 | Specific heat ratio |
| SG Select | | 1 | REAL[1] | Input specific gravity 0=ideal, 1=real |
| Zs1 Entry | (None) | 6 | 1.000000 | Compressibility of gas used for ideal specific gravity |

| LABEL | UNITS | DP | DEFAULT | DESCRIPTION |
|--------------|--------------|-----------|----------------|---|
| AGA8 Mthd | | 0 | DETAIL[0] | AGA-8 Method 0=detail 1=GR, CO2, BTU 2=GR, CO2, N2 |
| Zs | | 6 | 1.000000 | Standard compressibility |
| Zb | | 6 | 1.000000 | Base compressibility |
| Mol Wt | | 4 | 16.8000 | Calculated by AGA-8 |
| B | | 6 | 0.000000 | AGA-8 2nd virial coeff. |
| C | | 6 | 0.000000 | AGA-8 3rd virial coeff. |
| D | | 6 | 0.000000 | AGA-8 reduced density |
| K3 | | 6 | 0.000000 | AGA-8 mixture size parameter |
| Real Grav | (None) | 4 | 0.6000 | Current Specific Gravity |
| Energy | MJ/M3 | 3 | 38.000 | Current Energy |
| Methane | MOL% | 4 | 95.0000 | Methane MOL% |
| Nitrogen | MOL% | 4 | 0.0000 | Nitrogen MOL% |
| CO2 | MOL% | 4 | 0.0000 | Carbon dioxide MOL% |
| Ethane | MOL% | 4 | 5.0000 | Ethane MOL% |
| Propane | MOL% | 4 | 0.0000 | Propane MOL% |
| H2O | MOL% | 4 | 0.0000 | Water MOL% |
| H2S | MOL% | 4 | 0.0000 | Hydrogen Sulphide MOL% |
| Hydrogen | MOL% | 4 | 0.0000 | Hydrogen MOL% |
| CO | MOL% | 4 | 0.0000 | Carbon Monoxide MOL% |
| Oxygen | MOL% | 4 | 0.0000 | Oxygen MOL% |
| I-Butane | MOL% | 4 | 0.0000 | I-Butane MOL% |
| Butane | MOL% | 4 | 0.0000 | Butane MOL% |

ULTRA 3000 METRIC SINGLE ORIFICE

| LABEL | UNITS | DP | DEFAULT | DESCRIPTION |
|--------------|--------------|-----------|----------------|---|
| I-Pentane | MOL% | 4 | 0.0000 | I-Pentane MOL% |
| Pentane | MOL% | 4 | 0.0000 | Pentane MOL% |
| Hexane | MOL% | 4 | 0.0000 | Hexane MOL% |
| Heptane | MOL% | 4 | 0.0000 | Heptane MOL% |
| Octane | MOL% | 4 | 0.0000 | Octane MOL% |
| Nonane | MOL% | 4 | 0.0000 | Nonane MOL% |
| Decane | MOL% | 4 | 0.0000 | Decane MOL% |
| Helium | MOL% | 4 | 0.0000 | Helium MOL% |
| Argon | MOL% | 4 | 0.0000 | Argon MOL% |
| Chrom Addr | (None) | 0 | 1 | Chromatograph address |
| Chrom Strm | (None) | 0 | 1 | Chromatograph stream |
| VPP 1 | M3 | 1 | 1000.0 | Volume per pulse 1 |
| PP 1 | SEC | 0 | 10 | Pulse period 1 |
| VPP 2 | M3 | 1 | 1000.0 | Volume per pulse 2 |
| PP 2 | SEC | 0 | 10 | Pulse period 2 |
| VP Mode | (None) | 0 | NONE[0] | Valve positioning option 0=disabled 1=flow rate control 2=upstream pressure override 3=downstream pressure override |
| Flw Setpnt | M3/HR | 1 | 0.0 | Flow rate setpoint |
| Deadband | PCT | 1 | 2.0 | Control deadband % |
| Small Step | PCT | 2 | 0.05 | Fine valve step % |
| Large Step | PCT | 1 | 0.5 | Coarse valve step % |
| Fine Cntrl | PCT | 0 | 5 | Error limit control % |

ULTRA 3000 METRIC SINGLE ORIFICE

| LABEL | UNITS | DP | DEFAULT | DESCRIPTION |
|--------------|--------------|-----------|----------------|--|
| Ovrd Pres | KPAG | 1 | 0.0 | Pres override limit |
| Preset Pos | PCT | 1 | 50.0 | Valve position for DP override |
| Dp Limit | KPA | 2 | 0.00 | DP override limit 0=disabled |
| Update Tim | SEC | 0 | 10 | Valve position update time |
| Orif Diam1 | MM | 4 | 100.0000 | Meter 1 orifice diameter |
| Pipe Diam1 | MM | 4 | 200.0000 | Meter 1 pipe diameter |
| Tap Lctn 1 | (None) | 0 | UPSTRM[1] | Tap location 0=downstream 1=upstream |
| Zflow Lim1 | KPA | 2 | 0.10 | Low flow cutoff in KPA |
| Corr Od1 | MM | 4 | 0.0000 | Temp corrected orifice diameter |
| Corr Pd1 | MM | 4 | 0.0000 | Temp corrected pipe diameter 1 |
| Corr Beta1 | (None) | 5 | 0.00000 | Temp corrected beta ratio |
| Ev 1 | (None) | 5 | 1.00000 | Velocity of approach factor |
| Cd 1 | (None) | 6 | 0.600000 | Coefficient of discharge |
| Zf 1 | (None) | 6 | 1.000000 | Flowing compressibility |
| Y 1 | (None) | 6 | 1.000000 | Expansion factor |
| Flw Extn 1 | (None) | 3 | 0.000 | sqrt(Hw*Pf) |
| Flw Time 1 | MIN | 2 | 0.00 | Flow time |
| Flow Rate1 | M3/HR | 1 | 0.0 | Hourly flow rate |
| Dly FlwRt1 | M3/D | 1 | 0.0 | Daily flow rate |
| Log Vol 1 | M3 | 0 | 0 | Logged accumulated volume |

ULTRA 3000 METRIC SINGLE ORIFICE

| LABEL | UNITS | DP | DEFAULT | DESCRIPTION |
|--------------|--------------|-----------|----------------|--|
| Today Vol1 | M3 | 0 | 0 | Daily accumulated volume |
| Ysday Vol1 | M3 | 0 | 0 | Ysday's accumulated volume |
| Tot Vol 1 | M3 | 0 | 0 | Total accumulated volume (Rolls over @ 10,000,000) |
| Erate 1 | MJ/HR | 1 | 0.0 | Energy flow rate |
| Log Enrgy1 | MJOULE | 0 | 0 | Logged accumulated energy |
| Tdy Enrgy1 | MJOULE | 0 | 0 | Today's accumulated energy |
| Ysy Enrgy1 | MJOULE | 0 | 0 | Ysday's accumulated energy |
| Tot Enrgy1 | MJOULE | 0 | 0 | Total accumulated energy (Rolls over @ 10,000,000) |

All totals roll over at 10,000,000 so adjust your units accordingly.

This page intentionally left blank.

ULTRA 3000 METRIC SINGLE ORIFICE

4.0 DEFINITION SPECIFIC SUBMENUS

The following submenus are found: Access → Edit → Menus

4.1 ALARMS

The ALARMS SUBMENU allows the user to view alarms and to edit and/or view the alarm limits.

| PROMPT | DEFAULT | SECURITY CLEARANCE | |
|---------------|----------------|---------------------------|--------------|
| | | READ | WRITE |
| Maint Mode | 0 | 0 | 100 |
| CutOffAlm | 0 | 0 | N/A |
| Zf Zero | 0 | 0 | N/A |
| Sys Error | 0 | 0 | N/A |
| Prs1 LoAlm | 0 | 0 | N/A |
| Prs1 HiAlm | 0 | 0 | N/A |
| Tmp1 LoAlm | 0 | 0 | N/A |
| Tmp1 HiAlm | 0 | 0 | N/A |
| Dp1 LoAlm | 0 | 0 | N/A |
| Dp1 HiAlm | 0 | 0 | N/A |
| Aux1 LoAlm | 0 | 0 | N/A |
| Aux1 HiAlm | 0 | 0 | N/A |
| Aux2 LoAlm | 0 | 0 | N/A |
| Aux2 HiAlm | 0 | 0 | N/A |
| Batt LoAlm | 0 | 0 | N/A |

ALARMS (CONTINUED)

| PROMPT | DEFAULT | | SECURITY CLEARANCE | |
|------------|----------|-------|--------------------|-------|
| | | | READ | WRITE |
| Rate1LoAlm | 0 | | 0 | N/A |
| Rate1HiAlm | 0 | | 0 | N/A |
| Prs1 LoLmt | 0.0 | KPAG | 100 | 100 |
| Prs1 HiLmt | 6900.0 | KPAG | 100 | 100 |
| Tmp1 LoLmt | -18.0 | DEGC | 100 | 100 |
| Tmp1 HiLmt | 66.0 | DEGC | 100 | 100 |
| Dp1 LoLmt | 0.00 | KPA | 100 | 100 |
| Dp1 HiLmt | 38.00 | KPA | 100 | 100 |
| Aux1 LoLmt | -1.00 | PCT | 100 | 100 |
| Aux1 HiLmt | 101.00 | PCT | 100 | 100 |
| Aux2 LoLmt | -1.00 | PCT | 100 | 100 |
| Aux2 HiLmt | 101.00 | PCT | 100 | 100 |
| Batt LoLmt | 5.50 | BATT | 100 | 100 |
| Rate1LoLmt | 0.0 | M3/HR | 100 | 100 |
| Rate1HiLmt | 142000.0 | M3/HR | 100 | 100 |

4.1.1 LOGGED ALARMS

The Logged Alarms can be viewed via the View Logs sub-menu of the Main Menu of the Electronic Flow Meter Definition and Configuration System. The number of transitions until logging begins have been defaulted to 5 for all logged alarms. Other alarms, such as, CutOffAlm, Zf Zero, etc. do not generate alarm log entries.

| LOGGED ALARMS |
|----------------------|
| Prs1 LoAlm |
| Prs1 HiAlm |
| Tmp1 LoAlm |
| Tmp1 HiAlm |
| Dp1 LoAlm |
| Dp1 HiAlm |
| Aux1 LoAlm |
| Aux1 HiAlm |
| Aux2 LoAlm |
| Aux2 HiAlm |
| Batt LoAlm |
| Rate1LoAlm |
| Rate1HiAlm |
| Sys Error |

4.2 ANALOGS

The ANALOGS submenu of this definition provides for toggling between LIVE and FIXED values of the following analogs.

| PROMPT | DEFAULT | | SECURITY CLEARANCE | |
|------------|-----------|-------|--------------------|-------|
| | | | READ | WRITE |
| Metr Pres1 | 0.0 | KPAG | 0 | 100 |
| Flw Temp1 | -18.0 | DEGC | 0 | 100 |
| Diff Pres1 | 0.00 | KPA | 0 | 100 |
| Aux Anlg 1 | 0.00 | PCT | 0 | 100 |
| Aux Anlg 2 | 0.00 | PCT | 0 | 100 |
| Battery | 12.00 | BATT | 0 | 100 |
| Flow Rate1 | 0.0 | M3/HR | 0 | 100 |
| Valve Pos | 50.0 | PCT | 0 | 100 |
| Inst Prs1 | ####.# | KPAG | 100 | 100 |
| Inst Tmp1 | ###.# | DEGC | 100 | 100 |
| Inst Dp1 | ###.## | KPA | 100 | 100 |
| Inst Aux1 | ###.## | PCT | 100 | 100 |
| Inst Aux2 | ###.## | PCT | 100 | 100 |
| Inst Batt | ##.## | BATT | 100 | 100 |
| F/L Prs1 | LIVE[0] | | 100 | 100 |
| Man Pres1 | 3350.000 | KPAG | 100 | 100 |
| F/L Tmp1 | LIVE[0] | | 100 | 100 |
| Man Temp1 | 43.00 | DEGC | 100 | 100 |
| F/L Dp1 | LIVE[0] | | 100 | 100 |
| Man Dp1 | 5.0000 | KPA | 100 | 100 |
| F/L Aux1 | LIVE[0] | | 100 | 100 |
| Man Aux1 | 0.00 | PCT | 100 | 100 |
| F/L Aux2 | LIVE[0] | | 100 | 100 |
| Man Aux2 | 0.00 | PCT | 100 | 100 |
| F/L AOut1 | LIVE[0] | | 100 | 100 |
| Man AOut1 | 0.00 | %OPEN | 100 | 100 |
| Maint Mode | DISABL[0] | | 100 | 100 |

- represents live values

ULTRA 3000 METRIC SINGLE ORIFICE

4.3 SCALES

The high- and low-scale values for the analogs shown in the following table can be modified in the SCALES submenu.

| PROMPT | DEFAULT | | SECURITY CLEARANCE | |
|------------|----------|-------|--------------------|-------|
| | | | READ | WRITE |
| M Pres1/Lo | 0.000 | KPAG | 100 | 100 |
| M Pres1/Hi | 6900.000 | KPAG | 100 | 100 |
| M Temp1/Lo | -18.00 | DEGC | 100 | 100 |
| M Temp1/Hi | 66.00 | DEGC | 100 | 100 |
| D Pres1/Lo | 0.0000 | KPA | 100 | 100 |
| D Pres1/Hi | 38.0000 | KPA | 100 | 100 |
| Aux 1 Lo | 0.00 | PCT | 100 | 100 |
| Aux 1 Hi | 100.00 | PCT | 100 | 100 |
| Aux 2 Lo | 0.00 | PCT | 100 | 100 |
| Aux 2 Hi | 100.00 | PCT | 100 | 100 |
| Battery Lo | 0.00 | BATT | 100 | 100 |
| Battery Hi | 15.83 | BATT | 100 | 100 |
| Flw Rt Low | 0.0 | M3/HR | 0 | 100 |
| Flw Rt Hi | 142000.0 | M3/HR | 0 | 100 |

4.4 DIGITALS

The DIGITALS submenu provides for viewing and/or editing the digital inputs and outputs.

| PROMPT | DEFAULT | SECURITY CLEARANCE | |
|---------------|----------------|---------------------------|--------------|
| | | READ | WRITE |
| VP 1 | 0 | 0 | 100 |
| VP 2 | 0 | 0 | 100 |
| DIn1 | 0 | 0 | N/A |
| DIn2 | 0 | 0 | N/A |
| DIn3 | 0 | 0 | N/A |
| DIn4 | 0 | 0 | N/A |
| Dout1 | 0 | 0 | 100 |
| Dout2 | 0 | 0 | 100 |
| Dout3 | 0 | 0 | 100 |
| Dout4 | 0 | 0 | 100 |
| F/L Dout1 | LIVE[0] | 100 | 100 |
| Man Dout1 | OFF[0] | 100 | 100 |
| F/L Dout2 | LIVE[0] | 100 | 100 |
| Man Dout2 | OFF[0] | 100 | 100 |
| F/L Dout3 | LIVE[0] | 100 | 100 |
| Man Dout3 | OFF[0] | 100 | 100 |
| F/L Dout4 | LIVE[0] | 100 | 100 |
| Man Dout4 | OFF[0] | 100 | 100 |

ULTRA 3000 METRIC SINGLE ORIFICE

4.5 CONFIG

The following default parameters can be changed in the CONFIG submenu.

| PROMPT | DEFAULT | SECURITY CLEARANCE | |
|---------------|----------------|---------------------------|--------------|
| | | READ | WRITE |
| Orif Diam1 | 100.0000 MM | 0 | 100 |
| Pipe Diam1 | 200.0000 MM | 0 | 100 |
| Zflow Lim1 | 0.10 KPA | 0 | 100 |
| Tap Lctn 1 | UPSTRM[1] | 0 | 100 |
| Atms Pres | 101.560 KPAA | 0 | 100 |
| Pres Base | 101.560 KPAA | 0 | 100 |
| Temp Base | 15.56 DEGC | 0 | 100 |
| AGA8 Mthd | DETAIL[0] | 0 | 100 |
| SG Select | REAL[1] | 0 | 100 |
| Spec Grav | 0.6000 | 0 | 100 |
| Zs1 Entry | 1.000000 | 0 | 100 |
| Orif Mtrl1 | STAIN[1] | 0 | 100 |
| Pipe Mtrl1 | CARBON[0] | 0 | 100 |
| Tref Orif1 | 20.0 DEGC | 0 | 100 |
| Tref Pipe1 | 20.0 DEGC | 0 | 100 |
| Chrom Strm | 1 | 0 | 100 |
| Version | 1.00 | 0 | N/A |

4.6 CONTROL

The CONTROL submenu provides for entering the control values for the pulse outputs.

| PROMPT | DEFAULT | | SECURITY CLEARANCE | |
|------------|-----------|-------|--------------------|-------|
| | | | READ | WRITE |
| VPP 1 | 1000.0 | M3 | 0 | 100 |
| PP 1 | 10 | SEC | 0 | 100 |
| VPP 2 | 1000.0 | M3 | 0 | 100 |
| PP 2 | 10 | SEC | 0 | 100 |
| VP Mode | NONE[0] | | 0 | 100 |
| Flw Setpnt | 0.0 | M3/HR | 0 | 100 |
| Deadband | 2.0 | PCT | 0 | 100 |
| Small Step | 0.05 | PCT | 0 | 100 |
| Large Step | 0.5 | PCT | 0 | 100 |
| Fine Cntrl | 5 | PCT | 0 | 100 |
| Ovrd Pres | 0.0 | KPAG | 0 | 100 |
| DP Limit | 0.00 | KPA | 0 | 100 |
| Preset Pos | 50.0 | PCT | 0 | 100 |
| Update Tim | 10 | SEC | 0 | 100 |
| Valve Pos | 50.0 | PCT | 0 | 100 |
| F/L VP Out | FIXED[1] | | 0 | 100 |
| FixdVP Val | 50.0 | PCT | 0 | 100 |
| AnOutSel | 0 | | 0 | 100 |
| Inst Rate | 0.0 | M3/HR | 0 | 100 |
| Flow Rate1 | 0.0 | M3/HR | 0 | 100 |
| Diff Pres1 | 0.00 | KPA | 0 | 100 |
| Metr Pres1 | 0.0 | KPAG | 0 | 100 |
| Maint Mode | DISABL[0] | | 0 | 100 |
| pplowlim1 | 4 | SEC | 100 | 100 |
| max_puls1 | 100 | | 100 | 100 |
| pplowlim2 | 4 | SEC | 100 | 100 |
| max_puls2 | 100 | | 100 | 100 |

ULTRA 3000 METRIC SINGLE ORIFICE

4.7 CALCULATED DATA

The CALC DATA submenu allows the user to determine the calculated values for specified inputs. The values shown here are typical values and not default values.

| PROMPT | SAMPLE VALUES | SECURITY CLEARANCE |
|---------------|----------------------|---------------------------|
| | | READ |
| AGA8 Mthd | DETAIL[0] | 0 |
| Zs | 0.997811 | 0 |
| Zb | 0.997811 | 0 |
| Flow Rate1 | 11741.5 M3/HR | 0 |
| Ev 1 | 1.03281 | 100 |
| Cd 1 | 0.603222 | 100 |
| Y 1 | 0.999519 | 100 |
| Flw Extn 1 | 131.369 | 0 |
| Zf 1 | 0.948190 | 0 |
| B | -0.051740 | 100 |
| K3 | 0.100912 | 100 |
| Mol Wt | 16.7444 | 100 |

4.8 LIVE GAS DATA

Data retrieved from the Gas Chromatograph can be read in this menu.

| PROMPT | DEFAULT | | SECURITY CLEARANCE |
|------------|-----------|-------|--------------------|
| | | | READ ONLY |
| Chrom Strm | 1 | | 0 |
| Energy | 0.000 | MJ/M3 | 0 |
| CO2 | 0.0000 | MOL% | 100 |
| Ethane | 0.0000 | MOL% | 100 |
| I-Butane | 0.0000 | MOL% | 100 |
| I-Pentane | 0.0000 | MOL% | 100 |
| Methane | 0.0000 | MOL% | 100 |
| Nitrogen | 0.0000 | MOL% | 100 |
| N-Butane | 0.0000 | MOL% | 100 |
| N-Heptane | 0.0000 | MOL% | 100 |
| N-Hexane | 0.0000 | MOL% | 100 |
| N-Octane | 0.0000 | MOL% | 100 |
| N-Pentane | 0.0000 | MOL% | 100 |
| Propane | 0.0000 | MOL% | 100 |
| Spec Grav | 0.0000 | | 100 |
| GC Fail | 0 | | 100 |
| F/L GC | FIXED [1] | | 100 |
| GC timeout | 120 SEC | | 100 |

4.9 FIXED GAS DATA

Entries for gas specific parameters can be edited in this submenu.

| PROMPT | DEFAULT | | SECURITY CLEARANCE | |
|-----------|---------|-------|--------------------|-------|
| | | | READ | WRITE |
| Spec Grav | 0.6000 | | 0 | 100 |
| Energy | 38.000 | MJ/M3 | 0 | 100 |
| CO2 | 0.0000 | MOL% | 100 | 100 |
| Nitrogen | 0.0000 | MOL% | 100 | 100 |
| Spec Heat | 1.30 | | 100 | 100 |
| Methane | 95.0000 | MOL% | 100 | 100 |
| Ethane | 5.0000 | MOL% | 100 | 100 |
| Propane | 0.0000 | MOL% | 100 | 100 |
| Water | 0.0000 | MOL% | 100 | 100 |
| H2S | 0.0000 | MOL% | 100 | 100 |
| Hydrogen | 0.0000 | MOL% | 100 | 100 |
| CO | 0.0000 | MOL% | 100 | 100 |
| Oxygen | 0.0000 | MOL% | 100 | 100 |
| I-Butane | 0.0000 | MOL% | 100 | 100 |
| N-Butane | 0.0000 | MOL% | 100 | 100 |
| I-Pentane | 0.0000 | MOL% | 100 | 100 |
| N-Pentane | 0.0000 | MOL% | 100 | 100 |
| N-Hexane | 0.0000 | MOL% | 100 | 100 |
| N-Heptane | 0.0000 | MOL% | 100 | 100 |
| N-Octane | 0.0000 | MOL% | 100 | 100 |
| N-Nonane | 0.0000 | MOL% | 100 | 100 |
| N-Decane | 0.0000 | MOL% | 100 | 100 |
| Helium | 0.0000 | MOL% | 100 | 100 |
| Argon | 0.0000 | MOL% | 100 | 100 |

4.10 RATES AND VOLUMES

The RATES AND VOLUMES can be monitored on this screen.

| PROMPT | DEFAULT | | SECURITY CLEARANCE | |
|---------------|----------------|--------|---------------------------|--------------|
| | | | READ | WRITE |
| Flow Rate1 | 0.0 | M3/HR | 0 | N/A |
| Dly FlwRt1 | 0.0 | M3/D | 0 | N/A |
| Today Vol1 | 0 | M3 | 0 | N/A |
| Ysday Vol1 | 0 | M3 | 0 | N/A |
| Tot Vol 1 | 0 | M3 | 0 | N/A |
| Erate 1 | 0.0 | MJ/HR | 0 | N/A |
| Tdy Enrgy1 | 0 | MJOULE | 0 | N/A |
| Ysy Enrgy1 | 0 | MJOULE | 0 | N/A |
| Tot Enrgy1 | 0 | MJOULE | 0 | N/A |

ULTRA 3000 METRIC SINGLE ORIFICE

4.11 DIAGNOSTICS

The DIAGNOSTICS SUBMENU allows the user to edit and /or view the calibration parameters.

| PROMPT | DEFAULTS | | SECURITY CLEARANCE | |
|------------|----------|--------|--------------------|-------|
| | | | READ | WRITE |
| Inst Prs1 | ####.# | KPAG | 100 | 100 |
| RawLS Prs1 | 10000 | COUNTS | 100 | 100 |
| RawHS Prs1 | 50000 | COUNTS | 100 | 100 |
| Tol Prs1 | 25 | | 100 | 100 |
| CalPtsPrs1 | 0 | | 100 | 100 |
| AsFndPrs1 | ARRAY | | 100 | 100 |
| AsLeftPrs1 | ARRAY | | 100 | 100 |
| RAsLftPrs1 | ARRAY | | 100 | 100 |
| OfstUsPrs1 | NO [0] | | 100 | 100 |
| OfAsFdPrs1 | 0.0 | KPAG | 100 | 100 |
| OfAsLfPrs1 | 0.0 | KPAG | 100 | 100 |
| Inst Tmp1 | ###.# | DEGC | 100 | 100 |
| RawLS Tmp1 | 39173 | COUNTS | 100 | 100 |
| RawHS Tmp1 | 44436 | COUNTS | 100 | 100 |
| Tol Tmp1 | 25 | | 100 | 100 |
| CalPtsTmp1 | 0 | | 100 | 100 |
| AsFndTmp1 | ARRAY | | 100 | 100 |
| AsLeftTmp1 | ARRAY | | 100 | 100 |
| RAsLftTmp1 | ARRAY | | 100 | 100 |
| OfstUsTmp1 | NO [0] | | 100 | 100 |
| OfAsFdTmp1 | 0.0 | DEGC | 100 | 100 |
| OfAsLfTmp1 | 0.0 | DEGC | 100 | 100 |
| Inst Dp1 | ###.## | KPA | 100 | 100 |
| RawLS Dp1 | 10000 | COUNTS | 100 | 100 |
| RawHS Dp1 | 50000 | COUNTS | 100 | 100 |
| Tol Dp1 | 25 | | 100 | 100 |

DIAGNOSTICS (CONTINUED)

| PROMPT | DEFAULTS | SECURITY CODES | |
|------------|--------------|----------------|-------|
| | | READ | WRITE |
| CalPtsDp1 | 0 | 100 | 100 |
| AsFndDp1 | ARRAY | 100 | 100 |
| AsLeftDp1 | ARRAY | 100 | 100 |
| RAsLftDp1 | ARRAY | 100 | 100 |
| OfstUsDp1 | NO [0] | 100 | 100 |
| OfAsFdDp1 | 0.00 KPA | 100 | 100 |
| OfAsLfDp1 | 0.00 KPA | 100 | 100 |
| Inst Aux1 | ###.## PCT | 100 | 100 |
| RawLS Aux1 | 36056 COUNTS | 100 | 100 |
| RawHS Aux1 | 49214 COUNTS | 100 | 100 |
| Tol Aux1 | 25 | 100 | 100 |
| CalPtsAux1 | 0 | 100 | 100 |
| AsFndAux1 | ARRAY | 100 | 100 |
| AsLeftAux1 | ARRAY | 100 | 100 |
| RAsLftAux1 | ARRAY | 100 | 100 |
| OfstUsAux1 | NO [0] | 100 | 100 |
| OfAsFdAux1 | 0.00 PCT | 100 | 100 |
| OfAsLfAux1 | 0.00 PCT | 100 | 100 |
| Inst Aux2 | ###.## PCT | 100 | 100 |
| RawLS Aux2 | 36056 COUNTS | 100 | 100 |
| RawHS Aux2 | 49214 COUNTS | 100 | 100 |
| Tol Aux2 | 25 | 100 | 100 |
| CalPtsAux2 | 0 | 100 | 100 |
| AsFndAux2 | ARRAY | 100 | 100 |
| AsLeftAux2 | ARRAY | 100 | 100 |
| RAsLftAux2 | ARRAY | 100 | 100 |
| OfstUsAux2 | NO [0] | 100 | 100 |
| OfAsFdAux2 | 0.00 PCT | 100 | 100 |
| OfAsLfAux2 | 0.00 PCT | 100 | 100 |

ULTRA 3000 METRIC SINGLE ORIFICE

DIAGNOSTICS (CONTINUED)

| PROMPT | DEFAULTS | | SECURITY CODES | |
|------------|----------|--------|----------------|-------|
| | | | READ | WRITE |
| Inst Batt | ##.## | BATT | 100 | 100 |
| RawLS Batt | 0 | COUNTS | 100 | 100 |
| RawHS Batt | 255 | COUNTS | 100 | 100 |
| To1 Batt | 25 | | 100 | 100 |
| CalPtsBatt | 0 | | 100 | 100 |
| AsFndBatt | ARRAY | | 100 | 100 |
| AsLeftBatt | ARRAY | | 100 | 100 |
| RAsLftBatt | ARRAY | | 100 | 100 |
| OfstUsBatt | NO [0] | | 100 | 100 |
| OfAsFdBatt | 0.00 | BATT | 100 | 100 |
| OfAsLfBatt | 0.00 | BATT | 100 | 100 |

This page intentionally left blank.

5.0 COMMUNICATIONS

5.1 DANIEL MODBUS ASCII REGISTER LIST

| | |
|------|------------|
| 703 | Log1 Accs |
| 704 | Log2 Accs |
| 705 | LogU Accs |
| 720 | LogE Accs |
| 1005 | VP 1 |
| 1006 | VP 2 |
| 1013 | DIn1 |
| 1014 | DIn2 |
| 1015 | DIn3 |
| 1016 | DIn4 |
| 1025 | Batt LoAlm |
| 1026 | Prs1 Alarm |
| 1028 | Tmp1 Alarm |
| 1029 | Dp1 Alarm |
| 1031 | Aux1 Alarm |
| 1032 | Aux2 Alarm |
| 1033 | Flw Rt Alm |
| 1034 | Sys Error |
| 1098 | F/L Prs1 |

| | |
|------|------------|
| 1100 | F/L Tmp1 |
| 1101 | F/L Dp1 |
| 1103 | F/L Aux1 |
| 1104 | F/L Aux2 |
| 1105 | F/L AOut1 |
| 1106 | F/L VP Out |
| 1201 | Batt LoAlm |
| 1203 | Prs1 LoAlm |
| 1204 | Prs1 HiAlm |
| 1207 | Tmp1 LoAlm |
| 1208 | Tmp1 HiAlm |
| 1209 | Dp1 LoAlm |
| 1210 | Dp1 HiAlm |
| 1213 | Aux1 LoAlm |
| 1214 | Aux1 HiAlm |
| 1215 | Aux2 LoAlm |
| 1216 | Aux2 HiAlm |
| 1217 | Maint Mode |
| 1224 | Rate1LoAlm |
| 1225 | Rate1HiAlm |
| 1232 | Sys Error |

ULTRA 3000 METRIC SINGLE ORIFICE

| | |
|------|------------|
| 3002 | Log1 Recno |
| 3004 | Log2 Recno |
| 3011 | Contr Hour |
| 4094 | Cur Year |
| 4095 | Cur Month |
| 4096 | Cur Day |
| 4097 | Cur Hour |
| 4098 | Cur Min |
| 4099 | Cur Sec |
| 7005 | VP 1 |
| 7006 | VP 2 |
| 7019 | Battery |
| 7020 | Metr Pres1 |
| 7022 | Flw Temp1 |
| 7023 | Diff Pres1 |
| 7025 | Aux Anlg 1 |
| 7026 | Aux Anlg 2 |
| 7027 | Flow Rate1 |
| 7028 | Valve Pos |
| 7029 | Version |
| 7030 | Sys Error |
| 7033 | Atms Pres |
| 7034 | Pres Base |
| 7035 | Temp Base |
| 7036 | Orif Mtrl1 |
| 7037 | Pipe Mtrl1 |
| 7038 | Tref Orif1 |
| 7039 | Tref Pipe1 |
| 7041 | Spec Heat |
| 7042 | SG Select |
| 7043 | AGA8 Mthd |
| 7044 | Zs |
| 7045 | Zb |

| | |
|------|------------|
| 7046 | Mol Wt |
| 7047 | B |
| 7050 | K3 |
| 7051 | Real Grav |
| 7052 | Energy |
| 7053 | Methane |
| 7054 | Nitrogen |
| 7055 | CO2 |
| 7056 | Ethane |
| 7057 | Propane |
| 7058 | Fixed H2O |
| 7059 | Fixed H2S |
| 7060 | Hydrogen |
| 7061 | Fixed CO |
| 7062 | Fixed O2 |
| 7063 | I-Butane |
| 7064 | N-Butane |
| 7065 | I-Pentane |
| 7066 | N-Pentane |
| 7067 | N-Hexane |
| 7068 | N-Heptane |
| 7069 | N-Octane |
| 7070 | Fixed Nona |
| 7071 | Fixed Deca |
| 7072 | Fixed He |
| 7073 | Fixed Ar |
| 7075 | Chrom Strm |
| 7076 | VPP 1 |
| 7077 | PP 1 |
| 7078 | VPP 2 |
| 7079 | PP 2 |

| | |
|------|------------|
| 7091 | VP Mode |
| 7092 | Flw Setpnt |
| 7093 | Deadband |
| 7094 | Small Step |
| 7095 | Large Step |
| 7096 | Fine Cntrl |
| 7098 | Ovrd Pres |
| 7099 | Dp Limit |
| 7100 | Preset Pos |
| 7101 | Update Tim |
| 7120 | Orif Diam1 |
| 7121 | Pipe Diam1 |
| 7122 | Tap Lctn 1 |
| 7123 | Zflow Lim1 |
| 7124 | Corr Od1 |
| 7125 | Corr Pd1 |
| 7126 | Corr Beta1 |
| 7127 | Ev 1 |
| 7128 | Cd 1 |
| 7129 | Zf 1 |
| 7130 | Y 1 |
| 7131 | Flw Extn 1 |
| 7132 | Flw Time 1 |
| 7133 | Flow Rate1 |
| 7134 | Dly FlwRt1 |
| 7135 | Log1 Vol1 |
| 7136 | Today Vol1 |
| 7137 | Ysday Vol1 |
| 7138 | Tot Vol 1 |
| 7139 | Erate 1 |
| 7140 | Log1 Eng1 |
| 7141 | Tdy Enrgy1 |
| 7142 | Ysy Enrgy1 |
| 7143 | Tot Enrgy1 |

| | |
|------|------------|
| 7210 | Stn Flw Rt |
| 7211 | St DFlw Rt |
| 7212 | Log1 StVol |
| 7213 | St Tdy Vol |
| 7214 | St Ysy Vol |
| 7215 | St Tot Vol |
| 7216 | Stn Erate |
| 7217 | Log1 StEng |
| 7218 | St Tdy Eng |
| 7219 | St Ysy Eng |
| 7220 | St Tot Eng |
| 7261 | Battery Lo |
| 7262 | Battery Hi |
| 7263 | M Pres1/Lo |
| 7264 | M Pres1/Hi |
| 7267 | M Temp1/Lo |
| 7268 | M Temp1/Hi |
| 7269 | D Pres1/Lo |
| 7270 | D Pres1/Hi |
| 7273 | Aux 1 Lo |
| 7274 | Aux 1 Hi |
| 7275 | Aux 2 Lo |
| 7276 | Aux 2 Hi |
| 7283 | Flw Rt Low |
| 7284 | Flw Rt Hi |
| 7301 | Batt LoLmt |
| 7304 | Prs1 LoLmt |
| 7305 | Prs1 HiLmt |

| | |
|------|------------|
| 7310 | Tmp1 LoLmt |
| 7311 | Tmp1 HiLmt |
| 7313 | Dp1 LoLmt |
| 7314 | Dp1 HiLmt |
| 7319 | Aux1 LoLmt |
| 7320 | Aux1 HiLmt |
| 7322 | Aux2 LoLmt |
| 7323 | Aux2 HiLmt |
| 7333 | Rate1LoLmt |
| 7334 | Rate1HiLmt |
| 7401 | Inst Batt |
| 7402 | Inst Prs1 |
| 7404 | Inst Tmp1 |
| 7405 | Inst Dp1 |
| 7407 | Inst Aux1 |
| 7408 | Inst Aux2 |
| 8001 | Hardwre ID |
| 8002 | F/L Prs1 |
| 8003 | Inst Prs1 |
| 8004 | Man Pres1 |

| | |
|------|------------|
| 8005 | M Pres1/Lo |
| 8006 | M Pres1/Hi |
| 8007 | Prs1 LoLmt |
| 8008 | Prs1 HiLmt |
| 8009 | F/L Tmp1 |
| 8010 | Inst Tmp1 |
| 8011 | Man Temp1 |
| 8012 | M Temp1/Lo |
| 8013 | M Temp1/Hi |
| 8014 | Tmp1 LoLmt |
| 8015 | Tmp1 HiLmt |
| 8016 | F/L Dp1 |
| 8017 | Inst Dp1 |
| 8018 | Man Dp1 |
| 8019 | D Pres1/Lo |
| 8020 | D Pres1/Hi |
| 8021 | Dp1 LoLmt |
| 8022 | Dp1 HiLmt |
| 8023 | F/L Aux1 |
| 8024 | Inst Aux1 |
| 8025 | Man Aux1 |
| 8026 | Aux 1 Lo |
| 8027 | Aux 1 Hi |
| 8028 | Aux1 LoLmt |
| 8029 | Aux1 HiLmt |
| 8030 | F/L Aux2 |
| 8031 | Inst Aux2 |
| 8032 | Man Aux2 |
| 8033 | Aux 2 Lo |
| 8034 | Aux 2 Hi |
| 8035 | Aux2 LoLmt |
| 8036 | Aux2 HiLmt |
| 8037 | Inst Batt |
| 8038 | Battery Lo |
| 8039 | Battery Hi |
| 8040 | Batt LoLmt |
| 8044 | F/L Aout1 |

| | |
|------|------------|
| 8045 | Pct Flow 1 |
| 8046 | Man Aout1 |
| 8050 | Flw Rt Low |
| 8051 | Flw Rt Hi |
| 8052 | Rate1LoLmt |
| 8053 | Rate1HiLmt |
| 8501 | F/L GC |
| 8502 | LiveGCData |
| 8503 | GC Fail |
| 8504 | Chrom Strm |
| 8505 | Energy |
| 8506 | CO2 |
| 8507 | Ethane |
| 8508 | I_Butane |
| 8509 | I_Pentane |
| 8510 | Methane |
| 8511 | Nitrogen |
| 8512 | N_Butane |
| 8513 | N_Heptane |
| 8514 | N_Hexane |
| 8515 | N_Octane |
| 8516 | N_Pentane |
| 8517 | Propane |
| 8518 | Spec Grav |
| 8519 | Methane |
| 8520 | Nitrogen |
| 8521 | CO2 |
| 8522 | Ethane |
| 8523 | Propane |
| 8524 | Water |
| 8525 | H2S |
| 8526 | Hydrogen |
| 8527 | CO |
| 8528 | Oxygen |
| 8529 | I-Butane |
| 8530 | N-Butane |
| 8531 | I-Pentane |

| | |
|------|------------|
| 8532 | N-Pentane |
| 8533 | N-Hexane |
| 8534 | N-Heptane |
| 8535 | N-Octane |
| 8536 | N-Nonane |
| 8537 | N-Decane |
| 8538 | Helium |
| 8539 | Argon |
| 8540 | SG Select |
| 8541 | Spec Grav |
| 8542 | Zs1 Entry |
| 8543 | GC timeout |
| 8601 | AnOutSel |
| 8602 | VP Mode |
| 8603 | Flw Setpnt |
| 8604 | Deadband |
| 8605 | Small Step |
| 8606 | Large Step |
| 8607 | Fine Cntrl |
| 8608 | Ovrd Pres |
| 8609 | Dp Limit |
| 8610 | Preset Pos |
| 8611 | Update Tim |
| 8612 | Valve Pos |
| 8613 | F/L VP Out |
| 8614 | FixdVP Val |

6.0 AGA8 NOMINAL RANGES FOR THE DETAIL AND GROSS CHARACTERIZATION METHODS

| QUANTITY | RANGE | |
|------------------------|--------------|--------------------|
| Relative Density | 0.56 | to 0.87 |
| Gross Heating Value | 17.772519 | to 42.847793 MJ/M3 |
| Methane Mole% | 45.2 | to 98.3 |
| Nitrogen Mole% | 0.3 | to 53.6 |
| Carbon Dioxide Mole% | 0.04 | to 28.94 |
| Ethane Mole% | 0.24 | to 9.53 |
| Propane Mole% | 0.02 | to 3.57 |
| Butanes Mole% | 0.01 | to 1.08 |
| Pentanes Mole% | 0.002 | to 0.279 |
| Hexanes Plus Mole% | 0.0005 | to 0.1004 |
| Helium Mole% | 0.0 | to 0.158 |
| Hydrogen Mole% | 0.0 | |
| Carbon Monoxide Mole% | 0.0 | |
| Argon Mole% | 0.0 | |
| Oxygen Mole% | 0.0 | |
| Water Mole% | 0.0 | to 0.05 |
| Hydrogen Sulfide Mole% | 0.0 | to 0.02 |

Gross Method - Temperatures from 0.0 to 54.44444 DegC
 Pressures from atmospheric to 8273.708 KPAA

Detail Method - Temperatures from -128.88889 to 404.44444 DegC
 Pressures from atmospheric to 275790.28 KPAA

Reference - AGA8 Nov 1992 Manual

| AGA3 NOMINAL RANGES |
|--|
| Orifice Diameters greater than 11.43 MM |
| Pipe Diameters 50.8 MM and greater |
| Beta ratios of 0.10 to 0.75 |
| Temperatures -45.55556 to 176.66667 DegC |
| Pressures 0.0 to 34473.785 KPAG |
| Differential Pressures 0.0 to 186.63 KPA |

This page intentionally left blank.

WARRANTY CLAIM REQUIREMENTS

To make a warranty claim, you, the Purchaser, must:

1. Provide Daniel with proof of the Date of Purchase and proof of the Date of Shipment of the product in question.
2. Return the product to Daniel within twelve (12) months of the date of original shipment of the product, or within eighteen (18) months of the date of original shipment of the product to destinations outside of the United States. The Purchaser must prepay any shipping charges. In addition, the Purchaser is responsible for insuring any product shipped for return, and assumes the risk of loss of the product during shipment.
3. To obtain Warranty service or to locate the nearest Daniel office, sales, or service center call (281) 897-2900, Fax (281) 897-2901, or contact:

Daniel Measurement Services
19203 Hempstead Highway
Houston, Texas 77065

When contacting Daniel for product service, the purchaser is asked to provide information as indicated on the following "Customer Problem Report".

Daniel Measurement Services offers both on call and contract maintenance service designed to afford single source responsibility for all its products.

Daniel Industries, Inc. reserves the right to make changes at any time to any product to improve its design and to insure the best available product.

DANIEL INDUSTRIES, INC.
CUSTOMER PROBLEM REPORT

FOR FASTEST SERVICE, COMPLETE THIS FORM, AND RETURN IT ALONG WITH THE AFFECTED EQUIPMENT TO CUSTOMER SERVICE AT THE ADDRESS INDICATED BELOW.

COMPANY NAME: _____

TECHNICAL CONTACT: _____ PHONE: _____

REPAIR P. O. #: _____ IF WARRANTY, UNIT S/N: _____

INVOICE ADDRESS: _____

SHIPPING ADDRESS: _____

RETURN SHIPPING METHOD: _____

EQUIPMENT MODEL #: _____ S/N: _____ FAILURE DATE: _____

DESCRIPTION OF PROBLEM: _____

WHAT WAS HAPPENING AT TIME OF FAILURE? _____

ADDITIONAL COMMENTS: _____

REPORT PREPARED BY: _____ TITLE: _____

IF YOU REQUIRE TECHNICAL ASSISTANCE, PLEASE FAX OR WRITE THE MAIN CUSTOMER SERVICE DEPARTMENT AT:

DANIEL MEASUREMENT SERVICES
ATTN: CUSTOMER SERVICE
19203 HEMPSTEAD HIGHWAY
HOUSTON, TEXAS 77065

PHONE: (281) 897-2900
FAX: (281) 897-2901

THIS DIGITAL APPARATUS DOES NOT EXCEED THE CLASS A LIMITS FOR RADIO NOISE EMISSIONS FROM DIGITAL APPARATUS AS SET OUT IN THE RADIO INTERFERENCE REGULATIONS OF THE CANADIAN DEPARTMENT OF COMMUNICATIONS.

LE PRÉSENT APPAREIL NUMÉRIQUE N'ÉMET PAS DES BRUITS RADIOÉLECTRIQUES DÉPASSANT LES LIMITES APPLICABLES AUX APPAREILS NUMÉRIQUES DE CLASSE A PRESCRITES DANS LE RÉGLEMENT SUR LE BROUILLAGE RADIOÉLECTRIQUE ÉDICTÉ PAR LE MINISTÈRE DES COMMUNICATIONS DU CANADA.

The sales and service offices of Daniel Industries, Inc. are located throughout the United States and in major countries overseas.

Please contact Daniel Measurement Services at 19203 Hempstead Highway, Houston, Texas 77065, or phone (281) 897-2900 for the location of the sales or service office nearest you.

Daniel Measurement Services offers both on-call and contract maintenance service designed to provide single-source responsibility for all Daniel Measurement and Control products.

Daniel Measurement and Control reserves the right to make changes to any of its products or services at any time without prior notification in order to improve that product or service and to supply the best product or service possible.

DANIEL
