

CERTIFICATE OF COMPLIANCE

Certificate Number 20151112 – E234790
Report Reference E234790- 20090528
Issue Date 2015-NOVEMBER-12

Issued to: EGS ELECTRICAL GROUP L L C
9377 W HIGGINS RD
ROSEMONT, IL 60018-4973 USA

This is to certify that representative samples of Power Supplies for Use in Hazardous Locations - Component
Class I, Division 2, Groups A, B, C and D.
Model No. SDN 20-24-480CC.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: ANSI/ISA 12.12.01-2007, "Non-Incendive Electrical Equipment for use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations; CSA-C22.2 No. 213 (1987), "Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations."

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. The final acceptance of the component is dependent upon its installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

