

Asset Optimization Division

12001 Technology Drive Eden Prairie, MN 55344 (952) 828-3112

Fax: (952) 828-3033

September 20, 2011

Subject: Power Supply and Charger Compatibility for the 375 and 475 Field Communicators

To Whom it May Concern;

With the introduction of the 375 Li-lon Power Module for the 375 Field Communicator, the model **00475-0003-0022** Power Supply & Charger has been introduced to support both the 375 Li-lon Power Module as well as the new 475 Field Communicator. The model **00475-0003-0022** Power Supply and Charger replaces the previous **00375-0003-0011** Power Supply & Charger which has been discontinued.

The new model **00475-0003-0022** charger will also support the 375 NiMh Battery when used with a special adapter cable provided with the new charger. The previous **00375-0003-0011** charger has a 4 pin connector for use with the 375 NiMH pack. The new **00475-0003-0022** charger has a 6 pin connector for user with the 375 and 475 Li-lon Power Module. It is, therefore, impossible to plug the old **00375-0003-0011** Charger into a new Li-lon Power Module on either the 375 or 475 Field Communicators. The following chart summarizes this compatibility:

	Compatible w/ 375 NiMh Battery?	Compatible with 375 Lilon Power Module?	Compatible with 475 Li- Ion Power Module?
00375-0003-0011	YES	NO	NO
00475-0003-0022	YES (with Adapter Cable)	YES	YES

Alan Dewey
475 Field Communicator Product Manager
Asset Optimization Division
Emerson Process Management
Phone +1 952 828 3112

Email: Alan.Dewey@emerson.com