

EU Declaration of Conformity



No: RML 178 Rev. B

We,

Rosemount Measurement Limited
158 Edinburgh Avenue,
Slough, Berkshire, SL1 4UE
United Kingdom

declare under our sole responsibility that the product,


Model SQUING 2 Vibrating Fork Liquid Level Switch

manufactured by,

Rosemount Measurement Limited
158 Edinburgh Avenue,
Slough, Berkshire, SL1 4UE
United Kingdom

to which this declaration relates, is in conformity with the provisions of the European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community notified body certification, as shown in the attached schedule.



(signature)

David J Ross-Hamilton

(name)

Global Approvals Manager

(function)

4/20/2016

(date of issue)

EU Declaration of Conformity



No: RML 178 Rev. B

EMC Directive (2014/30/EU)

Model T***K*N*****

Harmonized Standards: EN 61326-1:2013; EN 61326-2-3:2013; EN 60947-5-6:2001

Model T***T*N*****, T***V*N*****, T***G*N*****, T***H*N*****

Harmonized Standards: EN 61326-1:2013; EN 61326-2-3:2013

LV Directive (2014/34/EU)

Model T***T*N*****, T***V*N*****

Harmonized Standards: EN 61010-1:2010

ATEX Directive (2014/34/EU)

Model T***K*N*****; T***H*N*****

Sira 01ATEX2121X – Intrinsically safe (Gas & Dust)

Equipment Group II, Category 1 GD Ex ia IIC T5...T2 Ga
Ex ia IIIC T85°C...T265°C Da

Harmonized Standards: EN 60079-11:2012; EN 60079-26:2007

Other Standards Used: IEC 60079-0:2011

Model T*****EX*, T*****ES*

Sira 01ATEX1263X – Flameproof

Equipment Group II, Category 1/2 GD Ex db IIC T6...T2 Ga/Gb
Ex tb IIIC T85°C...T265°C Db

Harmonized Standards: EN 60079-0:2012/A11:2013; EN 60079-1:2014;
EN 60079-26:2015; EN 60079-31:2014

(Minor variations in design to suit the application and/or mounting requirements are identified by alpha/numeric characters where indicated * above)

EU Declaration of Conformity



No: RML 178 Rev. B

ATEX Notified Body

Sira Certification Service [Notified Body Number: 0518]
Unit 6, Hawarden Industrial Park,
Hawarden, CH5 3US, United Kingdom

ATEX Notified Body for Quality Assurance

Sira Certification Service [Notified Body Number: 0518]
Unit 6, Hawarden Industrial Park,
Hawarden, CH5 3US, United Kingdom

