



CSA INTERNATIONAL

# Certificate of Compliance

**Certificate:** 1539246 (34186)

**Master Contract:** 155560

**Project:** 1932631

**Date Issued:** 2007/07/11

**Issued to:** Rosemount Analytical Inc.

Uniloc Division  
2400 Barranca Pky  
Irvine, CA 92606  
USA  
Attention: Jerry Flock

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** Wesley Van Hill, C.E.T.

**Authorized by:** Patricia Pasemko, Operations  
Manager

## **PRODUCTS**

**CLASS 2258 02** - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

**CLASS 2258 04** - PROCESS CONTROL EQUIPMENT - Intrinsically Safe, Entity - For  
Hazardous Locations

**CLASS 2258 04 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe, Entity - For Hazardous  
Locations**

**Class I, Division 1, Groups A, B, C, D; Class II, Division 1, Groups E, F, G; Class III**

**2-wire transmitters, HART Protocol:**



**Certificate:** 1539246 (34186)

**Master Contract:** 155560

**Project:** 1932631

**Date Issued:** 2007/07/11

---

Models Xmt-A-HT, Xmt-P-HT, Xmt-C-HT and Xmt-T-HT; rated 42.4 Vdc max, output 4-20mA; CSA Enclosure Type 4X; Temp code T4; Maximum ambient 50°C; Intrinsically safe when connected per installation instruction No 1400251, 1400255, 1400259, 1400263

Input, all transmitters,  $V_{max} = 30V$ ,  $I_{max} = 200mA$ ,  $P_{max} = 0.9W$ ,  $C_i = 0nF$ ,  $L_i = 0uH$

Output, Model Xmt-A/pH-HT,  $V_{oc} = 12.9V$ ,  $I_{sc} = 86.5mA$ ,  $P_{max} = 169.4mW$ ,  $C_a = 1uF$ ,  $L_a = 5mH$

Output, Model Xmt-C-HT,  $V_{oc} = 7.2V$ ,  $I_{sc} = 221mA$ ,  $P_{max} = 279.5mW$ ,  $C_a = 13uF$ ,  $L_a = 800uH$

**2-wire transmitters, Foundation Fieldbus:**

Models Xmt-A-FF, Xmt-P-FF, Xmt-C-FF and Xmt-T-FF; rated 9-32 Vdc max, output 4-20mA; CSA Enclosure Type 4X; Temp code T4; Maximum ambient 50°C; Intrinsically safe when connected per installation instruction No 1400252, 1400256, 1400260, 1400264

**Entity Parameters,**

$V_{max} = 30V$ ,  $I_{max} = 300mA$ ,  $P_{max} = 1.3W$ ,  $C_i = 0.4nF$ ,  $L_i = 0uH$

**Output, Model Xmt-A/P-FF,**

$V_t = 13.03V$

$I_t = 157.17mA$

$P_o = 511.59mW$

$C_a = 964.5nF$  Groups A/B

$C_a = 5.99mF$  Groups C/D

$C_a = 21.69mF$  Group D

$L_a = 974mH$  Groups A/B

$L_a = 2.974mH$  Groups C/D

$L_a = 7.97mH$  Groups D

**Output, Model Xmt-C-FF,**

$V_t = 7.71V$

$I_t = 174.42mA$

$P_o = 336.19mW$



**Certificate:** 1539246 (34186)

**Master Contract:** 155560

**Project:** 1932631

**Date Issued:** 2007/07/11

---

Ca = 850nF Groups A/B

Ca = 128mF Groups C/D

Ca = 9978mF Group D

La = 865mH Groups A/B

La = 2.66mH Groups C/D

La = 7.16mH Groups D

**2-wire transmitters, Fieldbus Intrinsic Safety Concept (FISCO):**

Models Xmt-A-FI, Xmt-P-FI, Xmt-C-FI and Xmt-T-FI; rated 9-17.5 Vdc max, output 4-20mA; CSA Enclosure Type 4X; Temp code T4; Maximum ambient 50°C; Intrinsically safe when connected per installation instruction No 1400303, 1400304, 140005, 1400306

**Entity Parameters,**

Vmax = 17.5V, Imax = 380mA, Pmax = 5.32W, Ci = 0.4nF, Li = 0uH

**Output, Model Xmt-A/P-FI,**

Vt = 13.03V

It = 64.15mA

Po = 208.96mW

Ca = 964.5nF Groups A/B

Ca = 5.99mF Groups C/D

Ca = 21.69mF Group D

La = 7.97mH Groups A/B

La = 29.97mH Groups C/D

La = 59.97mH Groups D

**Output, Model Xmt-C-FI,**

Vt = 7.71V

It = 64.15mA



**Certificate:** 1539246 (34186)

**Master Contract:** 155560

**Project:** 1932631

**Date Issued:** 2007/07/11

---

Po = 123.65mW

Ca = 850nF Groups A/B

Ca = 128mF Groups C/D

Ca = 9978mF Group D

La = 7.965mH Groups A/B

La = 29.965mH Groups C/D

La = 59.965mH Groups D

**CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations**

**Class I, Division 2, Groups A, B, C, D; Class II, Division 1, Groups E, F, G; Class III**

**HART:**

Models Xmt-A-HT, Xmt-P-HT, Xmt-C-HT and Xmt-T-HT; rated 42.4 Vdc max, output 4-20mA; CSA Enclosure Type 4X; Temp code T4; Maximum ambient 50°C.

**Fieldbus Foundation:**

Models Xmt-A-FF, Xmt-P-FF, Xmt-C-FF and Xmt-T-FF; rated 9-32 Vdc max, output 4-20mA; CSA Enclosure Type 4X; Temp code T4; Maximum ambient 50°C.

**Fieldbus Intrinsically Safe Concept:**

Models Xmt-A-FI, Xmt-P-FI, Xmt-C-FI and Xmt-T-FI; rated 9-17.5 Vdc max, output 4-20mA; CSA Enclosure Type 4X; Temp code T4; Maximum ambient 50°C.

**APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No. 0-M1991 - General Requirements Canadian Electrical Code Part II

CSA Standard C22.2 No.0.4-M2004 - Bonding and Grounding of Electrical Equipment (Protective Grounding)

CSA Standard C22.2 No. 25-M1966 - Enclosures for Use in Class II Groups E, F and G Hazardous Locations

CSA Standard C22.2 No. 94-M1991 - Special Purpose Enclosures



**CSA INTERNATIONAL**

**Certificate:** 1539246 (34186)

**Master Contract:** 155560

**Project:** 1932631

**Date Issued:** 2007/07/11

---

CSA Standard C22.2 No.142-M1987 – Process Control Equipment

CSA Standard C22.2 No. 157-M1992 - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations

CSA Standard C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations



## ***Supplement to Certificate of Compliance***

**Certificate:** 1539246

**Master Contract:** 155560

***The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.***

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
1932631	2007/07/11	Update Report 1539246 to include alternate Fieldbus Digital Communication Card (Intrinsically Safe)
1794325	2006/06/10	Update Report 1539246; revised pwb layout, reposition of connector, JP-3(Replace Figures 58, 59, 61 and 82).
1768366	2006/05/15	Update Report 1539246 to include new LCD Display.
1617418	2005/06/06	Update Report 1539246 include Models XMT-x-FF and XMT-x-FI
1617421	2005/04/22	Update Report 1539246, include sensors Model 242 (3" – 4") for use with Transmitter Model Xmt-T-HT
1596387	2005/04/06	Update Report 1539246, include alternative enclosure material, GE Plastics, Type EXL9330
1539246	2004/07/21	Certification of Xmt-HT Transmitter (I.S. Gr A-G; NI Gr A-D; DIP Groups E-G, Class III) Similar to already-approved 5081-HT