

MILLENNIUM II



ISO 9001:2000



Monitoring Inc.

. Net Safety

Monitoring Inc.

, Net Safety Monitoring Inc.

Net Safety

Net Safety Monitoring Inc.

Net Safety Monitoring Inc.

36

, Net Safety Monitoring Inc.

Net Safety Monitoring Inc.

Net Safety Monitoring Inc.

www.net-safety.com

Net Safety Monitoring Incorporated

: (403) 219-0688

Corporate Headquarters

: (403) 219-0694

2721 Hopewell Place NE

E-mail: info@net-safety.com

Calgary, AB Canada T1Y 7J7

- : www.net-safety.com

	2
	2
	2
	5
	5
	5
	5
	6
	6
1.	7
1.1	7
1.2	7
1.2.1	7
1.2.2	8
2.	9
2.1	9
	9
2.1.1	9
	9
2.2	10
2.2.1	11
2.2.2	13
2.2.3	13
2.2.4	14
2.2.5	15
2.2.6	16
3.	17
3.1	17
	18
	/	18
3.2	18
3.3 LED	18
3.4	(.....).....	18
4.	19
4.1	19
4.2	/	19
4.2.1	(.....).....	19
4.2.1 (.....)	21
4.2.2	/	21

4.2.3	22
4.2.4	23
4.2.5	23
4.2.6	24
4.2.7	24
4.2.8	MODBUS.....	25
4.2.9	25
4.3.0	26
4.3.1	26
4.3.2	27
4.3.3	27
4.3.4	()	28
4.3.5	29
4.3.6	29
4.3.7	-	29
4.4	30
4.5	30
4.5.1	4-20	30
4.5.2	30
4.5.3	, LED	31
4.5.4	RS-485 Modbus RTU	31
4.5.5	HART	34
5.	35
5.1	35
5.2	35
5.3	/	35
5.4	36
	37
A:	, (ESD).....	37
B:	38
:	MILLENNIUM II	39

Millennium II,
Net Safety

Millennium,

« »

Millennium II

/HART,

Millennium II (Analog/HART
SX3)

()

« »

:

M2a-b-c, Millennium II :

1. EN 61779-1 EN 61779-4

TX-M2a-b, Millennium II, ():

1. Millennium 2 3, IP54
EN 50014 EN 60079-0.

2. EN 61779-1 EN 61779-4

(AL)

Millennium II,
(SS).

1:



Millennium II ()

()

()

Millennium II	A		B		C	
(AL)	5,6	142	5,4	137	5,7	145
(SS)	5,1	130	4,6	117	5,8	147

1:



1.

1.1


Net Safety Monitoring.

1.2

1.2.1

Millennium II

2:




1.2.2

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.
- 7.
- 8.
- 9.
- 10.
- 11.
- 12.

“Pull Here” ().

3:



2.

2.1



85°C.

5°C

. ATEX ,



).

(,

•

•

4 – 20 A

,

4 – 20 A

•

, ,

« ».

IEC 61000-1,

IEC 61000-4 EMI MIL-W16878D
B/N.

•

•

B)

•

RS-485,

(120).

•

RS-485 - 2-

2.1.1



Millennium II,

-55°C +85 °C.

:

•

« »,

« ».

•

•

L-1


+½ +1½.

2.2



4.

4:




(ESD).

2.2.1


()

5, 6 7.


5:



6:



7:




2.2.2

Millennium II

RST COM.

8:



2.2.3




2

	+Vdc()
	SigA
	SigB
	Com

3

RST	
+Vdc(10.5-32)	(+)
COM	(-)
4-20(CH1)	
ISO(CH1)	+Vdc 4-20
4-20(CH2)	
ISO(CH2)	+Vdc 4-20

9:



2.2.4

JP1 JP2 1 2
5
(MAN-0081).

2.2.5


MAN-0076 .2 Millennium II
2008
Net Safety Monitoring Inc.

10.

10:

/	
	+
	-
1	+
	-
2	+
	-
3	+
	-

/		
FNO		.
FCOM		
FNC		.
A1NO	1	.
A1COM		
A1NC		
A2NO	2	.
A2COM		
A2NC		
A3NO	3	.
A3COM		
A3NC		



2.2.6

3,0 A. , LED

()

(1 00% (), “Channel 1 00 %LEL (or PPM), Channel 2 00 %LEL (or PPM)”
2 00% ()).

“Disabled” /

4,0

1225

3.

3.1

OLED


« 3: LED

» .16.

LED -

(/)

« » -



3: LED

» .16.

«3.2

»

17.

) (, : (

:
Millennium II

«1», «2»

«3».



(,)

/

8 ,6 4
8,6 4

3.2
Millennium II

LED (OLED)

(8,6 4).

3.3 LED
LED

, « , / , LED ,
».

3.4

()
()

4.

4.1

1. () .
2. "Calibrate Sensor?" (?).
3. , 1 2. 1 (2 (8 6))
4. 4 3) 3 (
5. "Exit"()
6. , 50 . - ;

4.2

4:

/	Modbus	()
---	--------	-----

4.2.1

50% Millennium II
50% 10- 60% ,
'cal. gas value' () . 24
5 , 4 . .

LED

1. ()", ' 1(' 1) "enter Main menu "yes"()
2. 3 3). "Calibrate Sensor?" (?), (
3. 3 3). "Calibrate Sensor #1?" (1?), (
4. 2, (2 2) "Calibrate Sensor #2?"
5. (1 2), (3 3).
6. "YES" (1 1)
7. 1 1), "Apply Clean Air" (). "Z & Span" , ("Setting zero" ().
8. 50% (%)
9. "Spanning" (% ,)
10. "Remove Cal Gas".
11. "Cal Complete".
12. ()

	Calibrate Sensor	Calibrate Sensor#1	Calibrate Sensor#1?	Apply Clean Air	CH1: Setting Zero	Apply 50% LEL/PPM	Spanning (value)%LEL /PPM	Remove Gas	Cal. Complete
	/	/	'YES'	'Z&Span' (/)					
	3	1		1)					
		2		()					
		3							

4.2.1 ()

« » , ().

(2 2).



0,5 – 1,0

4.2.2 /

CH1 (1) (CH2 Millennium II. –)

1. , 1 (1) “enter main menu”, “yes”.

2. « » (2) “Enable/Disable Channel?”. “Enable/Disable Channel?”

3. (3 3) “CH 1 Enabled”.

4. 1 (3 3). “CH 1 disabled”.

5. “CH 2 enabled”, « » (2 2 2). (3 3)

6. / “Exit”, « » (2 3 2), (3).

7. (1), (3 2) “Exit”, (2), « »

: , 50 ,

4.2.4

- : ()
- 1, 2 3: ()
- 1. , 1 (1) "yes". "enter main menu",
- 2. « » (1 1) « » (2 2), "Set Relay Options?" (?).
- 3. (3 3) .
- 4. « » (2 2) « » (1 1), 3 (3) (1, 2 3). (Alarm Relay).
- 5. Alarm Relay, "Norm. De-Energized" () "Norm. Energized" () (3 3) .
- 6. « » ("Latching" (2 2), "Non-Latching" (), "Latching" "Non- Latching". (3 3) .
- 7. 2), "Exit". , « » (3 2 3),
- 8. 2(2) "Exit", 3(3) , ..

4.2.5

- (3) .
- 1. , 1 (1) "yes". "enter main menu",
- 2. 2), « » (1 1) « » (2 2) "Relay Assignment?" (?). "Alarm Relay1" (1), "Alarm Relay 2"(3) "Exit" ().
- 3. 1 2). (3 3) « » « » (1 2) .

4. (Point 2), (RL) (CH), (Point 1)

5. : "RL1:CH1 Point 1" RL1:CH2 Point 1 "RL1:CH1 Point 1" 1(RL1)
RL1:CH2 Point 2 "RL1:CH1 Point 2" RL1:CH2 Point 1 RL1:CH1 Point 2 "RL1:CH2 Point 2"

6. ("Disabled" (3), "Low" (3), "High" (3) / 1 2(CH1 2),

7. « » « » (1 1) ((RL) 2 (CH), 2) "Exit"

8. "Exit", (3 1) 3) 2(2)

4.2.6

(20,9) - :
Above (), Above (), - Below (), Below ().
: Above Above, Below Below Above Below .

4.2.7

1. "enter main menu", 1 (1) "yes".

2. 2), « » (1 1) « » (2) "Select Display Language?" (?).

3. (3 3). "English" ().

4. (3 3).

5. "Exit", « » (2 2) (3 3) "Exit" 3 3).

3.

4.2.8 MODBUS

MODBUS:

- : 001 () 247
 - : 02400 bps, 04800 bps, 09600 bps (), 19200 bps 57600 bps.
 - : (), , .
1. , ' 1 (1) "yes". "enter main menu",
 2. « » (1 1) « » (2 2), "Modbus Setup" (Modbus).
 3. (3 3)
 4. (3 3) Current Setting () Slave Address () « » (1 1) « » (2 2) 001). 001-247. (3 3),
 5. 3(3) . « » (2 2) ' Baud rate () , « » (1 3 1) 3) 2) (3 3),
 6. 3). « » (2 2) , Parity Bit (3)
 7. (2 3(2) 3) « » (1 1) « » (3 3),
 8. "Exit", « » (3 2 2) "Exit" , 3 3) 3.

4.2.9

(MST).

1. , ' 1 (1) "yes". "enter main menu",
2. 2), « » (1 1) « » (2 2) "Setup Current Date?" (?).

3. (3 3)
4. / / . « » (1 1) 2 2)
OK.
5. , "OK?" "Exit" (3

4.3.0

(MST).

1. , 1 (1) "yes". "enter main menu",
2. 2), « » (1 1) « » (?). 2
"Setup Current Time?" (?).
3. (3 3)
4. / / . « » (1 1) 2 2)
OK.
5. 3), , "OK?" "Exit" (3

4.3.1

Millennium II 980 .

1. , 1 (1) "yes". "enter main menu",
2. 2), « » (1 1) « » (?). 2
"View Event Log?" (?).
3. (3 3) « » (1 1) « » (2 2)
4. "Exit", 3(3), 1(1)
2 (2), 3 3 "Exit".

- : CH1, CH2 : ML2.

- : 11 , Millennium II, 5.
- :

5:

	Power UP / RST	ML2	
	Communicate Er	CH1	CH2
	High Alarm	CH1	CH2
	Low Alarm	CH1	CH2
	Cal Complete	CH1	CH2
	Cal Zero fail	CH1	CH2
	Cal Span Fail	CH1	CH2
	Cal Abort	CH1	CH2
	Sensor Fail	CH1	CH2
	Enabled	CH1	CH2
	Disabled	CH1	CH2

4.3.2

Millennium II

1. , 1 (1) "yes". "enter main menu",
2. « » (1 1) « » (2 2), "Manual Reset?" (?).
3. (3 3)
4. "Initiate Reset"(). YES
(1 1).

4.3.3

Millennium II



1. , 1 (1) "yes". "enter main menu",
2. « » (1 1) « » (2) 2), "Self test Relay?" (?).
3. (3 3)
4. "Self Test Relay. Caution, will trip alarm" (YES (1 1). "Ensure alarm response items are disconnected." (YES (1 1).
5. "Exit", « » « »: 1(1) 2(2), 3(3)
6. 1, 2 3. - "Relay Test Complete" (Net Safety

4.3.4

1. , 1 (1) "yes". "enter main menu",
2. « » (1 1) « » (2) 2), "Sensor Upper Limit (Range)" ()).
3. (3 3).
4. (), 1, 1(2 3 3), , 3 3) 2. « » (2 2), (
5. « » « » (1 2 1 2) « »/« » () . :
6. (3 3),
7. "Exit"

4.3.5

"Select Gas Type" ("K- "))

()

4.3.6

50%

10% 60%

1. "enter main menu", 1 (1) "yes".

2. 2), « » (1 1) « » (2) "Cal Gas value" ().

3. 1 2. (3 3),

4. 1 (1) 2 (2). 3 :

5. : 50. : 0 5 0

6. 0 9 1(1) 2(2) / (

7. "Exit"

4.3.7

Millennium II.

1. "enter main menu", 1 (1) "yes".

2. 2), « » (1 1) « » (2) "Serial Number Firmware Version" ().

3. (3 3). -

4. "Exit", (3 3)

4.4

LED
«Sensor Fault»,

2,5



4.5 Millennium II

, RS-485 Modbus RTU

HART. 4-20 A,

4.5.1 4-20

20 A.
4,0 A

4 -

LED

4,0 – 20,0 A.

4.5.2

1, 2 3
» «

« » « » « »

4.5.3

6

LED

, LED

6:

	(A)	LED		
		()	()	
0	4-20	()	()	-
1	3.0			()
2	3.3			,
3	3.3			,
4	3.6			,
5	3.6			4 3%
6	2.5			,
7	3.0			90 ()
8	3.6			4,
9	3.0/3.3			90
10	3.0/3.3			4 , 90-
11	2.5			_____ (-40°C).
12	2.5			_____ (+75°C).
13	2.5			_____ <8 .
14	2.5			_____ >33 .

	(A)	LED		
15	2.5			
16	20.0			
17	2.5			_____ : « » ()
18	2.5			_____ : . .
20	2.5			_____ : .
21	2.5			_____ : .

4.5.4 RS-485 Modbus RTU

RS-485 Modbus RTU. 7 8 ML2.
 Modbus

7. Modbus

40001	(RTU sensor out), 1	X	
40002	(RTU sensor stat), 1	X	
40003	(RTU temperature), 1	X	
40004	*RFU, 1, 0x0000	X	
40005	RFU, 1, 0x0000	X	
40006	(RTU sensor out), 2	X	
40007	(RTU sensor stat), 2	X	
40008	(RTU temperature), 2	X	
40009	RFU, 2, 0x0000	X	
40010	RFU, 2, 0x0000	X	
40011	(RTU sensor out), 3	X	
40012	(RTU sensor stat), 3	X	
40013	(RTU temperature), 3	X	
40014	RFU, 3, 0x0000		
40015	RFU, 3, 0x0000		
40016	(RTU sensor out), 4	X	
40017	(RTU sensor stat), 4	X	
40018	(RTU temperature), 4	X	
40019	RFU, 4, 0x0000	X	
40020	RFU, 4, 0x0000	X	
40021	ML2 **	X	
40022 40090	RFU		
40091	, 1 - 4	X	X
40092	, 1 - 4	X	X
MODBUS 40093 - 40096			
40093	1	X	X
40094	1	X	X
40095	2	X	X
40096	2	X	X
40097	RFU, 3	X	X
40098	RFU, 3	X	X
40099	RFU, 4	X	X
40100	RFU, 4	X	X
40101			X

*RFU –

** ML2 (40021) –

7

8: ML2

0x0000	-
0x0001	1.
0x0002	1
0x0004	1
0x0008	2.
0x0010	2
0x0020	2
0x0040	1
0x0080	2

6.2.5 HART

HART –

Millennium II.
Millennium II.

,
HART-
Millennium II –

HART-
HART- Net Safety
HART-
(MAN-0083)

HART-

,
Millennium II
HART-
(MAN-0081).

5.

5.1

Net Safety Monitoring

90

LED

Millennium II

50%
) 12,5 A (53%)
 11,5 A (47%
 «+» «-> 10%) 13,3 A
 (58%) 10,7 A (42%)

5.2

Millennium II

5.3 /

9.

Net Safety	
CCS-1	/
JB-MPNS-A JB-MPNS-S	
DSC-1	
TX-M21-A	
TX-M21-AR	
TX-M21-ARS	
TX-M21-AD	Modbus
TX-M21-ARD	Modbus
TX-M21-AH	/ Hart
TX-M21-AHR	/ Hart
TX-M22-A	
TX-M22-AR	
TX-M22-ARS	
TX-M22-AD	Modbus
TX-M22-ARD	Modbus

5.4

Authorization number).
(403) 219-0688

(Material Return
Net Safety Monitoring

- 1. (Net Safety).
- 2. ,
- 3. ,
- 4. - ,
- 5. : Net Safety Monitoring Inc., 2721 Hopewell Place NE,
Calgary, Alberta, Canada, T1Y 7J7
- 6. : RETURN for REPAIR ().
- 7. : Equipment being returned
for repair All charges to be billed to the sender (,)

1-4,

A:

(ESD)

:

!

-
-
-
-
-
-



B.










1

()	AWG #20	AWG#18	AWG#16	AWG#14	AWG#12	AWG#10	AWG#8
30.5	1.02	0.64	0.40	0.25	0.16	0.10	0.06
61	2.03	1.28	0.80	0.51	0.32	0.20	0.13
91.5	3.05	1.92	1.20	0.76	0.48	0.30	0.19
122	4.06	2.55	1.61	1.01	0.64	0.40	0.25
152.5	5.08	3.20	2.01	1.26	0.79	0.50	0.31
183	6.09	3.83	2.41	1.52	0.95	0.60	0.38
213.5	7.11	4.47	2.81	1.77	1.11	0.70	0.44
244	8.12	5.11	3.21	2.02	1.27	0.80	0.50
274.5	9.14	5.75	3.61	2.27	1.43	0.90	0.57
305	10.20	6.39	4.02	2.53	1.59	1.09	0.63
381	12.70	7.99	5.03	3.16	1.99	1.25	0.79
457.5	15.20	9.58	6.02	3.79	2.38	1.50	0.94
534	17.80	11.20	7.03	4.42	2.78	1.75	1.10
610	20.30	12.80	8.03	5.05	3.18	2.00	1.26
686	22.80	14.40	9.03	5.68	3.57	2.25	1.41
762.5	25.40	16.00	10.00	6.31	3.97	2.50	1.57
915	30.50	19.20	12.00	7.58	4.76	3.00	1.88
1067.5	35.50	22.40	14.10	8.84	5.56	3.50	2.21
1220	40.60	25.50	16.10	10.00	6.35	4.00	2.51
1372.5	45.70	28.70	18.10	11.40	7.15	4.50	2.82
1525	50.10	32.00	20.10	12.60	7.94	5.00	3.14
1677.5	55.80	35.10	22.10	13.91	8.73	5.50	3.46
1830	61.00	38.30	24.10	15.20	9.53	6.00	3.77
1982.5	66.00	41.50	26.10	16.40	10.30	6.50	4.08
2135	71.10	44.70	28.10	17.70	11.10	7.00	4.40
2287.5	76.10	47.90	30.10	19.00	12.00	7.49	4.71
2440	81.20	51.10	33.10	20.20	12.70	7.99	5.03
2745	91.40	57.50	36.10	22.70	14.30	8.99	5.65
3050	102.00	63.90	40.20	25.30	15.90	9.99	6.28

1

C: Millennium II

			/HART	
()	: <150 A 24 : 100 24			
	10,5 - 32	10,5 - 32	18 - 32	10,5 - 32
-	: 150 170 450 470 ,5 FM		1	; 2
	: IEC 61000-1-4 IEC 61000-4-3			
	LED LED (,)			
	: -55°C +85°C			
	0 - 99%			
	, , 316			
IP/NEMA	IP67/Nema4X			
	/ 2			
	(4) 5A 30 / 250 (4) 2,5A 60 /	4-20	4-20 HART-	RS 485 Modbus RTU

	<p style="text-align: center;"> Class I, Div 2 Grps ABCD; Class I, Zone 2 AEx/Ex nA nC IIC, T5.</p> <p style="text-align: center;">FM07 ATEX 0014X:  0575  II 3G, Ex nAnC IIC, T5,, -55°C +85°C. FM 6320, CSA-C22.2 No. 152, ANSI/ISA-92.0.01, ANSI/ISA-92.03.01 FM6340, EN61779-1, EN61779-4.</p> <p>TX-M2a-b, Millennium 2 ()</p> <p>1. Millennium 2 , IP54, EN 50014 EN 60079-0.</p> <p>2. , EN 61779-1 EN 61779-4</p>
316 SS	<p style="text-align: center;"> Class I, Div I Grps BCD; Class I, Zone 1 AEx/Ex d IIB+H2, T5, IP67, Type 4X, -55°C +85°C FM 6320, CSA-C22.2 No. 152, ANSI/ISA-92.0.01, ANSI/ISA-92.03.01 FM6340, EN61779-1, EN61779-4.</p> <p>FM07 ATEX 0013X:  0575  II 2G, Ex d IIB+H2, T5, IP67, -55°C +85°C M2a-b-c, Millennium 2</p> <p>1. , EN 61779-1 EN 61779-4</p>
	<p style="text-align: center;"> Class I, Div I Grps BCD; Class I, Zone 1 AEx/Ex d IIB+H2, T5, IP67, Type 4X, -55°C +85°C FM 6320, CSA-C22.2 No. 152, ANSI/ISA-92.0.01, ANSI/ISA-92.03.01 FM6340, EN61779-1, EN61779-4.</p> <p>DNV-2005-OSL-ATEX-0324:  0575  I 2G, EEx d IIB+H2, T5, IP66, -40°C +85°C M2a-b-c, Millennium 2</p> <p>1. , EN 61779-1 EN 61779-4</p>

Net Safety Monitoring Inc.
2721 Hopewell Place NE, Calgary, AB Canada T1Y 7J7
1-866-FIREGAS (347-3427). (403) 219-0688. (403) 219-0694
<http://www.net-safety.com> info@net-safety.com

[8:00 – 17:00]: (403) 769-6074; (403) 717-8219.
: (403) 219-0694 Email: productservices@net-safety.com
http://www.net-safety.com/service/product_services.html

