

RECOMMENDED D>150 [6]
MIN D=50 [2] REQUIRES SPECIAL CONFIG SETTINGS.

MAX REC. H<(D+100) [D+4]

DEPENDING ON TURBULENCE IN TANK AND MOUNTING ANGLE THE PROBE MAY NEED TO BE ANCHORED OR SUPPORTED.

N<ØBRIDLE/PIPE

THE PROBE MUST BE IN THE CENTER OF THE BRIDLE/PIPE.

POS	ITEM DESCRIPTION	QTY	REMARK	SUPPLIER
04	GASKET	1	ACC. TO BSP-G THREAD STD.	CUSTOMER
03	GASKET	1	SOFT GASKET T=MIN 1.6 (ANSI B16.5/1a, EN1514-1/1BC). SEE NOTE 1.	CUSTOMER
02	SCREW/NUT/WASHER	-	ACC. TO FLANGE STD, SEE NOTE 1.	CUSTOMER
01	FLANGE	1	DIM. ACC. TO ANSI B 16.5/EN 1092-1. OTHER ON REQUEST. P/T RATING, SEE NOTE 1.	RMT

ISSUED BY	WEEK	PRODUCT CODE	FILE	INSTALLATION DRAWING TITLE
GU-TK-MA	0708	5300	PRO/E	MECHANICAL INSTALLATION DWG RIGID SINGLE LEAD, SPECIAL MTRL
APPROVED BY	WEEK	ORIGINAL DWG NO.	SCALE	
GU-HF	0708			

ROSEMOUNT | 1 ST ANGLE | DOC TYPE 2 | DWG NO. 9240017-988 | ISSUE 01 | SHEET 1/1

THE COPYRIGHT/OWNERSHIP OF THIS DOCUMENT IS AND WILL REMAIN OURS. THE DOCUMENT MUST NOT BE USED WITHOUT OUR AUTHORIZATION OR BROUGHT TO THE KNOWLEDGE OF A THIRD PARTY. CONTRAVENTION WILL BE PROSECUTED. ROSEMOUNT TANK RADAR AB, SWEDEN.

PART	DLINK DATA	DRV.
00-7	ISSUE-VER	00-1

INST DWG A3 061023

2. GUIDELINES AND TANK CONNECTIONS VALID FOR BOTH ø4 AND ø6 WIRE.
1. P/T-RATING FOR FLANGE, SEE REF MANUAL.

FOR MORE INFO SEE REFERENCE MANUAL