

Tank ID	Port	RTG	DAU

NOTE 1
WHEN A RS-232 PORT (X10 OR X11) IS BEEING USED, A SPECIAL JUMPER (9240 002-731) MUST BE PRESENT IN X5 OR X6 RESPECTIVELY.

NOTE 2
TRL/2 BUS. CUSTOMER SUPPLIED SINGLE TWISTED, PREFERABLY SHIELDED PAIR. INDIVIDUAL SHIELDING IS MANDATORY WHERE TWO BUSES RUN ALONGSIDE.
MIN. AWG 20 - 0.5 SQMM.
THE TWO WIRES MAY BE INTERCHANGED.

B

Product Discontinued

ISSUED BY	WEEK	PRODUCT CODE	FILE
GKM	9137	REX	ACAD
APPROVED BY	WEEK	ORIGINAL DWG NO.	SCALE
GKT	9138	9240 002-906	

INSTALLATION DRAWING TITLE
EL.INSTALLATION DRAWING
EXTERNAL MODEM-FCU

ROSEMOUNT®
Tank Gauging

1 ST ANGLE

DOC TYPE	DWG NO.	ISSUE	SHEET
2	9240 002-906	7	1/1

THE COPYRIGHT/OWNERSHIP OF THIS DOCUMENT IS AND WILL REMAIN OURS. THE DOCUMENT MUST NOT BE USED WITHOUT OUR AUTHORIZATION OR BROUGHT TO THE KNOWLEDGE OF A THIRD PARTY. CONTRAVENTION WILL BE PROSECUTED. ROSEMOUNT TANK RADAR AB, SWEDEN.