Product Discontinued



Tank ID	Port	RTG	DAU

NOTE 1

WHEN USING A RS-232 PORT (X10 OR X11) A SPECIAL JUMPER (9240 002-731 RTR SUPPLIED) MUST BE USED IN X5 OR X6 RESPECTIVELY.

NOTE 2

TRL/2 BUS. CUSTOMER SUPPLIED SINGLE TWISTED, PREFERABLY SHIELDED PAIR. INDIVIDUAL SHIELDING IS MANDATORY WHERE TWO OR MORE BUSES RUN ALONGSIDE.
MIN. AWG 20 - 0.5 SQMM. THE TWO WIRES MAY BE INTERCHANGED.

NOTE 3

CUSTOMER SUPPLIED SHIELDED, TWISTED PAIR DATA TRANSMISSION CABLE, MIN AWG 24 - 0.25 SQMM, MAX TOTAL LENGTH 1.2 KM.
THE IMPEDANCE AT 100kHz SHOULD BE APPROXIMATELY 120 OHMS.
USE DUAL PAIRS (FULL DUPLEX MODE) IF A RECEIVE/TRANSMIT CONTROL SIGNAL IS NOT AVAILABLE FROM THE HOST.

NOTE 4

SET JUMPER S3 ON THE FCI-BOARD ACCORDING TO TYPE OF TRANSMISSION: S3 = 1-2 & 3-4 FOR HALF DUPLEX, S3 = 1-3 & 2-4 FOR FULL DUPLEX.
IN FULL DUPLEX MODE USE THE A-B TERMINALS TO RECEIVE DATA FROM THE HOST AND THE A'-B' TERMINALS TO TRANSMIT DATA TO THE HOST.

NOTE 5

TERMINATE THE END OF THE BUS WITH THE CHARACTERISTIC LINE IMPEDANCE.
INTERNAL TERMINATOR ON THE FCI-BOARD IS FACTORY CONNECTED WITH JUMPERS S1 & S2.

NOTE 6

THE FCI-BOARD IS GALVANICALLY ISOLATED FROM GROUND.
TERMINALS WITH THE SAME DESIGNATION ARE INTERNALLY CONNECTED.

ISSUED BY	WEEK	PRODUCT CODE	FILE	INSTALLATION DRAWING TITLE
GSP-MH	9832	REX	ACAD	EL. INSTALLATION DRAWING PC-HOST-FCU
APPROVED BY	WEEK	ORIGINAL DWG NO.	SCALE	
GKT	9832	9240 007-989		

ROSEMOUNT® Tank Gauging

1 ST ANGLE

DOC TYPE	DWG NO.	ISSUE	SHEET
2	9240 007-989	4	1/1

THE COPYRIGHT/OWNERSHIP OF THIS DOCUMENT IS AND WILL REMAIN OURS. THE DOCUMENT MUST NOT BE USED WITHOUT OUR AUTHORIZATION OR BROUGHT TO THE KNOWLEDGE OF A THIRD PARTY. CONTRAVENTION WILL BE PROSECUTED. ROSEMOUNT TANK RADAR AB, SWEDEN.