

CERTIFICATE OF COMPLIANCE

Certificate Number 20130719-E125326
Report Reference E125326-20021106
Issue Date 2013-JULY-19

Issued to: TOPWORX INC
3300 FERN VALLEY RD
LOUISVILLE KY 40213

**This is to certify that
representative samples of**

TELEMETERING EQUIPMENT FOR USE IN HAZARDOUS
LOCATIONS


See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: See Addendum Page for Standards

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130719-E125326
Report Reference E125326-20021106
Issue Date 2013-JULY-19

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Discrete Valve Controller, Model DXS/DXP/DXR –FF followed by 0, followed by G, R, F, Y, T, 4, B1, B3, B5, B7 or B9, followed by S, N, 1 or 2, followed by E, 4, M, 5, 8, 6, 1, 9, 7, 3, A or B, followed by S, followed by Blank, P, R, or U, followed by Blank, A, S, 6, B or R, followed by any number or letter, followed by any number or letter. Intrinsically Safe for use in Class I, Division 1, Groups A, B, C and D Hazardous Locations when connected in accordance with Control Drawing CERT-ES-03467-1.

Discrete Valve Controller, Model DXS/DXP/DXR –FF, FL or FP followed by 2, followed by G, R, F, Y, T, 4, B1, B3, B5, B7 or B9, followed by S, N, 1 or 2, followed by E, 4, M, 5, 8, 6, 1, 9, 7, 3, A or B, followed by S, followed by Blank, P, R, or U, followed by Blank, A, S, 6, B or R, followed by any number or letter, followed by any number or letter. Non-incendive for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations when connected in accordance with Control Drawing CERT-ES-03468-1.

Discrete Valve Controller, Model DXS/DXP-FF, FL or FP followed by 1, followed by G, R, F, Y, T, 4, B1, B3, B5, B7 or B9, followed by S, N, 1 or 2, followed by E, 4, M, 5, 8, 6, 1, 9, or 7, followed by S, E, B, or V, followed by Blank, P, R, or U, followed by Blank, A, S, 6, B or R, followed by any number or letter, followed by any number or letter. Explosion-Proof for use in Class I, Division 1, Groups C and D Hazardous Locations.


STANDARDS:

ISA 12.12.01 - Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations.

UL 1203 - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations.

CAN/CSA C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment For Use In Class I, Division 2 Hazardous Locations.

CAN/CSA C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

