CERTIFICATE OF COMPLIANCE

 Certificate Number
 20160908-E125326

 Report Reference
 E125326-20120821

 Issue Date
 2016-SEPTEMBER-08

Issued to: Topworx Inc

3300 Fern Valley Rd Louisville KY 40213-3528

This is to certify that representative samples of

TELEMETERING EQUIPMENT FOR USE IN HAZARDOUS

LOCATIONS

SEE ADDENDUM PAGE FOR MODELS

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 913 Standard for Intrinsically Safe Apparatus and

Associated Apparatus for Use in Class I, II, and III, Division

1, Hazardous (Classified) Locations

CAN/CSA C22.2 No. 157-92 Standard for Intrinsically Safe

and Non-incendive Equipment for Use in Hazardous

Locations

Additional Information: See the UL Online Certifications Directory at

www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC





CERTIFICATE OF COMPLIANCE

 Certificate Number
 20160908-E125326

 Report Reference
 E125326-20120821

 Issue Date
 2016-SEPTEMBER-08

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models/Product:

USL, CNL - Class I, Groups A, B, C and D; Class II, Groups E, F and G Hazardous Locations. Valvetop Monitors/Controllers, Model TV followed by F, L, or H, followed by K, M, P, R, T, E, N, 4, 5, or 0, followed by 2, 4, S or X, followed by 0, followed by up to thirteen alphanumeric characters. Intrinsically safe when installed in accordance with control drawing ES-03039-1, ES-03040-1, ES-03041-1, ES-03042-1, ES-03043-1, ES-03091-1, ES-03837-1, ES-03838-1, ES-03839-1, ES-05745-1 or ES-03846-1.

USL, CNL - Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G Hazardous Locations.

Valvetop Monitors/Controllers, Model TV followed by F, L, or H, followed by P, R, E, N, 4, or 5, followed by 2 or 4, followed by 2, followed by up to thirteen alphanumeric characters. Suitable for use in Division 2 locations when installed in accordance with control drawing ES-03039-1, ES-03040-1, ES-03041-1, ES-03042-1, ES-03043-1, or ES-03091-1.

Valvetop Monitors/Controllers, Model TV followed by F, L, or H, followed by A, followed by M, S, or K, followed by 2, followed by up to thirteen alphanumeric characters.

Valvetop Monitors/Controllers, Model TV followed by F, L, or H, followed by P, followed by M, B, or K, followed by 2, followed by up to thirteen alphanumeric characters

Valvetop Monitors/Controllers, Model TV followed by F, L, or H, followed by D, followed by M, N, or K, followed by 2, followed by up to thirteen alphanumeric characters

ValveTop Monitors/Controllers, Model TV F/L/H; followed by R, P + one alphanumeric character; followed by 2; followed by one alphanumeric character; followed by one alphanumeric character; followed by P, M, E or 1; followed by M; followed by Blank, 0, 1 or 2; followed by Blank, 0, A or 6; followed by Blank, 0, 1 or 8; followed by Blank, 0, 1 or 2; followed by 1 to 5 alphanumeric characters. Suitable for use in Division 2 locations when installed in accordance with control drawing ES-03039-1, ES-03040-1, ES-03041-1, ES-03042-1, ES-03043-1, or ES-03091-1.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

