



# CB TEST CERTIFICATE

Ref. Certificate No.

NL-10695/M1

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	KEMA Quality B.V.		
Product:	Valve Actuator Controller FieldQ		
Applicant:	Emerson Process Management Valve Automation Div., EL-O-Matic B.V.	Asveldweg 11, 7556 AE Hengelo	The Netherlands
Manufacturer:	Emerson Process Management Valve Automation Div., EL-O-Matic B.V.	Asveldweg 11, 7556 AE Hengelo	The Netherlands
Factory:	Emerson Process Management Valve Automation Div., EL-O-Matic B.V.	Asveldweg 11, 7556 AE Hengelo	The Netherlands
Rating and principal characteristics:	QC01: 24 Vdc, 0,1 A, 2,5 W; QC02: 85-254 V, 50/60 Hz, 2,85 W QC03, QC04: 30 Vdc, 300 mA, 1,2 W QC30: 24-31 Vdc, 6 V, 3 W QC34: 9-30 Vdc, 22 mA		
Trade mark (if any):	Emerson		
Model/Type reference:	QC01, QC02, QC03, QC04, QC30 and QC34		
Additional information:	This certificate replaces CB NL-10695 dated 2006-05-29 due to adding low voltage models QC01, QC03, QC04, QC30 and QC34		
Sample of product tested to be in conformity with IEC:	61010-1(ed.2)	National differences: CA; US	
Test Report Ref. No:	2108214.50-QUA/PEP		

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.  
 Utrechtseweg 310  
 P.O. Box 5185  
 6802 ED Arnhem  
 The Netherlands



Signed by: A.G.H. Bergervoet

Date of issue: 2008-04-23