

# CERTIFICATE

## ELECTROMAGNETIC COMPATIBILITY

Applicant : **El-O-Matic B.V.**  
Contact person : **Mr. S. Van den Oever**  
Address : **Havenlaan 2**  
Postal code, Place : **5433 NL Cuyk**  
Country : **The Netherlands**

Electrical apparatus : **Electric Valve Actuator motor Unit**  
Trademark : **El-O-Matic**  
Type designation : **Actuator motor 110/1/50**  
**120/1/60**  
**220/1/50**

Environment : **Residential, commercial and industrial**

### Standards

**EN 50082-2:1995** Generic immunity standard, from which:  
**EN 61000-4-5** Surge transient immunity  
**EN 61000-4-11** Voltage dips, interruptions and variations immunity


Remark: **Unit is mounted in actuator types ELS18 - EL2500**

Other standards are found not applicable for this apparatus

The undersigned declares that the tested specimen of the described electrical apparatus meets the essential requirements of the **EMC Directive 89/336/EEC**. This Certificate is granted on account of tests made in the laboratory of **KEMA Nederland B.V.**. This Certificate does not include an assessment of the manufacturer's production.

KEMA Registered Quality Nederland B.V.  
(Competent Body EMC)  
Arnhem, April 10, 1996

R. Venhuizen



Certificate No. **47691-KRQ/ECM 96-4372**

\*Publication or reproduction of this document in total is allowed.