

Type Approval Certificate Extension

This is to certify that Certificate No. 96/60075(E6) for the undernoted products is extended and renumbered as shown.

This certificate is issued to:

PRODUCER Emerson Process Management- Valve Automation

PLACE OF 19200 NW Freeway

PRODUCTION Houston,

Texas – 77065

USA

ALTERNATE Emerson Process Management Valve Automation (Tianjin) Co., Ltd

PLACE OF PRODCUTION No 15, Xingwang Road, Wuqing Development Area,

Tianjin 301700

People's Republic of China

Emerson Process Management Hungary Kft.-Valve Automation Berényi u. 72-100 (Videoton Industrial Park, building number:230)

Székesfehérvár 8000 HUNGARY

DESCRIPTION Quarter turn, scotch yoke, pneumatic or hydraulic actuators, flanged and

external tie bar, spring return or double acting

TYPES G01, G2, G3, G4, G5, G7, G8, G10 and G13 series

SPECIFIED STANDARD Department of Energy Statutory Instruments

No. 978:1989 No. 825:1996

Certificate No. 96/60075(E7)

Issue Date 29 Jan 2016

Expiry Date 5 Feb 2018

Sheet 1 of 3 Gopal Nair

1330 Enclave Parkway

Suite 200

Houston , Texas 77077, IUSA

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



	Pneumatic	Hydraulic
Operating pressure (psi)	40 to 200	500 to 5000

Maximum output torque (lb.in)

Double acting	Spring return
40,500	40,500
60,000	59,300
105,000	78,300
210,000	161,300
480,000	386,000
930,000	743,600
1,500,000	1,146,400
3,000,000	2,433,000
6,000,000	4,918,000
	40,500 60,000 105,000 210,000 480,000 930,000 1,500,000 3,000,000

Temperature (°C) -40 to 177

OTHER CONDITIONS

- 1. This type approval may contribute to the requirement of a verification scheme established by a Duty Holder.
- 2. Below minus 20 °C, materials of pressure retaining components and torque transmitting components are to be impact tested.
- 3. Seal compound is to be suitable for the working temperature, refer to manufacturer.
- 4 For applications on ESD valves the following are the limitations: -
 - (i) The actuators are to be fire proofed to the same rating of the valves and are to be protected against explosion or impact.
 - (ii) The actuators are to be spring return self-closing type.
 - (iii) Suitable local controls are to be provided at the installation to release the hydraulic/pneumatic supply inlet for local closing of the spring return actuators.
 - (iv) The manual/hydraulic over rides are not to be provided.
 - (v) The evaluation of the leakage rate of the valve is not part of the actuator approval and is to be verified by the owner/operator.

Certificate No. 96/60075(E7)

Issue Date 29 Jan 2016

Expiry Date 5 Feb 2018

Sheet 2 of 3 Gopal Nair

1330 Enclave Parkway Suite 200

Houston, Texas 77077, IUSA



"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register of any modification or changes to the equipment in order to obtain a valid certificate."

The Design Appraisal Document No. 96/60075(E7) and its supplementary Type Approval Terms and Conditions form part of this Certificate.

All other details remain as the previous Certificate No. 96/60075(E6) to which this extension should be attached.

Certificate No. 96/60075(E7)

Issue Date 29 Jan 2016

Expiry Date 5 Feb 2018

Sheet 3 of 3

1330 Enclave Parkway Suite 200 Houston , Texas 77077, IUSA



Gopal Nair