

EC Declaration of Conformity
Emerson Process Management Valve Actuation, LLC

Emerson Process Management Valve Actuation, LLC declares under our sole responsibility that the product(s) listed below conform with the relevant provisions of directive 94/9/EC of 23 March 1994.

Products: TEC 2000 Valve Actuator, ECP 2000 Valve Actuator, and RDM Remote Display Module

Notified Body: SIRA Certification Service (0518)
Rake Lane, Eccleston, Chester, CH4 9JN, England

Conformity has been demonstrated with reference to the following documentation:

EC type-examination certification Sira 03ATEX1510X, Issue 5 (May 2, 2013)

Compliance with Essential Health & Safety Requirements has been assessed by reference to the following standards:

EN 60079-0:2009
EN 60079-1:2007
EN 60079-31:2009

Actuators conform to the requirements of the European Economic Community EMC Directive 2004/108/EC.


Actuators conform to the requirements of the European Economic Community Low Voltage Directive 2006/95/EC.

Gap analysis was conducted between EN 60079-0:2009 and EN 60079-0:2012. No impact was found to current design with the updated standard.

The object of the declaration described above is in conformity with the relevant Union harmonization legislation: Directive 94/9/EC (until April 19th, 2016) and Directive 2014/34/EU (from April 20th, 2016).



Raul R. Garcia, Electric Actuator Engineering Manager



March 22, 2016

Head Office & Factory

Emerson Process Management Valve Actuation, LLC
13840 Pike Road, Missouri City, TX 77489 USA

Eastern Hemisphere Sales

Emerson Process Management Valve Actuation, LTD
6-7 Galaxy House, New Greenham Park, Newbury, Berkshire RG 19 6HW, England