



# Certificate / Certificat

## Zertifikat / 合格証

ROS 061218 C001

*exida* hereby confirms that the:

### **3051S Pressure Transmitter**

Software Revision 7.0 and Above

### **Rosemount Inc.**

**(an Emerson Process Management company)**

### **Chanhassen, MN - USA**

Has been assessed per the relevant requirements of:

**IEC 61508 : 2010 Parts 1-7**

and meets requirements providing a level of integrity to:

**Systematic Capability: SC 3 (SIL 3 Capable)**

**Random Capability: Type B Element**

**SIL 2@HFT=0 SIL 3@HFT=1, Route 1<sub>H</sub>**

For models where SFF ≥ 90%

**SIL 2@HFT=0 SIL 3@HFT=1, Route 2<sub>H</sub>**

**PFD<sub>AVG</sub> and Architecture Constraints**

**must be verified for each application**

Safety Function:

The Rosemount 3051S Pressure Transmitter will measure Pressure/Level/Flow within the stated safety accuracy.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



*Michael Medoff*  
Evaluating Assessor

*William M. Goff*  
Certifying Assessor

The manufacturer may use the mark:



Valid until September 5, 2017.

Revision 1.8 September 5, 2014



ANSI Accredited Program  
PRODUCT CERTIFICATION  
#1004

# Certificate / Certificat / Zertifikat / 合格証

## ROS 061218 C001

**Systematic Capability: SC 3 (SIL 3 Capable)**

**Random Capability: Type B Element  
SIL 2@HFT=0 SIL 3@HFT=1, Route 1<sub>H</sub>**

**For models where SFF ≥ 90%**

**SIL 2@HFT=0 SIL 3@HFT=1, Route 2<sub>H</sub>**

**PFDAVG and Architecture Constraints must be verified for each application**

### Systematic Capability:

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

### Random Capability:

The SIL limit imposed by the Architectural Constraints for each element.

### IEC 61508 Failure Rates in FIT<sup>1</sup>

Route 1<sub>H</sub> Table

Device	$\lambda_{SD}$	$\lambda_{SU}$	$\lambda_{DD}$	$\lambda_{DU}$	SFF
3051S 4-20mA HART Pressure Transmitter: Coplanar Differential & Coplanar Gage	0	82	274	40	90%
3051S 4-20mA HART Pressure Transmitter: Coplanar Absolute, In-line Gage & In-line Absolute	0	80	260	37	90%

Route 2<sub>H</sub> Table<sup>2</sup>

Device	$\lambda_{SD}$	$\lambda_{SU}$	$\lambda_{DD}$	$\lambda_{DU}$
3051S 4-20mA HART Pressure Transmitter: Coplanar Differential & Coplanar Gage	0	82	274	40
3051S 4-20mA HART Pressure Transmitter: Coplanar Absolute, In-line Gage & In-line Absolute	0	80	260	37
3051S Flowmeter based on 1195, 405, or 485 Primaries				
3051S 4-20mA HART Flowmeter Series <sup>3</sup>	0	90	274	51
3051S Level Transmitter: (w/o additional Seal)				
3051S 4-20mA HART Pressure Transmitter: Coplanar Differential & Coplanar Gage	0	82	274	74
3051S Transmitter with Remote Seals <sup>4</sup>				

### SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFDAVG considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of this certification:

Assessment Report: ROS 13/01-010 R001 V2 R1

Safety Manual: 00809-0100-4007

<sup>1</sup>FIT = 1 failure / 10<sup>9</sup> hours

<sup>2</sup>SFF not required for devices certified using Route 2<sub>H</sub> data. For information detailing the Route 2<sub>H</sub> approach as defined by IEC 61508-2, see Technical Document entitled "Route 2<sub>H</sub> SIL Verification for Rosemount Type B Transmitters with Type A Components".

<sup>3</sup>Refer to ROS 13/04-008 R001 V1R0 for the Flowmeter FMEDA report for models that are excluded.

<sup>4</sup>Refer to the Remote Seal (ROS 1105075 R001 V1R3) FMEDA report for the additional failure rates to use when using with attached Remote Seals, or use exSILentia.



64 N Main St  
Sellersville, PA 18960