

## CB TEST CERTIFICATE

## CERTIFICAT D'ESSAI OC

## Product

## Produit

The USB Fieldbus Interface enables two-way communication between a computer and fieldbus devices. Its primary function is to allow the setup, configuration, monitoring, and troubleshooting of fieldbus devices and segments through a computer.

## Name and address of the Applicant

## Nom et adresse du demandeur

Asset Optimization Business Unit of Fisher Rosemount Systems Inc  
12001 Technology Drive  
Eden Prairie, MN 55344  
United States of America

## Name and address of the manufacturer

## Nom et adresse du fabricant

CSI  
835 Innovation Drive Knoxville, TN 37932  
United States of America

## Name and address of the factory

## Nom et adresse de l'usine

CSI  
835 Innovation Drive Knoxville, TN 37932  
United States of America

## Rating and principal characteristics

## Valeurs nominales et caractéristiques principales

5 Vdc, 500 mA, powered via USB connected to a 60950 approved computer

## Trademark (if any)

## Marque de fabrique (si elle existe)

Emerson

## Type of manufacturer's Testing Laboratories used

## Type de programme de laboratoire d'essais constructeur

## Model / Type Ref.

## Réf. de type

USB Fieldbus Interface B07060

## Additional information (if necessary may also be reported on page 2)

## Les informations complémentaires (si nécessaire, peuvent être indiquées sur la 2ème page)

M1: Changed manufacturer from Jabil, Inc. to CSI; Corrected rating from 200mA to 500mA. Added new PCB Rev. 5 in the components list. A1: Changed Applicant name from Emerson Process Management to Asset Optimization Business Unit of Fisher Rosemount Systems Inc and Manufacturer from Emerson Process Management to Jabil, Inc. Original certificate dated October 12, 2011.

## A sample of product was tested and found to be in conformity with IEC

## Un échantillon de ce produit a été essayé et été considéré conforme à la CEI

60950-1(ed.2);am1

## National differences / Comments

## Les différences nationales / Commentaires

CA, CH, DE, DK, ES, FI, GB, IE, NO, SE, US

## As shown in the test report Ref. No. which forms part of this certificate

## Comme indiqué dans le rapport d'essais numéro de référence qui constitue partie de ce certificat

100487205MIN-001

This CB Test Certificate is issued by the National Certification Body:

Intertek Testing Services, N.A.  
165 Main Street, Cortland, NY 13045, USA

Ce Certificat d'essai OC est établi par l'Organisme National de Certification

