



Certificate of Compliance

Certificate: 1248697 (LR 83777-17)

Master Contract: 179806

Project: 1248697

Date Issued: May 16, 2002

Issued To: FISHER SERVICE CO.
1612 S. 17th Ave.
Marshalltown, IA 50158
USA

Attention: Mr. Dennis Sickels

*The products listed below are eligible to bear the CSA Mark shown
NOTE: The "NRTL/C" indicator may appear adjacent to the CSA Mark.*



Issued by:


L. Ballantyne

Authorized by:


Nick Alfano
Operations Manager

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations - CERTIFIED TO U.S. STANDARDS

Class I, Div 2, Groups A, B, C and D:

- ROC306V-AC, Controller, rated 115V ac, 47-63Hz, Temp Code T4A, Type 4X.
- ROC306V-DC, Controller, rated 30V dc, Type 4X.
- Power Supply, Model W38133X0012, rated 115/230V ac, 47-63Hz, output 12V dc, 1.0 A, Temp Code T4A. For mounting in a suitable enclosure where final assembly is subject to acceptance of CSA or the inspection authority having jurisdiction.



CSA INTERNATIONAL

Certification: 1248697 (LR 83777-17)

Master Contract: 179806

Project: 1248697

Date: May 16, 2002

APPLICABLE REQUIREMENTS

- CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures
- CSA Std C22.2 No. 142-M1987 - Process Control Equipment
- CSA Std C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
- UL Std No. 1092 - Process Control Equipment
- UL Std No. 508 - Industrial Control Equipment
- UL Std No. 1604 - Electrical Equipment for Use in Class I and II, Division 2; Class III Hazardous (Classified) Locations

MARKINGS

- Company name;
- Model number;
- Serial number;
- Electrical rating;
- Hazardous Location designation;
- Special purpose enclosure designation, "Type 4X";
- CSA Monogram with "NRTL/C" indicator;
- Caution re Substitution of Components;
- Caution re Explosion Hazard;
- Reference to Installation Drawing A6040;