

Certificate

A031-0102/11, V1.0

TÜV NORD Systems GmbH & Co. KG hereby certifies to

Emerson Process Management

1100 W. Louis Henna Blvd., Bldg. 1
Round Rock, TX 78681 – 7430, USA

that the


DeltaV SIS™ with Electronic Marshalling

is capable for safety related applications up to SIL 3 and meets the requirements listed in the following standards.

- IEC 61508:2010;
ed. 2; part 1-7;
capable up to SIL3
- IEC 61511:2004
- EN 54-2:1997/A1:2006
- EN 298:2003
- EN 50156-1:2004
- NFPA 72:2007
- NFPA 85:2007
- NFPA 86:2011
- NFPA 87:2011

The certification is based on the report A031-0102/11TB and the list of certified components in the valid versions. This certificate entitles the holder to use the pictured Safety Approved mark.

Expiry date: 2018-04-29
Reference No.: 8109921724


Gerhard M. Rieger
Branch Manager

Augsburg, 2013-04-30

