

Certificate of Conformity

issued by Curtis-Straus

Company: Bristol Babcock
Product Tested: RTU 3340
Testing Date: June 16, 1998
Report No.: 980446

A sample of the product has been found to comply with the following standards:

EMC Immunity:

- ENV 50140 Radio-frequency electromagnetic field, Amplitude modulated
- ENV 50204 Radio-frequency electromagnetic field, Pulse modulated

Furthermore, the manufacturer may declare that the product is in conformity with the above standards.

Attested to by the hands and seals:

For Curtis-Straus

Derech Plante 7/6/98
Test Engineer Date

For the Manufacturer or Importer

James R. [Signature] 7/19/98
Date

[Signature] 6.JUL.98
Quality Manager Date