

CERTIFICATE

ELECTROMAGNETIC COMPATIBILITY

Applicant : **El-O-Matic B.V.**
Contact person : **Mr. S. van den Oever**
Address : **Havenlaan 2**
Postal code, Place : **5433 NL Cuyk**
Country : **The Netherlands**

Electrical apparatus : **Electric Valve Actuator motor Unit**
Trademark : **El-O-Matic**
Type designation : **Actuator motor 24V-DC
24V-AC**

Environment : **Residential, commercial and industrial**

Standards

EN 50082-2:1995 Generic immunity standard, from which:


EN 61000-4-5 Surge transient immunity
EN 61000-4-11 Voltage dips, interruptions and variations immunity

Remark: **Motor is mounted in actuator types ELS18 - EL800**

Other standards are found not applicable for this apparatus

The undersigned declares that the tested specimen of the described electrical apparatus meets the essential requirements of the **EMC Directive 89/336/EEC**. This Certificate is granted on account of tests made in the laboratory of **KEMA Nederland B.V.** This Certificate does not include an assessment of the manufacturer's production.

KEMA Registered Quality Nederland B.V.
(Competent Body EMC)
Arnhem, April 10, 1996

R. Venhuizen 

Certificate No. **47691-KRQ/ECM 96-4374**

Publication or reproduction of this document in total is allowed.