

EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management
Fisher Controls International LLC
205 South Center Street
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following products considered as,

**Non-electrical instrumentation
(pneumatic – positioners, controllers, transmitters, volume boosters, and switches)**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.




Danny Nelson
Vice President – Instrument Business Unit

14-March-2016

Date

European Contact

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

ATEX Directive – 2014/34/EU (Applicable only if this mark  appears on the product)

Non-electrical instrumentation – **Group II Category 2 GD**

Equipment is marked as follows:



Standards used: EN13463-1:2009, EN1127-1:2011

The Technical Documentation has been submitted and retained by the Notified Body:

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom

PED Directive – 2014/68/EU

Declaration of SEP

Models: Non-electrical instrumentation (pneumatic – positioners, controllers, transmitters, volume boosters, and switches)

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.

EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management
Fisher Controls International LLC
205 South Center Street
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product;

**Digital Level Controller
DLC3010**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



Michael McCarty
Vice President-Instrument Business Unit
& Advanced Research

20-July-2017

Date

European Contact

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

EMC Directive – 2014/30/EU

Models: All

EN 61326-1:2013

EN61326-2-3:2006

RoHS Directive – 2011/65/EU

Declaration of Exclusion

Models: All

The above equipment is excluded from the scope of this directive per Article 2, Paragraph 4, part C. Therefore the equipment cannot bear the CE mark related to RoHS compliance. However, the equipment may bear the CE mark to indicate compliance with other applicable EU directives.

ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)

Certificate – **LCIE01ATEX6053X – Group II Category 1 GD** – Intrinsically Safe & Dust

DLC3010

Ex ia IIC T5(Ta ≤ 80°C) Ga

Ex ia IIIC T83°C(Ta ≤ 80°C) Da, IP66

Standards used: EN60079-0:2012 + A11:2013 and EN60079-11:2012

Certificate – **LCIE01ATEX6054X – Group II Category 2 GD** – Flameproof & Dust

DLC3010

Ex d IIC T5(Ta ≤ 80°C) Gb

Ex tb IIIC T83°C(Ta ≤ 80°C) Db, IP66

Standards used: EN60079-0:2012 + A11:2013, EN60079-1:2007 and EN60079-31:2009

Certificate – **LCIE02ATEX6055X – Group II Category 3 GD** – Type n & Dust

DLC3010

Ex nA IIC T5(Ta ≤ 80°C) Gc

Ex tc IIIC T83°C(Ta ≤ 80°C) Dc, IP66

Standards used: EN60079-0:2012 + A11: 2013, EN60079-15:2010 and EN60079-31:2009

ATEX Notified Body for EC-Type Examination Certificate(s)

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081

33 Avenue du General Leclerc BP 8

F92233 Fontenay-aux-Roses cedex

France

ATEX Notified Body for Quality Assurance

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom

EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management
Fisher Controls International LLC
205 South Center Street
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Digital Valve Controllers
DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S
DVC6010F, DVC6020F, DVC6030F, DVC6010FS, DVC6020FS, DVC6030FS
DVC6005, DVC6005F, DVC6015, DVC6025, DVC6035
DVC6200, DVC6200S, DVC6200F, DVC6200FS, DVC6200P, DVC6200PS
DVC6205, DVC6205F, DVC6205P, DVC6215**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



Michael McCarty
Vice President – Instrument Business Unit
& Advanced Research

20-July-2017

Date

European Contact

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

EMC Directive – 2014/30/EU

Models: All
EN 61326-1:2013

RoHS Directive – 2011/65/EU

Declaration of Exclusion

Models: All

The above equipment is excluded from the scope of this directive per Article 2, Paragraph 4, part C. Therefore the equipment cannot bear the CE mark related to RoHS compliance. However, the equipment may bear the CE mark to indicate compliance with other applicable EU directives.

PED Directive – 2014/68/EU

Declaration of SEP

Models: DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S, DVC6005, DVC6005F, DVC6200, DVC6200S, DVC6200F, DVC6200FS, DVC6200P, DVC6200PS, DVC6205, DVC6205F, DVC6205P

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.

ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)

Certificate – **LCIE02ATEX6002X – Group II Category 1 GD** – Intrinsically Safe & Dust

--WHEN INSTALLED PER DWG GE60771--

HART – HW1

DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S, DVC6005, DVC6200, DVC6200S

Ex ia IIC or IIB T5(Ta ≤ 80°C), T6(Ta ≤ 75°C) Ga

DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S

Ex ia IIIC T92°C(Ta ≤ 80°C) / T85°C(Ta ≤ 73°C) Da

DVC6005, DVC6200, DVC6200S

Ex ia IIIC T89°C(Ta ≤ 80°C) / T85°C(Ta ≤ 76°C) Da

HART – HW2 without I/O Package

DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S, DVC6005, DVC6200, DVC6200S, DVC6205

Ex ia IIC T5(Ta ≤ 80°C), T6(Ta ≤ 74°C) Ga

DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S

Ex ia IIIC T101°C(Ta ≤ 80°C) / T85°C(Ta ≤ 64°C) Da

DVC6005, DVC6200, DVC6200S, DVC6205

Ex ia IIIC T91°C(Ta ≤ 80°C) / T85°C(Ta ≤ 74°C) Da

HART – HW2 with I/O Package

DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S, DVC6005, DVC6200, DVC6200S, DVC6205

Ex ia IIC or IIB T5(Ta ≤ 80°C), T6(Ta ≤ 61°C) Ga

Ex ia IIIC T104°C(Ta ≤ 80°C) / T85°C(Ta ≤ 61°C) Da

FIELD BUS & PROFIBUS

DVC6010F, DVC6020F, DVC6030F, DVC6010FS, DVC6020FS, DVC6030FS, DVC6005F, DVC6200F, DVC6200FS, DVC6200P, DVC6200PS, DVC6205F, DVC6205P

Ex ia IIC T4(Ta ≤ 80°C), T5(Ta ≤ 77°C), T6(Ta ≤ 62°C) Ga

Ex ia IIIC T103°C(Ta ≤ 80°C) / T100°C(Ta ≤ 77°C) / T85°C(Ta ≤ 62°C) Da

FEEDBACK ASSEMBLY

DVC6015, DVC6025, DVC6035

Ex ia IIC T4(Ta ≤ 125°C), T5(Ta ≤ 95°C), T6(Ta ≤ 80°C) Ga

Ex ia IIIC T146°C(Ta ≤ 125°C) / T135°C(Ta ≤ 114°C) / T100°C(Ta ≤ 79°C) / T85°C(Ta ≤ 64°C) Da

DVC6215 – Excludes Dust

Ex ia IIC T4(Ta ≤ 125°C), T5(Ta ≤ 95°C), T6(Ta ≤ 80°C) Ga

Standards used: EN60079-0:2012 + A11:2013, EN60079-11:2012

Certificate – **LCIE02ATEX6001X – Group II Category 2 G** – Flameproof

DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S, DVC6010F, DVC6020F, DVC6030F,
DVC6010FS, DVC6020FS, DVC6030FS, DVC6005, DVC6005F, DVC6200, DVC6200F, DVC6200P, DVC6200S,
DVC6200FS, DVC6200PS, DVC6205, DVC6205F, DVC6205P

Ex d IIC T5(Ta ≤ 85°C), T6(Ta ≤ 80°C) Gb

DVC6015, DVC6025, DVC6035, DVC6215

Ex d IIC T4(Ta ≤ 125°C), T5(Ta ≤ 95°C), T6(Ta ≤ 80°C) Gb

Standards used: EN60079-0:2012 + A11:2013, EN60079-1:2007

Certificate – **LCIE02ATEX6003X – Group II Category 3 G** – Type n

DVC6010, DVC6020, DVC6030, DVC6010S, DVC6020S, DVC6030S, DVC6010F, DVC6020F, DVC6030F,
DVC6010FS, DVC6020FS, DVC6030FS, DVC6005, DVC6005F, DVC6200, DVC6200F, DVC6200P, DVC6200S,
DVC6200FS, DVC6200PS, DVC6205, DVC6205F, DVC6205P

Ex nC IIC T5(Ta ≤ 80°C), T6(Ta ≤ 75°C) Gc

DVC6015, DVC6025, DVC6035, DVC6215

Ex nA IIC T4(Ta ≤ 125°C), T5(Ta ≤ 95°C), T6(Ta ≤ 80°C) Gc

Standards used: EN60079-0:2012 + A11:2013, EN60079-15:2010

ATEX Notified Body for EC-Type Examination Certificate(s)

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081

33 Avenue du General Leclerc BP 8

F92233 Fontenay-aux-Roses cedex

France

ATEX Notified Body for Quality Assurance

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom

EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management
Fisher Controls International LLC
205 South Center Street
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Electro-pneumatic Converters
3622, 3722 582i
Electro-pneumatic Transducer
646
Electro-pneumatic Positioner
3661**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



Michael McCarty
Vice President – Instrument Business Unit
& Advanced Research

20-July-2017

Date

European Contact

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

EMC Directive – 2014/30/EU

Models: All
EN 61326-1:2013

RoHS Directive – 2011/65/EU

Declaration of Exclusion

Models: All

The above equipment is excluded from the scope of this directive per Article 2, Paragraph 4, part C. Therefore the equipment cannot bear the CE mark related to RoHS compliance. However, the equipment may bear the CE mark to indicate compliance with other applicable EU directives.

PED Directive – 2014/68/EU

Declaration of SEP

Models: 3622, 3722, 582i, 646, 3661

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.

ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)

Certificate – **LCIE03ATEX6001X – Group II Category 1 GD – Intrinsically Safe & Dust**
3622, 3722

Ex ia IIC T4(Ta ≤ 82°C), T5(Ta ≤ 62°C), T6(Ta ≤ 47°C) Ga

Ex ia IIIC T120°C(Ta ≤ 82°C) / T100°C(Ta ≤ 62°C) / T85°C(Ta ≤ 47°C) Da, IP64

582i

Ex ia IIC T4(Ta ≤ 71°C), T5(Ta ≤ 62°C), T6(Ta ≤ 47°C) Ga

Ex ia IIIC T109°C(Ta ≤ 71°C) / T100°C(Ta ≤ 62°C) / T85°C(Ta ≤ 47°C) Da, IP64

646

Ex ia IIC T4(Ta ≤ 71°C), T5(Ta ≤ 40°C) Ga

Ex ia IIIC T155°C(Ta ≤ 71°C) / T124°C(Ta ≤ 40°C) Da, IP64

3661 – Excludes Dust

Ex ia IIC T4(Ta ≤ 82°C), T5(Ta ≤ 62°C), T6(Ta ≤ 47°C) Ga

Standards used: EN60079-0:2012, EN60079-11:2012

Certificate – **KEMA04ATEX2137X – Group II Category 2 GD – Flameproof & Dust**
582i, 646

Ex d IIC T6(Ta ≤ 71°C) Gb

Ex tb IIIC T74°C(Ta ≤ 71°C) Db

3622, 3722

Ex d IIC T5(Ta ≤ 82°C) Gb

Ex tb IIIC T82°C(Ta ≤ 79°C) Db

Standards used: EN60079-0:2012, EN60079-1:2007, EN60079-31:2009

Certificate – **LCIE03ATEX6002X – Group II Category 3 GD – Type n & Dust**
3622, 3722

Ex nA IIC T6(Ta ≤ 82°C) Gc

Ex tc IIIC T85°C(Ta ≤ 82°C) Dc, IP64

582i

Ex nA IIC T6(Ta ≤ 71°C) Gc

Ex tc IIIC T85°C(Ta ≤ 71°C) Dc, IP64

646

Ex nA IIC T6($T_a \leq 71^\circ\text{C}$) Gc

Ex tc IIIC T85°C($T_a \leq 71^\circ\text{C}$) Dc, IP64

3661 – Excludes Dust

Ex nA IIC T6($T_a \leq 82^\circ\text{C}$) Gc

Standards used: EN60079-0:2012, EN60079-15:2010, EN60079-31:2009

ATEX Notified Body for EC-Type Examination Certificate(s)

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081

33 Avenue du General Leclerc BP 8

F92233 Fontenay-aux-Roses cedex

France

DEKRA Certification B.V. – Notified Body Number: 0344

Utrechtseweg 310

6812 AR Arnhem

P.O. Box 5185

6802 ED Arnhem

The Netherlands

ATEX Notified Body for Quality Assurance

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom

EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management
Fisher Controls International LLC
205 South Center Street
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Position Transmitter
4210, 4211, 4221, 4215, 4220, 4221, 4222**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



Michael McCarty
Vice President – Instrument Business Unit
& Advanced Research

20-July-2017

Date

European Contact

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

EMC Directive – 2014/30/EU

Models: All
EN 61326-1:2013

RoHS Directive – 2011/65/EU

Declaration of Exclusion

Models: All

The above equipment is excluded from the scope of this directive per Article 2, Paragraph 4, part C. Therefore the equipment cannot bear the CE mark related to RoHS compliance. However, the equipment may bear the CE mark to indicate compliance with other applicable EU directives.

ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)

Certificate – **LCIE03ATEX6220X – Group II Category 1 GD** – Intrinsically Safe & Dust

4211, 4221

Ex ia IIC T4(Ta ≤ 71°C), T5(Ta ≤ 40°C) Ga

Ex ta IIIC T81°C(Ta ≤ 71°C), T50°C(Ta ≤ 40°C) Da, IP66

Standards used: EN60079-0:2009, EN60079-11:2012, EN60079-26:2007, EN60079-31:2009

Certificate – **SIRA11ATEX1344 – Group II Category 2 GD** – Flameproof & Dust

4210, 4211, 4212, 4215, 4220, 4221, 4222

Ex d IIC T5(Ta ≤ 71°C), T6(Ta ≤ 56°C) Gb

Ex tb IIIC T72°C(-20°C ≤ Ta ≤ 56°C) Db, IP66

Standards used: EN60079-0:2009, EN60079-1:2007, EN60079-31:2009

Certificate – **LCIE03ATEX6219 – Group II Category 3 GD** – Type n & Dust

4211, 4221

Ex nA IIC T4(Ta ≤ 71°C) Gc

Ex tc IIIC T81°C(Ta ≤ 71°C) Dc, IP66

Standards used: EN60079-0:2009, EN60079-15:2010, EN60079-31:2009

ATEX Notified Body for EC-Type Examination Certificate(s)

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081

33 Avenue du General Leclerc BP 8

F92233 Fontenay-aux-Roses cedex

France

SIRA Certification Service – Notified Body Number: 0518

Rake Lane, Eccleston

Chester, CH4 9JN

United Kingdom

ATEX Notified Body for Quality Assurance

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom

EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management
Fisher Controls International LLC
205 South Center Street
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Electro-pneumatic Transducer
846**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



Michael McCarty

Vice President – Instrument Business Unit
& Advanced Research

30-Nov-2017

Date

European Contact

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

EMC Directive – 2014/30/EU

Models: All
EN 61326-1:2013

RoHS Directive – 2011/65/EU

Declaration of Exclusion

Models: All

The above equipment is excluded from the scope of this directive per Article 2, Paragraph 4, part C. Therefore the equipment cannot bear the CE mark related to RoHS compliance. However, the equipment may bear the CE mark to indicate compliance with other applicable EU directives.

PED Directive – 2014/68/EU

Declaration of SEP

Models: 846

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.

ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)

Certificate – **LCIE03ATEX6298X – Group II Category 1 GD – Intrinsically Safe & Dust**
846

Ex ia IIC T4(Ta ≤ 80°C), T5(Ta ≤ 40°C) Ga

Ex ia IIIC T90°C(Ta ≤ 80°C) / T50°C(Ta ≤ 40°C) Da, IP66

Standards used: EN60079-0:2012 + A11: 2013, EN60079-11:2012

Certificate – **Baseefa05ATEX0130X – Group II Category 2 G – Flameproof**
846

Ex d IIB T5(Ta ≤ 80°C), T6(Ta ≤ 65°C) Gb

Standards used: EN60079-0:2012 + A11:2013, EN60079-1:2014

Certificate – **LCIE03ATEX6299 – Group II Category 3 GD – Type n & Dust**
846

Ex nA IIC T5(Ta ≤ 85°C), T6(Ta ≤ 74°C) Gc

Ex tc IIIC T88°C(Ta ≤ 85°C) T₅₀₀ / T77°C(Ta ≤ 74°C) T₅₀₀ Dc, IP66

Standards used: EN60079-0:2012 + A11:2013, EN60079-15:2010, EN60079-31:2014

ATEX Notified Body for EC-Type Examination Certificate(s)

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081

33 Avenue du General Leclerc BP 8

F92233 Fontenay-aux-Roses cedex

France

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom

ATEX Notified Body for Quality Assurance

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom

EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management
Fisher Controls International LLC
205 South Center Street
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Digital Valve Controller
DVC2000**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



Michael McCarty
Vice President – Instrument Business Unit
& Advanced Research

20-July-2017

Date

European Contact

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

EMC Directive – 2014/30/EU

Models: All
EN 61326-1:2013

RoHS Directive – 2011/65/EU

Declaration of Exclusion

Models: All

The above equipment is excluded from the scope of this directive per Article 2, Paragraph 4, part C. Therefore the equipment cannot bear the CE mark related to RoHS compliance. However, the equipment may bear the CE mark to indicate compliance with other applicable EU directives.

PED Directive – 2014/68/EU

Declaration of SEP

Models: DVC2000

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.

ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)

Certificate – **LCIE05ATEX6009X – Group II Category 1 G** – Intrinsically Safe
DVC2000
Ex ia IIC T4(Ta ≤ 80°C), T5(Ta ≤ 40°C) Ga
Standards used: EN60079-0:2012 + A11: 2013, EN60079-11:2012

ATEX Notified Body for EC-Type Examination Certificate(s)

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081
33 Avenue du General Leclerc BP 8
F92233 Fontenay-aux-Roses cedex
France

ATEX Notified Body for Quality Assurance

SGS Baseefa Limited – Notified Body Number: 1180
Rockhead Business Park
Staden Lane, Buxton, Derbyshire SK17 9RZ
United Kingdom

EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management
Fisher Controls International LLC
205 South Center Street
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Electro-pneumatic Transducer
i2P-100**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



Michael McCarty
Vice President – Instrument Business Unit
& Advanced Research

20-July-2017

Date

European Contact

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

EMC Directive – 2014/30/EU

Models: All
EN 61326-1:2013

RoHS Directive – 2011/65/EU

Declaration of Exclusion

Models: All

The above equipment is excluded from the scope of this directive per Article 2, Paragraph 4, part C. Therefore the equipment cannot bear the CE mark related to RoHS compliance. However, the equipment may bear the CE mark to indicate compliance with other applicable EU directives.

PED Directive – 2014/68/EU

Declaration of SEP

Models: i2P-100

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.

ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)

Certificate – **LCIE15ATEX3008X – Group II Category 1, 2 GD** – Intrinsically Safe, Flameproof, & Dust
i2P-100

Ex ia IIC T3(Ta ≤ 85°C), T4(Ta ≤ 81°C), T5(Ta ≤ 46°C) Ga

Ex ia IIIC T95°C(Ta ≤ 85°C) Da

Ex d IIC T5(Ta ≤ 85°C), T6(Ta ≤ 75°C) Gb

Ex tb IIIC T95°C(Ta ≤ 85°C) Db, IP64

Standards used: EN60079-0:2012 + A11:2013, EN60079-1:2007, EN60079-11:2012, EN60079-31:2009

Certificate – **LCIE15ATEX1008 – Group II Category 3 GD** – Type n & Dust

i2P-100

Ex nC IIC T5(Ta ≤ 85°C), T6(Ta ≤ 75°C) Gc

Ex tc IIIC T95°C(Ta ≤ 85°C) Dc, IP64

Standards used: EN60079-0:2012 + A11:2013, EN60079-15:2010, EN60079-31:2009

ATEX Notified Body for EC-Type Examination Certificate(s)

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081

33 Avenue du General Leclerc BP 8

F92233 Fontenay-aux-Roses cedex

France

ATEX Notified Body for Quality Assurance

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom

EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management
Fisher Controls International LLC
205 South Center Street
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Local Control Panel
LCP100**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



Michael McCarty
Vice President – Instrument Business Unit
& Advanced Research

20-July-2017

Date

European Contact

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

EMC Directive – 2014/30/EU

Models: All
EN 61326-1:2013

RoHS Directive – 2011/65/EU

Declaration of Exclusion

Models: All

The above equipment is excluded from the scope of this directive per Article 2, Paragraph 4, part C. Therefore the equipment cannot bear the CE mark related to RoHS compliance. However, the equipment may bear the CE mark to indicate compliance with other applicable EU directives.

ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)

Certificate – **SIRA15ATEX2194X – Group II Category 1 G** – Intrinsically Safe
LCP100

Ex ia IIB T4(Ta ≤ 65°C) Ga
Standards used: EN60079-0:2012, EN60079-11:2012, EN60079-26:2015

Certificate – **SIRA08ATEX3335X – Group II Category 2 G** – Increased Safety, Encapsulation, Intrinsically Safe
LCP100

Ex e mb [ib] IIC T4(Ta ≤ 65°C) Gb, IP66
Standards used: EN60079-0:2012 +A11:2013, EN60079-7:2007, EN60079-11:2012, EN60079-18:2015

Certificate – **SIRA12ATEX4216X – Group II Category 3 G** – Intrinsically Safe
LCP100

Ex ic IIC T4(Ta ≤ 65°C) Gc
Standards used: EN60079-0:2012 +A11:2013, EN60079-11:2012

ATEX Notified Body for EC-Type Examination Certificate(s)

SIRA Certification Services – Notified Body Number: 0518
Rake Lane, Ecclestone
Chester CH4 9JN
United Kingdom

ATEX Notified Body for Quality Assurance

SGS Baseefa Limited – Notified Body Number: 1180
Rockhead Business Park
Staden Lane, Buxton, Derbyshire SK17 9RZ
United Kingdom

EU Declaration of Conformity

We, the manufacturer,

**Emerson Process Management
Fisher Controls International LLC
205 South Center Street
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**On/Off
Wireless Position Monitor**

TopWorx 4310

**4310 Battery Power with or without Pneumatic Output
4310 External Power with or without Pneumatic Output**

Fisher 4320

**4320 Battery Power with or without Pneumatic Output
4320 External Power with or without Pneumatic Output**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



Michael McCarty
Vice President – Instrument Business Unit
& Advanced Research

20-July-2017

Date

European Contact

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

EMC Directive – 2014/30/EU

Models: All
EN 61326-1:2013

RoHS Directive – 2011/65/EU

Declaration of Exclusion

Models: All

The above equipment is excluded from the scope of this directive per Article 2, Paragraph 4, part C. Therefore the equipment cannot bear the CE mark related to RoHS compliance. However, the equipment may bear the CE mark to indicate compliance with other applicable EU directives.

RED Directive – 2014/53/EU

All models
EN 301 489-1:1.9.2:2011, EN 301 489-17:2.2.1:2012, IEC 61010-1:2010

PED Directive – 2014/68/EU

Declaration of SEP

Models: 4310, 4320 – Battery Power with Pneumatic Output, 4310, 4320 – External Power with Pneumatic Output

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.

ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)

Certificate – **LCIE13ATEX3059X – Group II Category 1 G – Intrinsically Safe**

4310, 4320 – Battery Power without Pneumatic Output

Ex ia IIC T3(-40°C ≤ Ta ≤ 85°C), T4(-40°C ≤ Ta ≤ 75°C), T5(-40°C ≤ Ta ≤ 40°C) Ga

4310, 4320 – Battery Power with Pneumatic Output

Ex ia IIC T4(-20°C ≤ Ta ≤ 50°C), T5(-20°C ≤ Ta ≤ 46°C), T6(-20°C ≤ Ta ≤ 31°C) Ga

4310, 4320 – External Power without Pneumatic Output

Ex ia IIC T5(-40°C ≤ Ta ≤ 80°C) Ga

4310, 4320 – External Power with Pneumatic Output

Ex ia IIC T5(-20°C ≤ Ta ≤ 50°C) Ga

Standards used: EN60079-0:2012 + A11:2013, EN60079-11:2012

ATEX Notified Body for EC-Type Examination Certificate(s)

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081

33 Avenue du General Leclerc BP 8

F92233 Fontenay-aux-Roses cedex

France

ATEX Notified Body for Quality Assurance

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom

EU Declaration of Conformity

We, the manufacturer,


**Emerson Process Management
Fisher Controls International LLC
205 South Center Street
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product;

**Digital Level Controller
DLC3020F**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



Michael McCarty
Vice President-Instrument Business Unit
& Advanced Research

20-July-2017

Date

European Contact

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

EMC Directive – 2014/30/EU

Models: All

EN 61326-1:2013

EN61326-2-3:2006

RoHS Directive – 2011/65/EU

Declaration of Exclusion

Models: All

The above equipment is excluded from the scope of this directive per Article 2, Paragraph 4, part C. Therefore the equipment cannot bear the CE mark related to RoHS compliance. However, the equipment may bear the CE mark to indicate compliance with other applicable EU directives.

ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)

Certificate – **LCIE10ATEX3091X – Group II Category 1 GD** – Intrinsically Safe & Dust

DLC3020F

Ex ia IIC T5(Ta ≤ 80°C), T6(Ta ≤ 73°C) Ga

Ex ia IIIC T87°C(Ta ≤ 80°C) / T80°C(Ta ≤ 73°C) Da, IP66

Standards used: EN60079-0:2012 + A11:2013, EN60079-11:2012

Certificate – **LCIE10ATEX3076 – Group II Category 2 GD** – Flameproof & Dust

DLC3020F

Ex d IIC T5(Ta ≤ 80°C), T6(Ta ≤ 73°C) Gb

Ex tb IIIC T87°C(Ta ≤ 80°C) / T80°C (Ta ≤ 73°C) Db, IP66

Standards used: EN60079-0:2012 + A11:2013, EN60079-1:2007, EN60079-31:2014

Certificate – **LCIE10ATEX1010 – Group II Category 3 GD** – Type n & Dust

DLC3020F

Ex nA IIC T5(Ta ≤ 80°C), T6(Ta ≤ 73°C) Gc

Ex tc IIIC T87°C(Ta ≤ 80°C) / T80°C(Ta ≤ 73°C) Dc, IP66

Standards used: EN60079-0:2012 + A11:2013, EN60079-15:2010, EN60079-31:2014

ATEX Notified Body for EC-Type Examination Certificate(s)

LCIE – Laboratoire Central des Industries Electriques – Notified Body Number: 0081

33 Avenue du General Leclerc BP 8

F92233 Fontenay-aux-Roses cedex

France

ATEX Notified Body for Quality Assurance

SGS Baseefa Limited – Notified Body Number: 1180

Rockhead Business Park

Staden Lane, Buxton, Derbyshire SK17 9RZ

United Kingdom

EU Declaration of Conformity

We, the manufacturer,


**Emerson Process Management
Fisher Controls International LLC
205 South Center Street
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Electric Actuator
easy-Drive**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



Michael McCarty
Vice President-Instrument Business Unit
& Advanced Research

20-July-2017

Date

European Contact

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

EMC Directive – 2014/30/EU

Models: All
EN 61326-1:2013

RoHS Directive – 2011/65/EU

Declaration of Exclusion

Models: All

The above equipment is excluded from the scope of this directive per Article 2, Paragraph 4, part C. Therefore the equipment cannot bear the CE mark related to RoHS compliance. However, the equipment may bear the CE mark to indicate compliance with other applicable EU directives.

ATEX Directive – 2014/34/EU (Applicable only if this mark appears on the product)

Certificate – **SIRA12ATEX1168X – Group II Category 2 G – Flameproof**
easy-Drive
Ex db IIA T6(Ta ≤ 70°C) Gb
Standards used: EN60079-0:2012/A11:2013, EN60079-1:2014

ATEX Notified Body for EC-Type Examination Certificate(s)

SIRA Certification Service – Notified Body Number: 0518
Unit 6, Hawarden Industrial Park,
Hawarden, CH5 3US
United Kingdom

ATEX Notified Body for Quality Assurance

SGS Baseefa Limited – Notified Body Number: 1180
Rockhead Business Park
Staden Lane, Buxton, Derbyshire SK17 9RZ
United Kingdom

EU Declaration of Conformity

We, the manufacturer,


**Emerson Process Management
Fisher Controls International LLC
205 South Center Street
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**Electro-pneumatic Transducer
546, 546NS**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



Josh Wilford
Vice President – Engineered Products

11-July-2016

Date

European Contact

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

EMC Directive – 2014/30/EU

All models

EN 61326-1:2013

PED Directive – 2014/68/EU

Declaration of SEP

Models: 546, 546NS

The above equipment was designed and manufactured in accordance with Sound Engineering Practice (SEP) and is in compliance with Article 4 paragraph 3 of the PED Directive. Therefore the equipment cannot bear the CE mark related to PED compliance. However, the equipment *may* bear the CE mark to indicate compliance with *other* applicable EU Directives.

EU Declaration of Conformity

We, the manufacturer,


**Emerson Process Management
Fisher Controls International LLC
205 South Center Street
Marshalltown, Iowa 50158 USA**

declare under our sole responsibility that the following product(s);

**HART® Filter
HF340, HF341**

to which this declaration relates, is in conformity with the provisions of the following European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community Notified Body certification, as shown in the attached schedule.



Michael McCarty
Vice President – Instrument Business Unit
& Advanced Research

17-August-2017

Date

European Contact

Emerson Process Management | Group Services SAS | Rue Paul-Baudry | B.P. 10 | 68701 Cernay Cedex France

EMC Directive – 2014/30/EU

Models: All
EN 61326-1:2013