



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

QC4abcdefg. FieldQ Actuator Control Modules.

XP/II/1/BCD/T6 * $\leq T_a \leq 60^\circ\text{C}$; XP/II/1/IIB+H₂/T6 * $\leq T_a \leq 60^\circ\text{C}$; DIP/II,III/1/EFG/T6 * $\leq T_a \leq 60^\circ\text{C}$; Type 4X/IP66

a = Control Module Type: 1, 2, 3

b = Conduit Connection: U

c = Protection Method: P5

d = Control Module Options: M, G, O, C, N, H

e = Action: S, D, F

f = Future Expansion Code: A

g = Language Code: 1

Special Conditions For Safe Use:

1. **T_{ambient} from -30°C to +60°C, except for Control Module Options O, C, N and H type which are -25°C to +60°C*

Equipment Ratings:

Explosionproof for use in Class I, Division 1, Groups B, C and D; and Class I, Zone 1, Group IIB+H₂; Dust-ignitionproof for use in Class II,III, Division 1, Groups E, F and G hazardous (classified) locations, indoors and outdoors, Type 4X/IP66.

FM Approved for:

Emerson Process Mgt - Valve Automation Division
EI-O-Matic
Asveldweg 11, 7556BR Hengelo
The Netherlands

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3615	2006
Class 3616	2011
Class 3810	2005
ANSI/NEMA 250	2003
ANSI/IEC	2004


Original Project ID: 3045972

Approval Granted: August 31, 2012

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC



Robert L Martell
Director, Electrical

August 31, 2012
Date