


CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product Produit	Valve control unit, component type
Name and address of the Applicant Nom et adresse du demandeur	Emerson Process Management Asveldweg 11, 7556 BR Hengelo The Netherlands
Name and address of the manufacturer Nom et adresse du fabricant	Emerson Machinery Equipment co. Ltd Bao Heng Technology Industry Park, North Hong Lang 2nd Road, District 68, Bao'an District, Shenzhen, 518101 China
Name and address of the factory Nom et adresse de l'usine	Emerson Machinery Equipment Co. Ltd Bao Heng Technology Industry Park, North Hong Lang 2nd Road, District 68, Bao'an District, Shenzhen, 518101 China
Rating and principal characteristics Valeurs nominales et caractéristiques principales	Signal input: QC 41xxxxxx 24 V DC, 1.8 W or 3.6 W QC 42xxxxxx 115 V AC, 3.6 W or 7.2 W QC 43xxxxxx 230 V AC, 3.6 W or 7.2 W Power dissipation depending on valve configuration. Signal output: The following configurations of switches can be used: - Potential free contact switches M-Type: 250VAC/10A(3A inductive load), 125VAC/10A(3A inductive load), 250VDC/0.25A, 125VDC/0.5A, 30VDC/0.5A - Potential free contact switches G-Type: 125VAC/1A, 30VDC/1A - 2 wire proximity switches: 20-250VAC/100mA, 10-300VDC/100mA - 2 wire NAMUR proximity switches: 8VDC/3mA - 3 wire proximity switches NPN or PNP: 10-30VDC/100mA
Trademark (if any) Marque de fabrique (si elle existe)	Emerson
Type of manufacturer's Testing Laboratories used Type de programme de laboratoire d'essais constructeur	
Model / Type Ref. Réf. de type	Field Q / QC41xxxxxx , QC42xxxxxx , QC43xxxxxx (The x is a variable that could represents a letter or a number according to the table in the section "Copy of marking plate" of the report)
Additional information (if necessary may also be reported on page 2) Les informations complémentaires (si nécessaire, peuvent être indiquées sur la 2ème page)	
A sample of product was tested and found to be in conformity with IEC Un échantillon de ce produit a été essayé et été considéré conforme à la CEI	61010-1(ed.2)
National differences / Comments Les différences nationales / Commentaires	CA, US
This CB Test Certificate is issued by the National Certification Body:	Ce Certificat d'essai OC est établi par l'Organisme National de Certification
DEKRA Certification B.V. Utrechtseweg 310 P.O. Box 5185 6802 ED Arnhem The Netherlands	 DEKRA Certification is former KEMA Quality



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES
FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEM CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS
DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

As shown in the test report Ref. No. which forms part of this certificate
Comme indiqué dans le rapport d'essais numéro de référence qui constitue
partie de ce certificat

2138665.50-PEP

This CB Test Certificate is issued by the National Certification Body:

Ce Certificat d'essai OC est établi par l'Organisme National de Certification

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands



DEKRA Certification is
former KEMA Quality

Date: 2012-01-12

Signature: H.R.M. Barends

A handwritten signature in blue ink, appearing to read 'H.R.M. Barends', written over the printed name.