

# Safety manual for Fisher™ 8580, 8590, and Control-Disk™ Valves

## Purpose

This safety manual provides information necessary to design, install, verify and maintain a Safety Instrumented Function (SIF) utilizing the Fisher 8580, 8590, or Control-Disk valve.

### ⚠ WARNING

This instruction manual supplement is not intended to be used as a stand-alone document. It must be used in conjunction with the following manuals:

Fisher 8590 Rotary Valve Instruction Manual ([D104016X012](#))

Fisher 8580 Rotary Valve ([D103300X012](#))

Fisher Control-Disk Rotary Valve ([D103298X012](#)) ([D104143X012](#))

Failure to use this instruction manual supplement in conjunction with the above referenced manuals could result in personal injury or property damage. If you have any questions regarding these instructions or need assistance in obtaining any of these documents, contact your [Emerson Process Management sales office](#).



## Introduction

This manual provides necessary requirements for meeting the IEC 61508 or IEC 61511 functional safety standards.

Figure 1. Fisher 8580, 8590, and Control-Disk Valves



## Terms and Abbreviations

**Safety:** Freedom from unacceptable risk of harm.

**Functional Safety:** The ability of a system to carry out the actions necessary to achieve or to maintain a defined safe state for the equipment / machinery / plant / apparatus under control of the system.

**Basic Safety:** The equipment must be designed and manufactured such that it protects against risk of injury to persons by electrical shock and other hazards and against resulting fire and explosion. The protection must be effective under all conditions of the nominal operation and under single fault condition.

**Safety Assessment:** The investigation to arrive at a judgment - based on the facts - of the safety achieved by safety-related systems.

**Fail-Safe State:** State where valve actuator is de-energized and spring is extended.

**Fail Safe:** Failure that causes the valve to go to the defined fail-safe state without a demand from the process.

**Fail Dangerous:** Failure that does not respond to a demand from the process (i.e. being unable to go to the defined fail-safe state).

**Fail Dangerous Undetected:** Failure that is dangerous and that is not being diagnosed by automatic stroke testing.

**Fail Dangerous Detected:** Failure that is dangerous but is detected by automatic stroke testing.

**Fail Annunciation Undetected:** Failure that does not cause a false trip or prevent the safety function but does cause loss of an automatic diagnostic and is not detected by another diagnostic.

**Fail Annunciation Detected:** Failure that does not cause a false trip or prevent the safety function but does cause loss of an automatic diagnostic or false diagnostic indication.

**Fail No Effect:** Failure of a component that is part of the safety function but that has no effect on the safety function.

**Low Demand Mode:** Mode, where the frequency of demands for operation made on a safety-related system is no greater than twice the proof test frequency.

## Acronyms

**FMEDA:** Failure Modes, Effects and Diagnostic Analysis

**HFT:** Hardware Fault Tolerance

**MOC:** Management of Change. These are specific procedures often done when performing any work activities in compliance with government regulatory authorities.

**PFD<sub>AVG</sub>:** Average Probability of Failure on Demand

**SFF:** Safe Failure Fraction, the fraction of the overall failure rate of a device that results in either a safe fault or a diagnosed unsafe fault.

**SIF:** Safety Instrumented Function, a set of equipment intended to reduce the risk due to a specific hazard (a safety loop).

**SIL:** Safety Integrity Level, discrete level (one out of a possible four) for specifying the safety integrity requirements of the safety functions to be allocated to the E/E/PE safety-related systems where Safety Integrity Level 4 has the highest level of safety integrity and Safety Integrity Level 1 has the lowest.

SIS: Safety Instrumented System – Implementation of one or more Safety Instrumented Functions. A SIS is composed of any combination of sensor(s), logic solver(s), and final element(s).

## Related Literature

Hardware Documents:

*Bulletin:*

51.6:8590, Fisher 8590 Butterfly Valve: [D104017X012](#)

51.6:8580, Fisher 8580 Rotary Valve: [D103299X012](#)

51.3:Control-Disk, Fisher Control-Disk Rotary Valve: [D103297X012](#) & [D104025X012](#)

*Instruction Manual:*

Fisher 8590 Rotary Valve: [D104016X012](#)

Fisher 8580 Rotary Valve: [D103300X012](#)

Fisher Control-Disk Rotary Valve: [D103298X012](#) & [D104143X012](#)

Guidelines/References:

- Safety Integrity Level Selection – Systematic Methods Including Layer of Protection Analysis, ISBN 1-55617-777-1, ISA
- Control System Safety Evaluation and Reliability, 2nd Edition, ISBN 1-55617-638-8, ISA
- Safety Instrumented Systems Verification, Practical Probabilistic Calculations, ISBN 1-55617-909-9, ISA

## Reference Standards

Functional Safety

- IEC 61508: 2000 Functional safety of electrical/electronic/ programmable electronic safety-related systems
- ANSI/ISA 84.00.01-2004 (IEC 61511 Mod.) Functional Safety – Safety Instrumented Systems for the Process Industry Sector

## Product Description

The Fisher 8590, 8580, and Control-Disk valves are a series of high performance butterfly valves. The 8580 valve has a linear disk configuration with a square or splined output shaft and is available in sizes NPS 2 to 12 in CL150/300 pressure ratings. The 8590 valve also has a linear disk configuration with splined output shaft and is available in sizes NPS 3 to 24 in CL 600 pressure rating. Optional 8590 shaft output connections are available in sizes 3 to 12 for square and sizes 14 to 24 for keyed. All three valve types are designed to meet international standards for pressure and temperature ratings, shell thickness, and bore diameters. They are engineered to control process fluids that can be used in a wide variety of applications and are typically used with other interface components (valve actuator and positioner or solenoid valve) to provide a final element subsystem for a SIF.

# Designing an SIF Using Fisher 8580, 8590, or Control-Disk Valve

## Safety Function

When the valve's actuator is de-energized, the actuator and valve shall move to its fail-safe position. Depending on which configuration is specified fail-closed or fail-open, the actuator will rotate the valve disk to close off the flow path through the valve body or open the flow path through the valve body.

The 8580, 8590, or Control-Disk valve is intended to be part of final element subsystem as defined per IEC 61508 and the achieved SIL level of the designed function must be verified by the designer.

## Pressure, Temperature, and Environmental limits

The designer of an SIF must check that the product is rated for use within the expected pressure, temperature, and environmental limits. Refer to the 8580, 8590, or Control-Disk valve product bulletin for these limits.

## Application limits

The materials of construction of 8580, 8590, or Control-Disk valves are specified in the product bulletin. A range of materials are available for various applications. The serial card will indicate what the materials of construction are for a given valve. It is especially important that the designer check for material compatibility considering on-site chemical contaminants and environmental conditions. If the 8580, 8590, or Control-Disk valve is used outside of the application limits or with incompatible materials, the reliability data provided becomes invalid.

## Diagnostic Response Time

The 8580, 8590, or Control-Disk valve does not perform any automatic diagnostic functions by itself and therefore it has no diagnostic response time of its own. However, automatic diagnostics of the final control subsystem may be performed such as Partial Valve Stroke Testing (PVST). This typically will exercise the valve over a small percentage of its normal travel without adversely affecting the flow through the valve. If any failures of this PVST are automatically detected and annunciated, the diagnostic response time will be the PVST interval time. The PVST must be performed 10 times more often than an expected demand in order for credit to be given for this test.

## Design Verification

A detailed FMEDA report is available from Emerson Process Management. This report details all failure rates and failure modes as well as the expected lifetime.

The achieved SIL of an entire SIF design must be verified by the designer via a calculation of  $PFD_{AVG}$  considering architecture, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with minimum HFT requirements.

When using an 8580, 8590, or Control-Disk valve in a redundant configuration, a common cause factor of at least 5% should be included in the Safety Integrity calculations. This value is dependent on the level of common cause training and maintenance in use at the end user's facility.

The failure rate data listed the FMEDA report is only valid for the useful lifetime of an 8580, 8590, or Control-Disk valve. The failure rates will increase after this time period. Reliability calculations based on the data listed in the FMEDA

report for mission times beyond the useful lifetime may yield results that are too optimistic, i.e. the calculated Safety Integrity Level will not be achieved.

## SIL Capability

### Systematic Integrity

---

Figure 2. exida SIL 3 Capable



The product has met manufacturer design process requirements of IEC 61508 Safety Integrity Level 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer. An SIF designed with this product must not be used at a SIL level higher than stated without “prior use” justification by the end user or diverse technology redundancy in the design.

### Random Integrity

The 8580, 8590, and Control-Disk valves are classified as Type A devices according to IEC 61508, having a hardware fault tolerance of 0. The complete final element subsystem, with a Fisher butterfly valve as the final control element, will need to be evaluated to determine the Safe Failure Fraction of the subsystem. If the SFF for the entire final element subsystem is between 60% and 90%, a design can meet SIL 2 @ HFT=0.

### Safety Parameters

For detailed failure rate information refer to the Failure Modes, Effects and Diagnostic Analysis Report for the 8580, 8590, and Control-Disk valve.

## Connection of the Fisher 8580, 8590, or Control-Disk Valve to the SIS Logic-solver

The final element subsystem (consisting of a positioner, actuator, and 8580, 8590, or Control-Disk valve) is connected to the safety rated logic solver which is actively performing the Safety Function as well as any automatic diagnostics designed to diagnose potentially dangerous failures within the 8580, 8590, or Control-Disk valve, actuator and any other final element components, (i.e. Partial Valve Stroke Test).

## General Requirements

The system's response time shall be less than process safety time. The final control element subsystem needs to be sized properly to assure that the response time is less than the required process safety time. The 8580, 8590, or Control-Disk valve will move to its safe state in less than the required SIF's safety time under the specified conditions.

All SIS components including the 8580, 8590, or Control-Disk valve must be operational before process start-up.

The user shall verify that the 8580, 8590, or Control-Disk valve is suitable for use in safety applications.

Personnel performing maintenance and testing on the 8580, 8590, or Control-Disk valve shall be competent to do so.

Results from the proof tests shall be recorded and reviewed periodically.

The useful life of the 8580, 8590, or Control-Disk valve is discussed in the Failure Modes, Effects and Diagnostic Analysis Report for the Fisher 8580, 8590, or Control-Disk valve.

## Installation and Commissioning

### Installation

The Fisher 8580, 8590, or Control-Disk valve must be installed per standard practices outlined in the appropriate instruction manual.

The environment must be checked to verify that pressure, temperature, and environmental conditions do not exceed the ratings.

The 8580, 8590, or Control-Disk valve must be accessible for physical inspection.

### Physical Location and Placement

The Fisher 8580, 8590, or Control-Disk valve shall be accessible with sufficient room for the actuator, pneumatic connections, any other components of the final control element. Provisions shall be made to allow for manual proof testing.

Pneumatic piping to the actuator shall be kept as short and straight as possible to minimize the airflow restrictions and potential clogging. Long or kinked pneumatic tubes may also increase the valve closure time.

The 8580, 8590, or Control-Disk valve shall be mounted in a low vibration environment. If excessive vibration can be expected special precautions shall be taken to ensure the integrity of pneumatic connectors or the vibration should be reduced using appropriate damping mounts.

## Operation and Maintenance

### Suggested Proof Test

The objective of proof testing is to detect failures within an 8580, 8590, or Control-Disk valve that are not detected by any automatic diagnostics of the system. Of main concern are undetected failures that prevent the Safety Instrumented Function from performing its intended function.

The frequency of proof testing, or the proof test interval, is to be determined in reliability calculations for the Safety Instrumented Functions for which an 8580, 8590, or Control-Disk valve is applied. The proof tests must be performed more frequently than or as frequently as specified in the calculation in order to maintain the required Safety Integrity of the Safety Instrumented Function.

The proof test shown in table 1 is recommended. The results of the proof test should be recorded and any failures that are detected and that compromise functional safety should be reported to Emerson Process Management. The suggested proof test consists of a full stroke of the 8580, 8590, or Control-Disk valve.

The person(s) performing the proof test of a 8580, 8590, or Control-Disk valve should be trained in SIS operations, including bypass procedures, valve maintenance and company Management of Change procedures. No special tools are required.

**Table 1. Recommended Full Stroke Proof Test**

Step	Action
1	Bypass the safety function and take appropriate action to avoid a false trip.
2	Interrupt or change the signal/supply to the actuator to force the actuator and valve to perform a full stroke to the Fail-Safe state and confirm that the Safe State was achieved and within the correct time.
3	Restore the supply/signal to the actuator and confirm that the normal operating state was achieved.
3	Inspect the 8580, 8590, or Control-Disk valve and the other final control element components for any leaks, visible damage or contamination.
4	Record the test results and any failures in your company's SIF inspection database.
5	Remove the bypass and restore normal operation.

## Repair and replacement

Repair procedures in the appropriate valve instruction manual must be followed.

## Manufacturer Notification

Any failures that are detected and that compromise functional safety should be reported to Emerson Process Management. Please contact Emerson Process Management customer service or your local Emerson Process Management service representative.

## Status of the Document

### Releases

Version History: (Version, Status, Date)

## Appendix A

### Sample Startup Checklist

This appendix provides a Sample Start-up Checklist for a Fisher 8580, 8590, or Control-Disk valve. A start-up checklist will provide guidance during the final control elements employment.

#### Start-Up Checklist

The following checklist may be used as a guide to employ the 8580, 8590, or Control-Disk valve in a safety critical SIF compliant to IEC61508.

#	Activity	Result	Verified	
			By	Date
<b>Design</b>				
	Target Safety Integrity Level and $PFD_{AVG}$ determined			
	Correct valve mode chosen (Fail-closed, Fail-open)			
	Design decision documented			
	Pneumatic compatibility and suitability verified			
	SIS logic solver requirements for valve tests defined and documented			
	Routing of pneumatic connections determined			
	SIS logic solver requirements for partial stroke tests defined and documented			
	Design formally reviewed and suitability formally assessed			
<b>Implementation</b>				
	Physical location appropriate			
	Pneumatic connections appropriate and according to applicable codes			
	SIS logic solver valve actuation test implemented			
	Maintenance instructions for proof test released			
	Verification and test plan released			
	Implementation formally reviewed and suitability formally assessed			
<b>Verification and Testing</b>				
	Electrical connections verified and tested			
	Pneumatic connection verified and tested			
	SIS logic solver valve actuation test verified			
	Safety loop function verified			
	Safety loop timing measured			
	Bypass function tested			
	Verification and test results formally reviewed and suitability formally assessed			
<b>Maintenance</b>				
	Tubing blockage / partial blockage tested			
	Safety loop function tested			

Neither Emerson, Emerson Process Management, nor any of their affiliated entities assumes responsibility for the selection, use or maintenance of any product. Responsibility for proper selection, use, and maintenance of any product remains solely with the purchaser and end user.

Fisher and Control-Disk are marks owned by one of the companies in the Emerson Process Management business unit of Emerson Electric Co. Emerson Process Management, Emerson, and the Emerson logo are trademarks and service marks of Emerson Electric Co. All other marks are the property of their respective owners.

The contents of this publication are presented for informational purposes only, and while every effort has been made to ensure their accuracy, they are not to be construed as warranties or guarantees, express or implied, regarding the products or services described herein or their use or applicability. All sales are governed by our terms and conditions, which are available upon request. We reserve the right to modify or improve the designs or specifications of such products at any time without notice.

Emerson Process Management  
 Marshalltown, Iowa 50158 USA  
 Sorocaba, 18087 Brazil  
 Cernay, 68700 France  
 Dubai, United Arab Emirates  
 Singapore 128461 Singapore

[www.Fisher.com](http://www.Fisher.com)

