

CERTIFICATE OF COMPLIANCE

Certificate Number R-E10444
Report Reference E10444-20200521
Issue Date 2020-JUNE-11

Issued to: APPLETON GROUP
9377 W HIGGINS RD
ROSEMONT IL 60018

**This certificate confirms that
representative samples of**

LUMINAIRE FITTINGS FOR USE IN HAZARDOUS
LOCATIONS; LUMINAIRES, MISCELLANEOUS, MARINE
See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 844 - Luminaires for Use in Hazardous (Classified)
Locations.
CSA C22.2 No. 137-M1981 - Electric Luminaires for Use in
Hazardous Locations.
UL 1598A - Supplemental Requirements for Luminaires for
Installation on Marine Vessels.
UL 1598 and CSA C22.2 NO. 250.0-18 - Luminaires.
UL 50E and CSA C22.2 NO. 94.2 - Enclosures for Electrical
Equipment, Environmental Considerations.
IEC 60529 - DEGREES OF PROTECTION REQUIRED BY
ENCLOSURE.


Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number R-E10444
Report Reference E10444-20200521
Issue Date 2020-JUNE-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Series ERM Rigmaster Explosionproof Linear LED Luminaire Fittings for use in hazardous locations, Class I, Division 1 Groups C and D; Class II, Division 1 Groups E, F, and G.

Luminaire Housing: Cat. Nos. ERM; followed by B, L, or N; followed by 2 or 4; followed by 1, 2, or 3; followed by C, N, or W; followed by F or C; followed by L; followed by BU or BH; followed by N; followed by G, R, or Y; followed by W or T; may be followed by 1 or 2.

Mounting Means:
Cat nos. ERMLSB and ERMLPB.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

