

Summary Sheet

No. TJ2206290101

Data: June. 29, 2022

Page 1 of 2

Client's name: EMERSON PROCESS MANAGEMENT (TIANJIN) VALVE CO.,LTD.

Client's address: No.15 XING WANG ROAD, WUQING DEVELOPMENT AREA, TIANJIN,
P.R.CHINA

SGS Ref. No. : TP22-003209

Sample Name : Actuator

Model No. : G4020

Date of Receipt : 2022-05-10

Testing Period : 2022-05-12 ~ 2022-06-29

Test Method : IEC 60529:1989/AMD2:2013/COR1:2019

Test Summary : The sample meets the requirements of IP6X, IPX6, IPX7M in the
standard. For further results, please refer to the following page(s)

Testing Report No. : RSTSTJ220629000101

SGS CSTC Standards Technical
Services (Tianjin) Co., Ltd.



Summary Sheet**No. TJ2206290101**

Data: June. 29, 2022

Page 2 of 2

Summary of Results:

No.	Test Item	Test Method	Result	Conclusion
1	IPX6	IEC 60529:1989/AMD2:2013/COR1:2019	No observed water ingress	Pass
2	IPX7M		No observed water ingress	Pass
3	IP6X		No observed dust ingress	Pass

Note: Pass : Meet the requirements;
Fail : Does not meet the requirements;
/ : Not Apply to the judgment.